
All TSOs' Common Grid Model Alignment Methodology in accordance with Article 24(3)(c) of the Common Grid Model Methodology

29 November 2017

1
2

Table of Contents

3			
4			
5	1	Introduction	6
6			
7	2	Legal background	9
8	2.1	Regulation 2015/1222	9
9	2.2	Other European legislation	10
10	2.3	Common Grid Model Methodology ("CGMM")	11
11			
12	3	CGMA Algorithm	18
13	3.1	The three phases of the CGMA process	18
14	3.2	Requirements with respect to the PPD	21
15	3.3	Processing phase: the CGMA algorithm	26
16	3.4	Post-processing phase	41
17			
18	4	Business processes	42
19	4.1	CGMA business processes overview	42
20	4.2	Summary of the three phases	42
21	4.3	Pre-processing phase process steps	46
22	4.4	Processing phase process steps	48
23	4.5	Post-processing phase process steps	67
24	4.6	Deadlines for all process steps and all time frames	69
25			
26	5	Reporting	71
27			
28	6	IT implementation	72
29	6.1	CGMA IT platform within the overall IT architecture	72
30	6.2	The CGMA IT specification	74
31	6.3	Summary of CGMA Data Exchanges Implementation Guide	80
32			
33			
34			

35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58

<h2>Table of Contents for Annexes</h2>
--

I.	ANNEX - Test Results.....	82
II.	ANNEX - Coordinated Pre-processing Approaches.....	83
	II (i) Pre-processing approach of CORESO.....	84
	II (ii) Pre-processing approach of Nordic RSC.....	89
	II (iii) Pre-processing approach of Baltic RSC.....	108
	II (iv) Pre-processing approach of SCC.....	110
III.	ANNEX - Summary of parameters used.....	118
IV.	ANNEX - Data Formats.....	120
V.	ANNEX - Glossary.....	123
VI.	ANNEX - CGM area in terms of coverage of bidding zones (as of 2017-07) as well as DC lines.....	125
VII.	ANNEX - CGM area in terms of coverage of CGMA algorithm optimisation areas (as of 2017-07) as well as DC lines.....	132

59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92

List of figures

Figure 1:	Phases of CGMA process.....	20
Figure 2:	Unbalanced preliminary AC-only net positions and preliminary DC flows at the start of the processing phase	26
Figure 3:	Balanced AC-only net positions and balanced DC flows at the end of the processing phase.....	28
Figure 4:	Absolute minimum and maximum net positions.....	45
Figure 5:	Substitution matrix	55
Figure 6:	Operational Planning Data Environment (stylised representation)	73
Figure 7:	Operational Planning Data Environment (stylised architecture).....	73
Figure 8:	CGMA IT platform architecture	74
Figure 9:	CGMA external data exchanges (D-2) excluding DC PSLC sub-process	76
Figure 10:	Retraining frequency (illustration)	86
Figure 11:	Principle of the Support Vector Machine (SVM) algorithm.....	88
Figure 12:	Example of estimated (brown) and market (blue) flows and the minimum and maximum net positions for SE1.....	97
Figure 13:	Lowest and highest maximum positions in 2015 and physical maximum.	98
Figure 14:	Bidding zone with transfer flow	99
Figure 15:	Correlations between German renewable generation and Nordic net positions	100
Figure 16:	Effect of including German net demand in the calculation of the sum of squared net demands	101
Figure 17:	Preliminary distribution functions of the flow errors	102
Figure 18:	Supply and demand curves for one area, original (to the left) and modified (to the right).....	103
Figure 19:	Supply and demand curves German/Austria (source: EPEX)	104
Figure 20:	Comparison of MAEs for three approaches	106
Figure 21:	Overview of pre-processing approach envisaged in Baltic region	108
Figure 22:	Dispersion of deviation between forecasted net position and realized net positions for EMS, for test period of one year	116
Figure 23:	Absolute forecast errors for all test hours	117
Figure 24:	Stylised topology of CGMA optimisation areas.....	142

93

94

List of tables

95

96 Table 1: Instantaneous peak load 2016 24

97 Table 2: Test case results, bidding zones 94

98 Table 3: Test case results, countries 94

99 Table 4: Test case results, HVDC flows 96

100 Table 5: Mean Average Error per bidding zone in MW for the Euphemia based
101 approach, compared with alternatives 105

102 Table 6: Mean Average Error per country in MW for the Euphemia based
103 approach, compared with alternatives 106

104 Table 7: CGMA input data 121

105 Table 8: CGMA output data 122

106 Table 9: DC lines to be included in CGMA process (as of 2017-07)..... 141

107

108 1 Introduction

109

110 One of the key inputs for any individual grid model ("IGM") of a bidding zone (or control area¹)
111 is that bidding zone's net position for the corresponding market time unit. Article 2(5) of
112 Regulation 2015/1222² defines net position as "the netted sum of electricity exports and imports
113 for each market time unit for a bidding zone"³. In other words, the net position (typically
114 measured in the unit "MW") is a number that states whether a bidding zone is a (net) exporter or
115 (net) importer of electricity. If the net position is positive, the bidding zone is a net exporter; if
116 the net position is negative, the bidding zone is a net importer⁴.

117

118 When no market schedules are available TSOs will typically base their IGM on an estimate of
119 the net position which, in the first instance, they are free to determine by themselves. However,
120 TSOs collectively have to respect a critical consistency requirement: all net positions within an
121 interconnected system have to sum to zero because the sum of exports has to be equal to the
122 sum of imports. When this consistency requirement is met, the net positions are referred to as
123 "balanced" and the IGMs are said to be "aligned". Unless this condition is fulfilled, it is not
124 possible to merge the IGMs from all TSOs into the Common Grid Model ("CGM").

125

126 Establishing balanced net positions is, in principle, straightforward for those time frames for
127 which schedule data are available (i.e., day-ahead and intraday). However, for time frames for
128 which schedules are not available; specifically, the

129

- (D-2) (two days ahead),

130

- (W-1) (week-ahead),

131

- (M-1) (month-ahead), and

132

- (Y-1) (year-ahead)

133

134

time frames; balanced net positions have to be established via a process known as "Common
Grid Model Alignment" ("CGMA"). The CGMA process consists of a set of procedures by
which the initial (preliminary) estimates of net positions are revised such that the resulting set of
net positions is balanced. The present CGMA Methodology ("CGMAM") collects these
procedures into a single document and describes them in detail.

138

139

140

The CGMA approach supersedes the practice of using net positions for a historical reference
timestamp. Since net positions for any historical reference timestamp have to be balanced by
definition, if all TSOs use their net position during that historical reference timestamp in a
model to be built for a future timestamp, the net positions will be balanced. However, since the

142

¹ Where a control area comprises more than one bidding zone, the TSO may provide a single IGM for the whole control area, cf. Chapter VI. For the sake of simplicity, the present document does not distinguish between the two cases and uses the term "bidding zone" only. Note, too, that "bidding zone" in the sense in which the term is used in the present document does not refer to internal bidding zones within a control area such as exist in Italy, Norway, or Sweden. Since in mathematical terms the CGMA algorithm represents a constrained optimisation, the bidding zones are also referred to as "optimisation areas."

² Commission Regulation (EU) 2015/1222 of 24 July 2015 establishing a guideline on capacity allocation and congestion management

³ A more precise way of referring to net positions in the sense in which the term is used in the present document would be to refer to "aggregate AC/DC net positions". However, the simpler (and slightly less accurate) term "net position" is used in order to be consistent with the terminology in Regulation 2015/1222.

⁴ In CGMES grid models, the converse sign convention is used.

143 future target timestamp is likely to differ from the historical reference timestamp, use of
144 historical net positions is not likely to provide a best estimate. The introduction of the CGMA
145 approach thus gives TSOs much more freedom in defining the scenarios for which they build
146 their models. In fact, as long as the requirements with respect to the input data are respected, the
147 CGMA approach will be able to accommodate any scenario.

148

149 Flows on direct current ("DC") lines linking different bidding zones are, of course, taken into
150 account when computing net positions if the DC line links different CGMA optimisation areas.
151 However, they impose special constraints with respect to the CGMA process. The CGMAM
152 addresses this challenge, too, and ensures that flows on DC lines are also consistent. The flows
153 thus established are referred to as "balanced flows on DC lines".

154

155 The remainder of the present introduction provides an overview of the document which is being
156 prepared on the basis of the Common Grid Model Methodology ("CGMM"). The CGMM exists
157 in three versions and was drafted by all TSOs just like the present document. The CGMM-v1-
158 plus (pursuant to Commission Regulation (EU) 2015/1222 of 24 July 2015 establishing a
159 guideline on capacity allocation and congestion management - the "CACM Guideline") covers
160 the day-ahead and intraday capacity calculation time frames and was approved by all NRAs in
161 May 2017. The CGMM-v2 (pursuant to Commission Regulation (EU) 2016/1719 of 26
162 September 2016 establishing a guideline on forward capacity allocation - the "FCA Guideline")
163 covers the month-ahead and year-ahead time frames and was submitted to all NRAs for
164 approval in July 2017. Finally, at the time of revision in November 2017 the CGMM-v3 was
165 being drafted pursuant to Commission Regulation (EU) 2017/1485 of 02 August 2017
166 establishing a guideline on electricity transmission system operation (the "SO Guideline"). The
167 relevant legal background is explained in Chapter 2. The CGMAM is a more flexible document
168 than the CGMM in that the latter requires regulatory approval whereas the former does not. It is
169 thus expected that the CGMAM will be revised more frequently. However, each revision needs
170 to be backed by a positive "All TSOs" vote.

171

172 Chapter 3 explains the CGMA algorithm. As will be explained below, the CGMA algorithm is
173 crucial in ensuring that the preliminary net positions can be transformed into balanced net
174 positions. The application of the CGMA algorithm is integrated into the overall CGMA
175 business processes which are described in Chapter 4.

176

177 Chapter 5 is dedicated to the reporting of key performance and quality indicators. CGMA being
178 a crucial starting point for processes such as capacity calculation, TSOs need to ensure that they
179 monitor it in a robust manner and make relevant data available for checking by external
180 stakeholders, too.

181

182 The last chapter in the body of the CGMAM, Chapter 6, provides an overview of the IT
183 arrangements required to implement the CGMA process.

184

185

186 The annexes contain in-depth descriptions of a number of rather technical topics. Annex I
187 summarises the results of two rounds of comprehensive tests used to gauge the performance of
188 the CGMA algorithm. The pre-processing approaches proposed by Regional Security
189 Coordinators and / or TSOs are the subject of Annex II. Pre-processing approaches aim at
190 minimising the adjustments required in order to compute balanced net positions, so three of the
191 future "alignment agents"⁵ have taken it upon themselves to develop strategies in this regard. A
192 summary of the parameters referenced in the CGMAM and on the data formats to be used as
193 part of the IT set-up are appended as Annexes III and IV, respectively.

194

195 Annex V contains a glossary. This also serves as a correspondence table which for a number of
196 important terms used in the present document states the equivalent terms used in related
197 documents. The last two annexes of the document, Annexes VI and VII, provide a list of the
198 bidding zones to be included in the CGMA process and a list of the optimisation areas and DC
199 lines used by the CGMA algorithm, respectively.

200

201 It should be noted that the material provided in this version of the CGMAM – especially the
202 descriptions of the algorithm, the processes and associated performance indicators, as well as
203 the IT setup – reflect the design envisaged as of the summer of 2017. TSOs are planning to
204 organise a parallel run ("dry run") towards the end of 2017 during which all aspects of this
205 design will be tested in practice. If during the parallel run additional adjustments to the
206 algorithm, processes, IT setup, etc. seem called for, these can still be specified and implemented
207 in advance of the go-live of the overall CGM process planned for June 2018 at the time of
208 revision.

209

210

211

212

213

214

215

216

217

218

219

220

221

222

223

224 Note to readers not associated with an ENTSO-E member organisation:

225 The present document is made available to stakeholders not associated with ENTSO-E member
226 organisations for the purpose of increasing transparency about TSOs' procedures and in order to
227 meet the legal requirement set out in Article 24(3)(c) of the Common Grid Model Methodology.

⁵ The role of "alignment agent" will be handled by Regional Security Coordinators (RSCs).

228 **2 Legal background**

229

230 The present chapter describes the legal framework for the CGMAM. The need for the CGMA
231 process is recognised in European legislation; specifically, Commission Regulation (EU)
232 2015/1222 of 24 July 2015 establishing a guideline on capacity allocation and congestion
233 management ("Regulation 2015/1222"). The TSOs have transposed the requirements set out in
234 Regulation 2015/1222 into their "All TSOs' proposal for a common grid model methodology in
235 accordance with Article 17 of Commission Regulation (EU) 2015/1222 of 24 July 2015
236 establishing a guideline on capacity allocation and congestion management" ("Common Grid
237 Model Methodology" or "CGMM"). While Regulation 2015/1222 is the only item of European
238 legislation that explicitly refers to the CGMA process, this process is implicitly required by
239 other items of legislation stipulating that TSOs prepare CGMs for time frames for which
240 schedules are not available.

241

242 **2.1 Regulation 2015/1222**

243

244 The most important passage in this Regulation is the following Article 18(3) which explicitly
245 requires TSOs to prepare the CGMAM:

246

For each scenario, all TSOs shall jointly draw up common rules for determining the net position in each bidding zone and the flow for each direct current line. These common rules shall be based on the best forecast of the net position for each bidding zone and on the best forecast of the flows on each direct current line for each scenario and shall include the overall balance between load and generation for the transmission system in the Union. There shall be no undue discrimination between internal and cross-zonal exchanges when defining scenarios, in line with point 1.7 of Annex I to Regulation (EC) No 714/2009.

247

248 In addition, Article 19(4) is relevant:

249

All TSOs shall harmonise to the maximum possible extent the way in which individual grid models are built.

250

251 Along with the other requirements set out in Regulation 2015/1222 relating to the Common
252 Grid Model, these provisions have been transposed into the CGMM by the TSOs.

253

254

255

256 2.2 Other European legislation

257

258 Two other European Regulations – the Commission Regulation (EU) 2016/1719 of 26
259 September 2016 establishing a guideline on forward capacity allocation ("FCA Guideline") and
260 the Commission Regulation (EU) 2017/1485 of 02 August 2017 establishing a guideline on
261 electricity transmission system operation ("SO Guideline") – also require TSOs to build a CGM
262 for time frames at which schedules are not available.

263

264 Specifically, Article 22 of the FCA Guideline stipulates that *"The process and requirements*
265 *set in Article 28 of Regulation (EU) 2015/1222 for creating a common grid model shall*
266 *apply when creating the common grid model for long-term capacity calculation time frames*
267 *in capacity calculation regions, where security analysis based on multiple scenarios*
268 *pursuant to Article 10 is applied."* In practical terms, this applies to year-ahead and month-
269 ahead CGMs.

270

271 The SO Guideline requires TSOs to build year-ahead CGMs for the purpose of performing
272 operational security analysis. Week-ahead CGMs are not mandatory at pan-European level. In
273 the case of the week-ahead CGM, Article 69(1) of the SO Guideline makes it clear that this
274 applies to TSOs "coordinating the operational security analysis of their transmission system for
275 the week-ahead timeframe": *"Where two or more TSOs consider it necessary, they shall*
276 *determine the most representative scenarios for coordinating the operational security analysis*
277 *of their transmission system for the week-ahead timeframe and shall develop a methodology for*
278 *merging the individual grid models analogous to the methodology for building the year-ahead*
279 *common grid model from year-ahead individual grid models in accordance with Article 67(1)."*

280

281 Note, however, that neither Regulation addresses the topic of CGM alignment explicitly.

282

283 While only the year-ahead and the two-days ahead CGMs are mandatory at pan-European level,
284 the CGMAM covers all time-frames for which CGMs are required, but schedules are not
285 available. Therefore although the different Regulations cited above cover different time frames
286 only a single CGMAM is required.

287

288

289

290 2.3 Common Grid Model Methodology ("CGMM")

291

292 Regulation 2015/1222 requires TSOs to jointly prepare a Common Grid Model Methodology
293 ("CGMM") that *"enable[s] a common grid model to be established."* (Article 17(2) of
294 Regulation 2015/1222). The CGMM sets out the TSOs' rules for preparing the Common Grid
295 Model (required by Regulation 2015/1222 as well as other items of European legislation; see
296 above) and was approved by NRAs in May 2017. Given the crucial importance of CGM
297 alignment in the preparation of both IGMs and CGMs, the CGMM contains detailed
298 requirements in this regard.

299

300 As was noted in the introduction, there are actually three different versions of the CGMM.
301 However, the provisions regarding Common Grid Model Alignment are consistent across the
302 three versions. For the avoidance of doubt, references to the CGMM denote references to the
303 CGMM prepared pursuant to Regulation 2015/1222 (CGMM-v1-plus).

304

305 Specifically, Article 4(2)(e) and (f) of the CGMM oblige TSOs to complete the following tasks
306 when building their IGM:

307

e. apply the common rules for determining the net position in each bidding zone and the flow
for each direct current line set out in Articles 18 and 19;

f. ensure that the model is consistent with the net positions and flows on direct current lines
established in accordance with Articles 18 and 19;

308

309

310 Articles 18 and 19 of the CGMM read as follows:
311

Article 18

Net positions and flows on direct current lines

1. For all scenarios for the day-ahead capacity calculation time-frame pursuant to Article 3, each TSO shall follow the CGM alignment procedure described in Article 19 in order to comply with Article 18(3) of Regulation 2015/1222.
2. For all scenarios for the intraday capacity calculation time-frame pursuant to Article 3, in order to comply with Article 18(3) of Regulation 2015/1222
 - a. the best forecast of the net position for each bidding zone and of the flow on each direct current line shall be based on verified matched scheduled exchanges;
 - b. each TSO shall share with all other TSOs the net position for its bidding zone(s) and the values for the flow on each direct current line used in its IGM via the information platform described in Article 21 in accordance with the CGM process described in Article 22.
3. For all scenarios pursuant to Article 3 in case of bidding zones connected by more than one direct current line, in order to comply with Article 18(3) of Regulation 2015/1222 the TSOs concerned shall agree on consistent values for the flows on direct current lines to be used in each TSO's IGM. These shall also be the values that the TSOs make available to all other TSOs.

312
313 Article 19 covers CGM alignment proper; i.e., addresses the case where schedules are not
314 available at the two-days ahead time horizon:
315

Article 19

CGM alignment

1. For each scenario for the day-ahead capacity calculation time-frame pursuant to Article 3, each TSO shall prepare and share with all other TSOs via the information platform referred to in Article 21 in accordance with the CGM process description set out in Article 22 its best forecast of
 - a. the net position for its bidding zone, being its preliminary net position;
 - b. the flow on each direct current line connected to its bidding zone being the preliminary flows on each direct current line;
 - c. any other input data required by the algorithm pursuant to paragraph 2.
2. All TSOs shall jointly define an algorithm which for each scenario and for all bidding zones aligns the preliminary net positions and preliminary flows on each direct current line in such a way that following the adjustment by the algorithm
 - a. the sum of adjusted net positions for all bidding zones in the CGM area balances the targeted net position for the CGM area;
 - b. for all bidding zones connected by at least one direct current line the sum of

- flows on all direct current lines is mutually consistent for both bidding zones concerned.
3. The algorithm shall have the following properties or features in order to ensure that in accordance with Article 18(3) of Regulation 2015/1222 there is no undue discrimination between internal and cross-zonal exchanges:
 - a. the alignments of preliminary net positions and preliminary flows on each direct current line shall be spread across all bidding zones and no bidding zone shall benefit from any preferential treatment or privileged status with respect to the operation of the algorithm;
 - b. in its objective function the algorithm shall give appropriate weight to the following when determining the adjustments required:
 - i. the size of the adjustments required to each preliminary net position and the preliminary flows on each direct current line, which shall be minimised;
 - ii. the ability of a bidding zone to adjust its preliminary net position and the preliminary flows on each direct current line, based on objective and transparent criteria;
 - c. the algorithm shall specify objective and transparent consistency and quality criteria which the input data required from each TSO shall meet;
 - d. the algorithm shall be robust enough to provide the results pursuant to paragraph 2 in all circumstances given the input data provided to it.
 4. TSOs shall agree on procedures
 - a. to reduce the absolute value of the sum of preliminary net positions for all bidding zones in the CGM area; and
 - b. to provide updated input data if necessary; and
 - c. to take into account reserve capacity and stability limits if it becomes necessary to update input data.
 5. TSOs shall regularly review and, if appropriate, improve the algorithm.
 6. TSOs shall publish the algorithm as part of the data to be provided pursuant to Article 31(3) of Regulation 2015/1222. If the algorithm was modified during the reporting period, TSOs shall clearly state which algorithm was in use during which period and they shall explain the reasons for modifying the algorithm.
 7. All TSOs shall jointly ensure that the algorithm is accessible to the relevant parties via the information platform referred to in Article 21.
 8. In accordance with Article 81 of Regulation 2015/1222 each TSO shall designate an alignment agent who shall perform, on behalf of the TSO, the following tasks in accordance with the process described in Article 22:
 - a. check the completeness and quality of the input data provided pursuant to paragraph 1 and, if necessary, replace missing data or data of insufficient quality with substitute data;
 - b. apply the algorithm in order to compute for each scenario and each bidding zone aligned net positions and aligned flows on all direct current lines that meet the requirements set out in paragraph 2 and make these available to all TSOs via the information platform referred to in Article 21;

- c. ensure that the results obtained are consistent with those obtained by all other alignment agents (if any).
9. Pursuant to Article 4(2)(f), each TSO shall ensure that its IGM is consistent with the aligned net position and aligned flows on direct current lines provided by the alignment agent.

316

317 The provisions in the CGMM Articles cited above outline the essential features of the CGMA
318 Methodology; these are explained in more detail in the present document.

319

320 Article 21 of the CGMM on the "Information platform" (known as the Operational Planning
321 Data Environment or "OPDE") also contains a number of provisions that are relevant for the
322 CGMA process:

323

Article 21 **Information platform**

1. All TSOs shall delegate the task of implementing and administering a joint information platform that provides at least the services described in paragraph 2 in accordance with Article 81 of Regulation 2015/1222.
 2. The information platform shall at a minimum support the CGM process in the following ways and it shall have all the features required to this end:
 - a. intraday capacity calculation time-frame - each TSO shall be able to use the information platform in order to share with all other TSOs the net position for its bidding zone(s) and the values for the flow on each direct current line used in its IGM pursuant to the CGM process described in Article 22;
 - b. (...)
 - c. day-ahead capacity calculation time-frame - each TSO shall be able to use the information platform in order to share with all other TSOs pursuant to the CGM process described in Article 22 its best forecast of
 - i. the net position for its bidding zone, comprising its preliminary net position;
 - ii. the flow on each direct current line connected to its bidding zone comprising the preliminary flows on each direct current line;
 - iii. any other input data required by the algorithm further to Article 19(2);
 - d. the algorithm pursuant to Article 19(2) shall be accessible via the information platform;
 - e. the alignment agent(s) shall be able to make the aligned net positions and aligned flows on direct current lines that meet the requirements set out in Article 19(2) available to all TSOs via the information platform;
- (...)

324

325 The most important process steps applicable to the two-days ahead CGMA process are set out in
326 Article 22 of the CGMM:
327

Article 22
CGM process

1. When preparing the CGM for the day-ahead capacity calculation time-frame, all TSOs, merging agents and alignment agents shall complete the following steps:
 - a. each TSO shall make preliminary net positions, preliminary flows on direct current lines as well as any other input data required for the CGM alignment process available to all TSOs via the information platform referred to in Article 21;
 - b. the alignment agent(s) shall check the completeness and quality of the input data provided pursuant to Article 19(1) and, if necessary, replace missing data or data of insufficient quality with substitute data;
 - c. the alignment agent(s) shall apply the algorithm in order to compute for each scenario and each bidding zone aligned net positions and aligned flows on direct current lines that meet the requirements set out in Article 19(2);
 - d. the alignment agent(s) shall make these aligned net positions and aligned flows on direct current lines available to all TSOs via the information platform referred to in Article 21;

(...)
2. When preparing the CGM for the intraday capacity calculation time-frame, all TSOs, merging agents, and alignment agents shall complete the following steps:
 - a. each TSO shall make its net position and flows on direct current lines for each scenario for the intraday capacity calculation time-frame available to all TSOs via the information platform referred to in Article 21. TSOs in bidding zones where the cross-zonal intraday market for the following day opens before 16:30h shall use the data as of 16:00h;

(...)

328
329 Article 23 of the CGMM on "Quality monitoring" addresses the need for TSOs to provide high-
330 quality input data for the CGMA process and to be transparent about how well the CGMA
331 process is functioning. In particular, as will be stressed throughout the present document, TSOs
332 shall publish data that make it possible to assess whether the "no undue discrimination"
333 requirement set out in Article 18(3) of Regulation 2015/1222 is being respected.
334

335

Article 23
Quality monitoring

(...)

3. All TSOs shall jointly define criteria that the preliminary net positions and preliminary flows on direct current lines as well as the other input data required for the CGM alignment process pursuant to Article 19 have to meet. Data sets that do not meet these criteria shall be replaced by substitute data.
4. All TSOs shall jointly define quality indicators that make it possible to assess all stages of the CGM process including, in particular, the CGM alignment process described in Article 19. They shall monitor these quality indicators and publish the indicators and the results of the monitoring as part of the data to be provided pursuant to Article 31(3) of Regulation 2015/1222.

336

337 Finally, the obligation to prepare the present CGMAM is – in addition to the corresponding
338 requirement in Regulation 2015/1222 - restated in Article 24 of the CGMM in somewhat greater
339 detail:

340

Article 24
Timescale for implementation

(...)

3. By six months after the approval of the present methodology (...)
 - b. each TSO shall formalise the delegation agreement with the alignment agent referred to in Article 19. In devising this agreement each TSO shall respect the provisions on delegation set out in Article 81 of Regulation 2015/1222;
 - c. all TSOs shall jointly specify and develop the algorithm referenced in Article 19 and shall also specify the rules and process associated with the said algorithm. All TSOs will publish on the internet the specifications, rules and process associated with the algorithm referenced in Article 19;
 - d. all TSOs shall jointly define the quality criteria and quality indicators referred to in Article 23;

(...)

6. All TSOs shall jointly prepare the available data related to quality monitoring in a sufficiently timely manner to allow these to be included in the first report referred to in Article 31 of Regulation 2015/1222 due by 14 August 2017. They shall prepare these data in subsequent years as required.

341

342 One additional task set out in Article 24 of the CGMM is the drafting of a governance
343 framework for the information platform referred to in Article 21 above by all TSOs. Since this
344 information platform – the Operational Planning Data Environment ("OPDE") – plays a very
345 important role in the CGMA process, that governance framework will have considerable
346 implications for the CGMA process, too.

347

348 In summary, the CGMM provisions relating to the CGMA process provide the framework for
349 the CGMAM, all major elements of which are addressed in the CGMM. The present document
350 provides the details required in order to make the CGMA process operational.

351

352

353

354 3 CGMA Algorithm

355

356 The present chapter describes the CGMA algorithm referred to in, inter alia, Article 19(2) of the
357 CGMM. This description, together with the description of the CGMA processes in Chapter 4,
358 reflects the requirements with respect to the algorithm set out in Article 19(3) and 19(4) of the
359 CGMM.

360 3.1 The three phases of the CGMA process

361

362 The CGMA process can be subdivided into three phases:

- 363 • Pre-processing phase
- 364 • Processing phase
- 365 • Post-processing phase

366

367 During the pre-processing phase each TSO provides its pre-processing data ("PPD") to the
368 CGMA IT platform which is operated by one or more alignment agents. The alignment agents –
369 which in practice will be Regional Security Coordinators ("RSCs") – are responsible for
370 completing a number of tasks related to the CGMA process on behalf of the TSO. These tasks
371 are described in more detail below.

372

373 The PPD consist of

- 374 • the preliminary net position (PNP)
- 375 • the feasibility range (FR) for the adjustment of the preliminary net position
- 376 • preliminary flows on DC lines
- 377 • maximum import and maximum export flows on DC lines

378

379 The following additional data can be optionally submitted as part of the PPD:

- 380 • absolute minimum and maximum net position (ABS_NP_MIN, ABS_NP_MAX)

381

382 The feasibility range is described by an interval $[FR_{neg}, FR_{pos}]$ such that under normal
383 circumstances the TSO expects its balanced (as opposed to preliminary) net position to be inside
384 the interval $[PNP + FR_{neg}, PNP + FR_{pos}]$. In practical terms, the feasibility range is a proxy
385 for flexibility and the ability of a bidding zone to accommodate different net positions.

386

387 As far as (both preliminary and balanced) DC flows are concerned, three points are worth
388 noting:

- 389 • DC flows may refer to both a single DC line or to an aggregate of DC lines. For the
390 time being, if DC lines on a DC border (i.e., two bidding zones linked by one or more
391 DC lines) are aggregated, then they are aggregated into a single DC connection.
392 However, it would also be possible to aggregate them into more than one DC
393 connection. To give an example, DC lines Skagerrak 1 to 4 could be modelled as any
394 number of DC connections between 1 and 4. The splitting / aggregation of DC flows is

395 determined as part of a separate sub-process referred to as "DC pole splitting and loss
396 calculation" (DC PSLC) that is not within scope of the CGMAM.

- 397 • Both within-synchronous area DC lines and across-synchronous area DC lines are
398 included if they connect different CGMA optimisation areas. The differences between
399 the two types of DC connections and the implications of this for the CGMA process are
400 explained below.
- 401 • Unless the flow on a DC line is zero there is always one exporting and one importing
402 end. The flow at the importing end is always equal to the flow at the exporting end
403 minus the losses on the line resp. the converters. The handling of DC losses in the
404 context of the CGMA process is not explained in the CGMAM, since it is part of the
405 DC PSLC sub-process referred to above.

406
407 The absolute minimum and maximum net position and their use in the process will be explained
408 in connection with the process descriptions in Chapter 4.

409
410 Note that these PPD need to be provided for each of the scenarios for which an IGM / CGM is
411 being prepared (and for which market schedules are not available). In the case of the two-days
412 ahead CGM this will typically correspond to 24 scenarios (one scenario per market time unit
413 which, in practical terms, will be one hour). In the case of the year-ahead CGM the expectation
414 is that eight scenarios will be used; one peak and one trough scenario for each season. All
415 scenarios that are mandatory at pan-European level are or will be described in the various
416 versions of the CGMM. The annotated version of the CGMM will feature descriptions of all
417 scenarios, whether mandatory at pan-European level or not.

418
419 In line with the requirement in Article 18(3) of Regulation 2015/1222, the PPD have to
420 correspond to the TSO's best forecast. It is rather intuitive that by estimating the PPD on a
421 regional basis in a coordinated manner the precision of the estimates ought to increase. The
422 more precise the estimates the smaller the adjustments required in order to obtain balanced net
423 positions. A number of parties are therefore developing methods for estimating PPD on a
424 regional basis. These so-called coordinated pre-processing approaches are presented in Annex
425 II. While these regional, coordinated approaches offer improvements relative to estimates
426 prepared by an individual TSO, there is no obligation for a TSO to prepare its PPD on the basis
427 of a regional approach. Each TSO's obligation is to provide PPD such that these meet the quality
428 standards set out in Chapter 3 on the algorithm. In line with Article 81 of Regulation 2015/1222,
429 a TSO can, of course, delegate this task to an RSC. Delegation to an RSC seems a particularly
430 relevant option for those TSOs that join a coordinated approach.

431
432 During the processing phase, the CGMA algorithm will use the PPD in order to compute the
433 variables of interest, namely

- 434 • balanced net positions
- 435 • balanced flows on DC lines

436
437 Also computed are AC-only net positions per bidding zone as well as indicative flows per AC
438 border. The AC-only net position is simply the balanced net position adjusted, where applicable,

439 for the balanced flows on DC lines. As for indicative flows per AC border, any two bidding
 440 zones have an AC border if they are linked by one or more AC tie lines. In other words, an AC
 441 border represents an aggregate of these tie lines. As a by-product of the computation, the
 442 CGMA algorithm also computes, for each AC border, an indicative flow figure which is
 443 provided along with the other CGMA results. These indicative AC flow figures do not have any
 444 bearing on actual physical flows, so any ex post comparison against realised flows would be
 445 meaningless. To see this, consider the example of three bidding zones all mutually linked via
 446 AC borders: an infinite number of combinations of AC flows could be determined that are all
 447 consistent with a given set of balanced net positions. By default the CGMA algorithm computes
 448 AC flows in such a way that these flows are minimised.

449
450

451 The accompanying CGMA Data Exchanges Implementation Guide refers to "CGMA results" as
 452 the set of balanced net positions, balanced flows on DC lines, AC-only net positions, and
 453 indicative AC flows. Together with the set of pre-processing data originally provided to the
 454 CGMA IT platform and any substituted or modified pre-processing data, the CGMA results
 455 constitute the "CGMA output data". The term "CGMA input data" used in the CGMA Data
 456 Exchanges Implementation Guide, however, is fully equivalent to "pre-processing data".

457


458 During the post-processing phase the balanced net positions and the balanced flows on DC lines
 459 will be used to adjust each TSO's IGM(s). The post-processing phase is mentioned for the sake
 460 of completeness, but the tasks that are part of this process phase are not part of the CGMA
 461 process.

462

463 The three phases can be illustrated as follows:

464

465



466

467 Figure 1: Phases of CGMA process

468

469 The present chapter is primarily about the processing phase and, in particular, the CGMA
 470 algorithm.

471

472

473

474

475

476 **3.2 Requirements with respect to the PPD**

477

478 In the processing phase, the CGMA algorithm uses the PPD in order to compute balanced net
479 positions and balanced flows on DC lines. That requires adjusting the preliminary net positions
480 as well as the preliminary flows on DC lines. However, the range of possible adjustments is
481 limited by the feasibility range (in the case of the net position) and the maximum permissible
482 import flow and maximum permissible export flows on DC lines (in the case of the preliminary
483 DC flows). Section 3.3 explains how losses on DC lines are taken into account. Clearly, if the
484 scope for adjustments is insufficient, it might not be possible to obtain balanced net positions
485 and balanced flows on DC lines.

486

487 To avoid the problem of non-convergence, the feasibility ranges have to be "of meaningful
488 magnitude".⁶ The "meaningful magnitude" requirement is a quality criterion that is checked at
489 the CGMA quality gate (to be described in more detail in Section 4.4 as well as Chapter 6 on IT
490 implementation). In the case of the (D-2) CGMA process time is of the essence, so data that do
491 not meet the quality requirements will be rejected and replaced by default data. This ensures that
492 the CGMA process can run nevertheless.

493

494 What, in concrete terms, does it mean for the data to be "of meaningful magnitude"? In the case
495 of the feasibility range for the adjustment of the preliminary net position, the answer to this
496 question is based on the concept of a weighting factor.

497

498 The weighting factor ("WF") is an indicator of the ease with which a given bidding zone should
499 be able to implement an adjustment of its net position of a given size. The intuition behind this
500 concept is that, holding everything else constant, it should be easier for a large system such as
501 France or Germany to adjust its net position by, for example, 500 MW than for a smaller system
502 such as Portugal or Slovenia. Thus the "meaningful magnitude" requirement can be expressed in
503 terms of the weighting factor; the larger the weighting factor, the larger the required feasibility
504 range.

505

506 After reviewing several candidates it was agreed to use "instantaneous peak load" as the
507 weighting factor. The instantaneous peak load for all relevant bidding zones is provided in the
508 "ENTSO-E Yearly Statistics & Adequacy Retrospect" (which, as the title suggests, is updated
509 every year with the previous year's data). Using this weighting factor as the reference, the
510 feasibility range for a bidding zone needs to exceed $2 \cdot \beta$ % of the weighting factor
511 (instantaneous peak load) in absolute terms in order for the corresponding set of PPD to pass the
512 quality gate. The TSO can shift this feasibility range around its PNP as it sees fit. The interval

⁶ For DC lines the maximum permissible import and maximum permissible export flows reflect the technical cable capabilities (excluding losses). Note that these may differ by direction of flow. If actual restrictions are more constraining than the technical cable capabilities, the TSOs can indicate this by providing suitably adjusted values for the maximum import and maximum export flows on the corresponding DC lines as part of the PPD (see above). This implies that with respect to DC flows there is no equivalent of the "meaningful magnitude" requirement that is applicable to net positions. This is explained in more detail below.

513 for the feasibility range could thus be symmetric about the PNP [$PNP - \beta \% * IPL$, $PNP + \beta \%$
514 $* IPL$] or the PNP could be at the top or bottom end of the interval: [$PNP - 2*\beta \% * IPL$, PNP]
515 or [PNP , $PNP + 2*\beta \% * IPL$], respectively. " β " is a parameter that can be modified so as to
516 widen or narrow the minimum feasibility range required. The initial proposal for " β " is 1 which
517 corresponds to a minimum feasibility range of 2 % of IPL. The test results reported in Annex I
518 suggest that this feasibility range ought to be sufficient in order for the CGMA algorithm to find
519 a solution.

520

521 The weighting factor and the " β " percentage will be reviewed periodically. Even if the WF as
522 such were not changed, the parameters will be updated on a yearly basis (when the new version
523 of the "ENTSO-E Yearly Statistics & Adequacy Retrospect" is released).

524

525 The following Table 1 presents the latest available data (for 2016 unless otherwise noted). Note
526 that the figures below refer to the national level whereas in the case of some countries (e.g.,
527 Germany) the IGMs and thus PPDs are provided on the level of control areas that do not cover
528 the entire country. In these cases, the figures below shall be pro-rated in proportion to the
529 instantaneous peak load on the level of the control area or an alternative suitable statistic (with
530 all data being properly documented). In a similar vein, where a relevant bidding zone or control
531 area is not (yet) included in the "ENTSO-E Yearly Statistics & Adequacy Retrospect" a suitable
532 alternative set of statistics shall be used in order to establish instantaneous peak load for that
533 area. Annex 0 provides additional detail.

534

Country	Value [MW]
AL	1552 ⁷
AT	11728
BA	2142
BE	13147
BG	7105
CH	10178
CZ	10512
DE	81945
DK	6115
EE	1538
ES	40144
FI	15177
FR	88571
GB	60133 ⁸
GR	9207
HR	2869
HU	6437
IE	4737
IT	53748
LT	1979
LU	1025
LV	1300
ME	576
MK	1457
NI	1758 [see FN 8]
NL	18243
NO	24485
PL	23779
PT	8139
RO	8752
RS	6958
SE	26576
SI	2144
SK	4360
TR	2217 ⁹
UA_W	1145 ¹⁰
XK	1160 ¹¹

⁷ Not yet included in ENTSO-E document; 2016 figure obtained directly from OST by the drafting team

⁸ 2015 figure obtained from ENTSO-E Yearly Statistics and Adequacy Retrospect as the Statistical Factsheet does not provide a breakdown into GB and NI

⁹ 5 % of 44341 MW (the 2016 IPL figure for all of Turkey) which corresponds to the share of the European part of Turkey in the overall area of the country. This is used as a proxy for the actual interconnection capacity which is disproportionately low given the large size of the Turkish power system and of the remainder of the Continental Europe power system.

¹⁰ Figure for 2014; source: ENTSO-E Yearly Statistics and Adequacy Retrospect 2015. An updated figure for Ukraine (UA_W) is no longer included in the 2016 edition (reporting on 2015 data). The drafting team has attempted to obtain an updated figure directly from Ukrenergo.

¹¹ Not yet included in ENTSO-E document; 2016 figure obtained directly from KOSTT by the drafting team

535 Source: ENTSO-E Statistical Factsheet 2016¹²

536 **Table 1: Instantaneous peak load 2016**

537

538 Note that the "meaningful magnitude" for the feasibility range is defined in terms of an absolute
539 value. However, each TSO is still required to provide two values – one for the maximum
540 negative adjustment (FR_{neg}) and one for the maximum positive adjustment (FR_{pos}) of the
541 preliminary net position.

542

543 To give an example, if Belgium (with an absolute minimum feasibility range of 263 MW; i.e.,
544 2% of 13,147 MW where 13,147 MW represents the 2016 WF and 2% follows from a value of
545 β of 1) declares a preliminary net position of $PNP = +500$ MW (i.e., an expected export of 500
546 MW), the following feasibility ranges would all be just accepted by the CGMA Quality Gate:

- 547 • [$FR_{neg} = -263$ MW, $FR_{pos} = 0$ MW] which results in a net position range of
548 [$NP_{min} = PNP + FR_{neg} = +500$ MW - 263 MW = +237 MW, $NP_{max} = PNP +$
549 $FR_{pos} = +500$ MW + 0 = +500 MW]
- 550 • [$FR_{neg} = -132$ MW, $FR_{pos} = +132$ MW] which results in a net position range of
551 [$NP_{min} = PNP + FR_{neg} = +500$ MW - 132 MW = +368 MW, $NP_{max} = PNP +$
552 $FR_{pos} = +500$ MW + 132 MW = +632 MW]
- 553 • [$FR_{neg} = 0$ MW, $FR_{pos} = +263$ MW] which results in a net position range of
554 [$NP_{min} = PNP + FR_{neg} = +500$ MW + 0 MW = +500 MW, $NP_{max} = PNP +$
555 $FR_{pos} = +500$ MW + 263 MW = +763 MW].

556

557 The equivalent weighting factor for DC lines is, in principle, given by the maximum technical
558 capacity of the line. If permanent or semi-permanent constraints (e.g., outages) restrict the
559 capacity that is actually available, the DC weighting factor can be reduced accordingly by the
560 relevant TSOs. The DC weighting factor is required as an input for the CGMA algorithm as will
561 be explained below. However, the "meaningful magnitude" for maximum permissible import
562 and maximum permissible export DC flows is not defined with respect to the DC weighting
563 factor, but is simply the largest maximum import and the largest maximum export flow
564 consistent with the technical design of the cable and operational requirements.

565

566 Note that each TSO can set specific maximum import and maximum export flows on each of its
567 DC lines for each individual scenario if necessary (i.e., in the case of the (D-2) time horizon for
568 each individual hour). These values can reflect, for example, ramping constraints or other
569 technical restrictions. The values specified will be checked against the maximum technical
570 capacity; if values are specified that exceed the technical maximum these will be rejected.
571 However, there is no problem in specifying values less than the maximum technical capacity.

572

¹² For the 2017 revision of the Common Grid Model Alignment Methodology and on an exceptional basis, the ENTSO-E Statistical Factsheet was used as the principal source. This made it possible to include - albeit provisional - 2016 data as opposed to 2015 data). The ENTSO-E Yearly Statistics & Adequacy Retrospect will remain the principal reference in future updates.

574 In summary, the data provided by each TSO need to meet the following requirements in order to
 575 pass the CGMA Quality Gate:

- 576 • the feasibility range needs to be wider than or at least equal to $2 \cdot \beta$ % of the bidding
 577 zone's weighting factor (the bidding zone's instantaneous peak load, typically relating to
 578 the previous year or the year before that; " β " being a parameter used to determine the
 579 width of the feasibility range)
- 580 • the maximum permissible import and maximum permissible export flows given for
 581 each of the DC lines must be the largest maximum import and the largest maximum
 582 export flows consistent with the technical design of the cable and operational
 583 requirements.

584
 585 The next section describes how the CGMA algorithm uses the data provided by TSOs in the
 586 pre-processing phase in order to obtain, inter alia, balanced net positions.

587
 588


589 3.3 Processing phase: the CGMA algorithm

590
 591

591 Objectives for this phase

592 The objectives for the processing phase are best illustrated by use of a diagram. Figure 2 shows
 593 the situation at the start of the processing phase when all bidding zones have submitted their
 594 preliminary net positions and preliminary DC flows. For the sake of clarity, preliminary AC-
 595 only net positions and preliminary DC flows are depicted separately. Bidding zones are indexed
 596 i and numbered from 1 to n ; DC lines are labelled with capital letters. Since a DC line always
 597 connects exactly two bidding zones each DC line appears in the diagram exactly twice. In
 598 principle this diagram relates to the pan-European level and encompasses all the bidding zones
 599 that take part in the CGM (and thus CGMA) process.

600
 601



602
 603 Figure 2: Unbalanced preliminary AC-only net positions and preliminary DC flows at the start of the processing
 604 phase
 605

606 The diagram shows that there is a problem with the preliminary net positions – the problem that
607 is to be solved in the processing phase. The "Preliminary net position across all bidding zones"
608 – the dark grey bar on the right-hand side of the diagram - is not equal to the "target net
609 position" (cf. far right of Figure 2). The latter quantity is always zero on the level of the CGM
610 area. Planned exchanges with "external" bidding zones (i.e., bidding zones that are not included
611 in the CGM and CGMA processes) have to be incorporated into the net position of that bidding
612 zone within the CGM area that is linked to them (e.g., an export to or import from Morocco
613 would be included in the net position of Spain). This discrepancy (i.e., the preliminary net
614 position across all bidding zones not being equal to the target) implies that TSOs' expectations
615 (which aim to reflect market participants' expectations to the extent possible) are not consistent:
616 in this particular illustration, TSOs expect market participants in aggregate to consume more
617 power than they plan to generate. Clearly that is not possible. The objective of the processing
618 phase is to determine a balanced net position for each TSO such that the net position across all
619 bidding zones is equal to the target (i.e., zero). In terms of the diagram, this means making the
620 grey bar disappear by adjusting the preliminary net position for each of the bidding zones.

621

622 In practical terms, if the "preliminary net position across all bidding zones" is negative (excess
623 load), it is necessary to increase total expected generation (i.e., the individual preliminary net
624 positions). The converse is the case when the "preliminary net position across all bidding zones"
625 is positive (excess generation). The objective of the processing phase is to determine what
626 exactly (in terms of MW) this adjustment should be for each of the bidding zones.

627


628 The present section describes how, for each of the bidding zones, the adjustment required to the
629 (unbalanced) preliminary net position is calculated; i.e., how the "preliminary net position
630 across all bidding zones" (the grey bar in Figure 2) is to be redistributed.

631

632 Expressing this in terms of Figure 3, for our example distribution of preliminary net positions,
633 the objective of the processing phase is to compute the size of the black boxes (making a
634 positive PNP more positive) and the boxes with dotted lines (making a negative PNP less
635 negative).

636

637



638 Figure 3: Balanced AC-only net positions and balanced DC flows at the end of the processing phase

639
640
641 It is quite intuitive that there is an infinite number of ways of redistributing the "preliminary net
642 position across all bidding zones". For example, one could use simple rules such as assigning
643 the complete adjustment to a single bidding zone (with bidding zones taking turns to adjust their
644 preliminary net position accordingly) or simply dividing the adjustment required by the number
645 of bidding zones and asking each bidding zone to make the same adjustment.

646
647 The technique used for computing the adjustments required in the present CGMAM is more
648 sophisticated than the simple rules sketched out above. That technique builds on an algorithm –
649 the CGMA algorithm – developed as part of the preparation of the CGMAM. Both the
650 algorithm and how it is to be implemented are explained next.

651
652 By way of background, note that when the preliminary net positions are adjusted, the flows on
653 DC lines have to be adjusted, too. Before the balanced net positions can be computed, the data
654 relating to a DC line linking any two TSOs need to be preliminarily balanced. The maximum
655 import and maximum export flows for each link also need to be consistent. In practice, the
656 CGMA process does not consider DC flows at the level of individual lines, but rather
657 aggregates the possibly multiple DC lines linking two optimisation areas across a DC border.
658 The splitting of the aggregate flows across the different DC lines happens as part of the DC pole
659 splitting and loss calculation sub-process which is out of scope of the CGMA process.

660
661 To summarise: the objectives of the processing phase are to obtain
662

- balanced net positions (one per bidding zone)
- balanced flows on DC lines (one flow figure per DC border)

663
664 by applying the CGMA algorithm. As a prerequisite for the computation, the following values
665 are also established:

- 666 • adjusted¹³ maximum import and maximum export flows per DC border (if applicable)

667

668 The CGMA algorithm: notation

669 This sub-section explains the notation for the CGMA algorithm and how it is to be applied to
670 the input data. The basic idea behind the algorithm is straightforward: given the objective of
671 obtaining balanced net positions and DC flows, minimize the adjustments required.
672 "Adjustments" are measured by the weighted sum of the squared differences between the
673 preliminary net position and the balanced net position; a similar criterion is applied to the
674 adjustments required with respect to DC flows.

675

676 The input data are the pre-processing data; i.e.,

677

678 (i) preliminary net position,

679 (ii) the feasibility range for the adjustment of the preliminary net position,

680 (iii) preliminary flows on DC lines, and

681 (iv) maximum import and maximum export flows on DC lines

682

683 in the resolution of one hour. Each hour is processed separately and independently of all other
684 hours (i.e., twenty-four independent calculation processes for the (D-2) time frame). In order to
685 use consistent notation throughout, the following symbols are introduced:

686

687 (i) preliminary net position,

688 • bidding zones are indexed i ; i runs from 1 to n

689 • n is the number of bidding zones covered by the algorithm; i.e., the total number of
690 bidding zones included in the pan-European CGM

691 • the preliminary net position forecast for bidding zone i is denoted PNP_i

692

693 (ii) the feasibility range for the adjustment of the preliminary net position,

694 • there is one feasibility range per bidding zone, so feasibility ranges are also indexed i
695 with i running from 1 to n

696 • the feasibility range is formed by two values:

697 ○ the maximum negative adjustment FR_{neg} with $FR_{neg} \leq 0$ and

698 ○ the maximum positive adjustment FR_{pos} with $FR_{pos} \geq 0$;

699 • the resulting range is $[FR_{neg}; FR_{pos}]$

700 • the feasibility range for bidding zone i is denoted $[FR_{neg,i}; FR_{pos,i}]$

701 • the resulting minimum and maximum net positions are

702 ○ $NP_{min,i} = PNP_i + FR_{neg,i}$

703 ○ $NP_{max,i} = PNP_i + FR_{pos,i}$;

704 ○ in summary $[NP_{min,i}; NP_{max,i}]$

705

706 (iii) preliminary flows on DC lines (per DC border),

¹³ "adjusted": consistent with the maximum import and maximum export flows given by both TSOs (which need not be the same); the adjustment is described in more detail below

- 707 • K is the set of all connections (AC and DC links) between bidding zones in Europe¹⁴
 708 • a single connection k has a defined direction from bidding zone i to bidding zone j¹⁵
 709 $k \in K, k = (i, j)$
 710 • flows from and to bidding zones belong to the set of all defined connections between
 711 bidding zones
 712 $K_{from,i} \subseteq K \quad k \in K_{from,i} \Leftrightarrow k \in K, k = (i, j)$
 713 $K_{to,i} \subseteq K \quad k \in K_{to,i} \Leftrightarrow k \in K, k = (h, i)$

714 Because both TSOs connected by a DC line will typically declare a preliminary flow for the
 715 same link each, it must be possible to distinguish the two declarants

- 716 • in summary, the preliminary flow on DC connection k forecast by TSO i is given by
 717 $IPFlow_{k,i}$
 718 • the "I" in the term denotes the fact that this is the TSO's "Individual" forecast
 719

720 (iv) maximum import and maximum export flows on DC lines

- 721 • maximum import flow on DC line k declared by TSO i (which corresponds to the
 722 maximum export on DC line k in the opposite direction) is given by $IFlow_{min,k,i}$
 723 • maximum export flow on DC line k declared by TSO i (which corresponds to the
 724 maximum import on DC line k in the opposite direction) is given by $IFlow_{max,k,i}$
 725 • where $IFlow_{min,k,i} \leq 0$ and $IFlow_{max,k,i} \geq 0$
 726 • once again, an "I" is included in the designation in order to make it clear that these are
 727 values given by an "Individual" TSO
 728

729 In addition to the input data from the pre-processing phase, a number of additional parameters
 730 need to be defined; these are:

731

732

733 (v) weighting factors

- 734 • there is one weighting factor per bidding zone for the adjustment of the net position:
 735 $NP_{weight,i}$
 736 • there is one weighting factor per connection: $F_{weight,k}$
 737

738 Some additional notation is introduced below; it makes sense to explain it first.
 739

740 Applying the algorithm: overview

741 This section gives a brief overview of the various steps in the process. In step 0, the target net
 742 position across all bidding zones is established. Since the target net position is always set equal
 743 to zero, this is not considered as a proper "step" and so is referred to as "step 0". Given input
 744 variables (including the target net position across all bidding zones of zero), in the first step -
 745 step 1 - the different values relating to DC lines (typically submitted by two declarants; i.e. two
 746 TSOs) are provisionally balanced. In other words, rules are defined that ensure that two possibly

¹⁴ Multiple AC links between the same bidding zones will be aggregated into a single virtual link. DC links between the same bidding zones are also aggregated at this stage of the process.

¹⁵ Flows in the opposite direction will be represented by negative values.

747 different values for preliminary, minimum, and maximum flows (on the level of DC borders)
 748 can be mapped into single ones. In step 2 of the process, the algorithm is applied in order to
 749 obtain balanced net positions at pan-European level and to calculate balanced DC flows. Step 3
 750 ensures that, given the model parameters and input data, a solution is found. At the conclusion
 751 of step 3 all preparations for the DC pole splitting and loss calculation sub-process have been
 752 completed. Following the computation of adjusted output variables during the DC PSLC sub-
 753 process; the results computed will be provided and can be used in order to adjust individual grid
 754 models in the post-processing phase.

756 Applying the algorithm: Step 0 – establishing the target net position across all bidding zones

757 In order to determine the target net position across all bidding zones, in principle the planned
 758 exchanges with external bidding zones (i.e., bidding zones that are not part of the CGM area)
 759 need to be known and netted. For example, if the planned net exchange with the relevant
 760 bidding zones is an import by these external bidding zones (i.e., an export by the CGM area) of
 761 1000 MW, then the target net position across all bidding zones is + 1000 MW.

763 In practice, however, the target net position across all bidding zones is always set equal to zero
 764 for computational reasons. Therefore, in the example the planned export of +1000 MW from the
 765 CGM area would be taken into account by including it in the PNPs of those bidding zones
 766 planning to exchange power "externally". Take the case of Spain and Morocco as an example.
 767 Spain and Morocco are linked by an AC connection. Assume that Spain is expecting to export
 768 100 MW to Morocco. If this is the only external flow, then the CGM area as a whole needs to
 769 export 100 MW and the target net position across all bidding zones could be thought to be + 100
 770 MW. However, since the target net position across all bidding zones is zero by convention, REE
 771 needs to take into account the planned export to Morocco in its preliminary net position. The
 772 declared net position for Spain would thus be reduced by 100 MW (the power that is planned to
 773 be exported to Morocco).

775 Applying the algorithm: Step 1 – obtaining preliminary balance on DC lines

776 Recall that, if both TSOs connected by DC connection (DC border) k provide data, the
 777 following variables need to be reconciled:

- 778 • TSO i forecasts the flow to be $IPFlow_{k,i}$
- 779 • TSO j forecasts the flow to be $IPFlow_{k,j}$
- 780 • individually declared maximum import flows are
 - 781 ○ $IFlow_{min,k,i}$
 - 782 ○ $IFlow_{min,k,j}$
- 783 • individually declared maximum export flows are
 - 784 ○ $IFlow_{max,k,i}$
 - 785 ○ $IFlow_{max,k,j}$

787 As for the forecast flow, the rule is to use the simple arithmetic average as the provisionally
 788 balanced flow (and, of course, to drop the subscript for the declarant):

789
$$PFlow_k = \frac{IPFlow_{k,i} + IPFlow_{k,j}}{2}$$

790 Maximum import and maximum export flows are computed as follows: $Flow_{min,k} =$
791 $max(IFlow_{min,k,i}; IFlow_{min,k,j})$ $Flow_{max,k} = min(IFlow_{max,k,i}; IFlow_{max,k,j})$

792

793

794 Recall that "a single connection k has a defined direction from bidding zone i to bidding zone j ".
795 This direction is set as a matter of convention – either of the two possibilities is fine, but the
796 convention has to be respected consistently. Given this convention, knowing the value of both
797 of the $IPFlow_{k,*}$ means knowing $PFlow_k$ which, in turn, means knowing the direction of the
798 flow on connection k . To make this more concrete, consider the example of the SwePol cable
799 linking Poland and Sweden (SE4). All flows on this cable will be expressed in terms of either an
800 export from Poland to Sweden or an export from Sweden to Poland. In the former case, an
801 import into Poland from Sweden would be expressed as a negative number. In the latter case, an
802 import into Sweden from Poland would be expressed as a negative number. Which of the two
803 options is chosen does not matter at all provided that the same convention known to (i.e.,
804 programmed into) the CGMA algorithm is applied by all other parties involved in the process.

805

806 In the definition of $PFlow_k$ it is important to note that the TSO-individual estimates have to be
807 expressed as expected flows that refer to the same end of the DC link. In other words, the
808 provisionally balanced flow is not obtained as the average of what TSO i (by assumption)
809 expects to export on link k and what TSO j (by assumption) expects to import on link k . These
810 two quantities cannot be properly compared because one of them (implicitly) takes losses into
811 consideration (namely what TSO j expects to import; i.e., import = export minus losses) and the
812 other (namely what TSO i expects to export) does not. Thus if the two forecasts are provided in
813 this way one of the values has to be corrected for the losses. In order to make the two forecasts
814 compatible such that they can be used in the above formula, either the losses have to be added
815 back at the importing end's estimate or the losses have to be deducted at the exporting end's
816 estimate. In practice, however, DC losses will be taken into account in a sub-process referred to
817 as DC PSLC (pole splitting and loss calculation). The convention is therefore that both TSOs
818 provide gross values (that have not been adjusted for losses) at this stage of the CGMA process.
819 In other words, DC borders will be treated as if there no losses on these.

820

821

822

823

824 Applying the algorithm: Step 2 – obtaining balanced net positions and DC flows

825 The CGMA algorithm is formulated as a weighted least squares optimisation problem with both
826 equality and inequality constraints. The different components of the least squares programme
827 are now introduced one by one.

828

829 There are two objective functions, one objective function for the minimisation of the adjustment
830 of the net positions and one objective function for the minimisation of the adjustment of the DC
831 flows.

832

833 The first objective function is given by

834

$$\min_{BNP_i} \sum_{i \in N} \frac{1}{NP_{weight,i}} (PNP_i - BNP_i)^2$$

835

836 This objective function minimises the aggregated adjustment of the preliminary net positions.
 837 BNP_i is a new variable that has not yet been defined. It denotes the "balanced net position" for
 838 bidding zone i . The BNP_i are the control variables. The objective function aims to minimize the
 839 weighted squared deviations of the balanced net position from the preliminary net position. The
 840 reason for trying to minimise the difference between the BNP and the PNP is that the larger that
 841 difference, the more extensive the changes required to the underlying IGM.

842

843 The weighting factor $NP_{weight,i}$ also deserves additional explanation in the context of the
 844 objective function. Because the inverse of the weighting factor is used in the objective function,
 845 a large value of $NP_{weight,i}$ means that the weight given to
 846 $(PNP_i - BNP_i)^2$ in the minimisation is low. That is just another way of saying that relatively
 847 larger adjustments are acceptable for bidding zone i than for another bidding zone with a lower
 848 weighting factor. As was noted above, the weighting factor is a proxy for how easily a bidding
 849 zone can accommodate a given adjustment of the net position. To restate the earlier example,
 850 surely a 500 MW adjustment should be easier to accomplish for a bidding zone such as France
 851 than for, say, Portugal.

852

853 The second objective function is given by

854

$$\min_{BFlow_k} \sum_{k \in K} \frac{1}{F_{weight,k}} (PFlow_k - BFlow_k)^2$$

855

856 This objective function minimises the aggregated adjustment of the preliminary DC flows as
 857 well as preliminary AC flows (explained below). Recall that K is the set of all connections
 858 between bidding zones, whether DC or AC, and that k is an index referring to both DC and AC
 859 connections. The control variables here are $BFlow_k$; i.e., balanced flows per DC border or AC
 860 connection. The objective function is conceptually the same as that used for determining
 861 balanced net positions. Note that this function is defined with respect to the preliminarily
 862 balanced DC flows (not the initial forecasts provided by TSOs individually) as well as the
 863 preliminarily balanced AC flows (simply zero by definition as explained below). The weighting
 864 factor $F_{weight,k}$ ensures that the adjustment falls more heavily on DC lines with higher capacity
 865 and most heavily on AC connections.

866

867 Thus far, in contrast to DC lines which were discussed in some detail in the preceding section,
 868 AC connections were hardly mentioned in the present document. However, they do need to be
 869 included in the optimisation, too, for otherwise it would not be possible to model flows between
 870 bidding zones that are not connected by DC lines. The following paragraphs explain the way in
 871 which AC connections are incorporated.

872

873 Flows on DC lines (or "DC flows") are defined as the values at the exporting and at the
874 importing ends of a DC line (DC border) which really exists as a physical asset. The difference
875 between the two values is made up by losses which, in the case of DC lines (DC borders), are
876 taken into account via the DC PSLC sub-process.

877

878 In contrast to this, the flow values assigned to an AC connection included in the CGMA
879 algorithm represent a flow of electricity from an exporting bidding zone to an importing bidding
880 zone; they do not correspond to physical flows and no losses on such connections are being
881 considered. This is because, in the context of the CGMA algorithm, an AC connection does not
882 correspond to a specific physical asset; it is merely a virtual connection between two bidding
883 zones. It is virtual, for example, in the sense that regardless of the actual number of tie lines
884 linking the two bidding zones, only a single AC connection is modelled in the CGMA
885 algorithm. Conversely, each pair of bidding zones is linked by at most one AC connection in the
886 CGMA algorithm. Further note that in the context of the CGMA algorithm the value of an AC
887 flow cannot be interpreted as the sum of the physical flows on the tie lines that it represents; the
888 AC flows are artefacts of the computation.

889

890 In the case of DC flows we speak of "preliminarily balanced DC flows" because the two TSOs
891 might not provide consistent data. Once the averaging rule described in the document has made
892 the data consistent, the DC flows are described as "preliminarily balanced".

893

894 For AC flows a similar procedure is not required in order to obtain the equivalent of
895 "preliminarily balanced" values. The reason for this is that TSOs do not provide preliminary AC
896 flow data that might be inconsistent with each other. Preliminary AC flows are set equal to zero
897 by default for all bidding zones, so that any two corresponding flows (i.e., the values for the
898 flow on a particular virtual AC connection) are always consistent; i.e., preliminarily balanced by
899 definition.

900

901 In the optimisation model there is no mathematical distinction between AC and DC connections
902 and between AC and DC flows. But for the AC connections and AC flows fixed rules are
903 defined:

- 904 • The connection weighting factor for all AC connections is set to a very high value for
905 higher priority in adjustment. The objective is the adjustment of AC connections before
906 the adjustment of DC connections where it is applicable:¹⁶

$$907 F_{weight,\hat{k}} \gg \sum_{k \in K_{DC}} F_{weight,k} \quad \forall \hat{k} \in K_{AC}$$

- 908 • The preliminary flow for each AC connection is set to zero:

$$909 PFlow_{\hat{k}} = 0 \quad \forall \hat{k} \in K_{AC}$$

- 910 • The maximum import and maximum export flow for each AC connection is unlimited
911 by default:

$$912 Flow_{min,\hat{k}} = -\infty \quad \forall \hat{k} \in K_{AC}$$

$$913 Flow_{max,\hat{k}} = +\infty \quad \forall \hat{k} \in K_{AC}$$

¹⁶ The concrete value will be defined in the implementation of the algorithm.

914 The advantage of this approach is a very sizeable reduction in the pre-processing data required.
915 In concrete terms, neither preliminary AC flows (per virtual AC connection) nor capacity
916 restrictions for the latter will have to be provided. In fact, it will not be possible for TSOs to
917 provide these data which will greatly simplify the IT implementation.

918 One special case needs to be mentioned in connection with the modelling of AC lines. This
919 special case concerns DC lines linking two bidding zones within the same synchronous area if
920 such a DC line is actually operated as a DC line (and not operated in AC-simulated mode) and
921 if, in addition to the DC connection (operated as a genuine DC line), these two bidding zones
922 are also linked by one or more AC connections. Note that it does not matter whether the (single
923 or more than one) AC connection parallels the DC line directly or via a detour (i.e., indirectly
924 via additional bidding zones). At the time of writing (in November 2017) this applied to

- 925 • Fennoskan 1 and 2 (operational DC lines linking bidding zones FI and SE3 which are
926 also linked by AC via FI – SE1 – SE2 – SE3)
- 927 • GRITA (operational DC connection linking bidding zone IT6 (BRNN) in Italy with
928 Greece (GR) with Italy and Greece also being indirectly linked by numerous AC
929 connections)
- 930 • Sweden's planned Southwest Link (DC line linking bidding zones SE3 and SE4 which
931 are also linked by AC)
- 932 • ALEGrO – a planned DC line connecting Belgium and the Amprion control area in DE
933 (both of which are indirectly linked in parallel by a number of AC connections)
- 934 • COBRA – a planned DC line connecting bidding zone DK1 with bidding zone NL
935 (both of which are also linked indirectly by AC connections)

936
937 If the process is not modified for these special cases, the result will be that the preliminary DC
938 flows will hardly be modified (if at all). In other words, the balanced flow values for the DC
939 lines would likely be identical to the preliminary flows. The reason for this is the very large
940 weighting factor that is applied to standard AC connections as well as the lack of a capacity
941 restriction for the latter. The entire adjustment required would effectively be made via the AC
942 connection(s), not the DC line.

943
944 For the time being, the preliminary DC flows on such lines will be made consistent in the way
945 described above.

946
947 There are a number of constraints that need to be respected. The first constraint

$$948 \sum_{i=1}^n BNP_i = 0$$

949 is the most straightforward one. It says that the balanced net positions need to sum to zero. That,
950 of course, is the point of computing balanced net positions. Note, however, that the right-hand
951 side of this constraint is zero as a matter of notational convention – because the target net
952 position will always be set equal to zero.

953
954 The next set of constraints is a set of inequality constraints which restrict the balanced net
955 position BNP_i to feasible values; i.e.,

956 $BNP_i \geq NP_{min,i} \forall i \in N$

957 and

958 $BNP_i \leq NP_{max,i} \forall i \in N$

959 Given the extensive discussion of the need for establishing a feasibility range, these constraints
960 also should not be surprising. If one of these constraints becomes binding, the corresponding
961 BNP_i is set equal to the constraint. Holding everything else equal, in that case the adjustment
962 required in other bidding zones increases.

963

964 The next set of constraints relates to the flows on DC lines.

965 Balanced flows must be within the min/max range for every connection (border) between
966 bidding zones:

967

$$BFlow_k \geq Flow_{min,k} \forall k \in K$$

968 and

$$BFlow_k \leq Flow_{max,k} \forall k \in K$$

969

970 The balanced net positions of each bidding zone must be equal to the aggregated balanced AC
971 and DC flows from and to this bidding zone:

$$BNP_i = \sum_{k \in K_{from,i}} BFlow_k - \sum_{k \in K_{to,i}} BFlow_k \quad \forall i \in N$$

972

973 The numerical solution of this optimisation problem requires some customisations.

974 The two objective functions will be optimised at the same time to ensure the fulfilment of all
975 constraints and to find a combined solution. So the two objective functions must be transformed
976 into a single function:

$$\min_{BNP_i, BFlow_k} W \sum_{i \in N} \frac{1}{NP_{weight,i}} (PNP_i - BNP_i)^2 + \sum_{k \in K} \frac{1}{F_{weight,k}} (PFlow_k - BFlow_k)^2$$

977 The global weighting factor W is introduced in order to prioritise the first term of the objective
978 function (net positions). Hence W must have a high value:¹⁷

$$W \gg 1$$

979

980 Additional constraints (e.g., ramping) are not being taken into account. The CGMA process is
981 not intended to give the allocation results; i.e., it does not predetermine the capacity calculation.
982 Instead it serves as an input for the capacity calculation which treats each synchronous area as a
983 copperplate; it is thus “unlimited” (i.e. allocation constraint free).

984 As far as ramping constraints specifically are concerned, the principal justification for not
985 including these is that the initial forecasts of DC flows are expected to be of sufficiently high
986 quality such that the relevant constraints have already been taken into account in the preliminary
987 DC flows provided. The relevance of concerns in this respect will, of course, be reviewed as
988 part of the CGMA dry run planned for the fourth quarter of 2017.

989

990 Applying the algorithm: Step 3 – scenarios without solutions

¹⁷ The concrete value will be defined in the implementation of the algorithm.

991 The task of this step is to ensure that a solution for the given model parameters always exists as
992 required by Article 19(3)(d) of the CGMM. Note that the present step only concerns the
993 operation of the algorithm, not the CGMA process. The CGMA process and, in particular, the
994 Active Quality Management Process (AQMP) that is part of the CGMA process complement
995 the operation of the algorithm described here. The AQMP also addresses the problem of non-
996 convergence (i.e., the CGMA algorithm not finding a solution); it is described in detail in the
997 following chapter on the business processes.

998

999 As far as the CGMA algorithm is concerned, for unsolvable situations methodology
1000 enhancements are needed. To all intents and purposes, the only relevant reason for the non-
1001 existence of a solution is a feasibility range for net positions that is too restrictive. Increasing the
1002 feasibility range for certain bidding zones can solve this problem. However, if feasibility ranges
1003 are to be extended, two questions have to be answered:

1004 1. How exactly (i.e., according to which rules or principles) should feasibility ranges be
1005 adjusted?

1006 2. How is it ensured that the extension of the feasibility ranges does not cause problems – after
1007 all, the feasibility ranges have been set by TSOs for a reason. If a TSO did not care about the
1008 feasibility range, it would presumably have specified a (wider) feasibility range in the first
1009 place.

1010

1011 On 1., note that the question of how to relax constraints when an algorithm does not find a
1012 solution is a very general one that is well understood and for which various mathematical
1013 techniques have been developed and implemented in software programs. The CGMA algorithm
1014 makes use of a standard toolkit originally developed by IBM in order to compute the feasibility
1015 range adjustments. Following some general background material the explanations below give
1016 the intuition behind the adjustment rules used by the CGMA algorithm.

1017

1018 Because of its quadratic objective function, the CGMA optimisation model falls into the general
1019 class of quadratic programming problems¹⁸. The CGMA algorithm can thus make use of the
1020 CPLEX solver - part of a software program developed by IBM (IBM ILOG CPLEX
1021 Optimisation Studio¹⁹) - in order to apply a set of standard techniques for solving such quadratic
1022 problems. The solver distinguishes between convex and nonconvex quadratic programs. Convex
1023 problems are not typically a challenge for the solver – in mathematical parlance it solves these
1024 efficiently in polynomial time. Nonconvex quadratic problems are much harder to solve than
1025 convex problems; in theoretical terms these are characterized as "NP-hard" (non-deterministic
1026 polynomial-time hard). The CPLEX solver is able to use a number of different approaches to
1027 solving such problems such as, for example, barrier algorithms and branch and bound
1028 algorithms. The default approach used by the CPLEX solver is the barrier optimizer.

1029

1030 Using the CPLEX solver entails a certain approach to relaxing the feasibility ranges which from
1031 a mathematical point of view are simply constraints. Specifically, the CPLEX solver uses an

¹⁸ For an explanation of quadratic programming see Gill, Philip E., Walter Murray, and Margaret H. Wright, Practical Optimization. New York: Academic Press, 1982 reprint edition.

¹⁹ See <http://www-03.ibm.com/software/products/en/ibmilogcpleoptistud> for additional information

1032 optimisation algorithm analogous to phase I of the simplex algorithm. The solver thus takes a
1033 model for which a solution does not exist initially and relaxes the constraints in order to obtain a
1034 solution. It does so in two phases and in a way that minimises a weighted penalty function. In
1035 the first phase it attempts to find a feasible solution that requires minimum change of
1036 constraints; i.e., it minimizes the sum of all feasibility range extensions required by, inter alia,
1037 using the slack variables. In the second phase, it finds an optimal solution (with respect to the
1038 objective function) among all those solutions which require only as much extension of
1039 feasibility ranges (= relaxation of constraints) as was found to be necessary in the first phase.

1040
1041 In other words, the solver has to analyse the influence of different feasibility ranges with respect
1042 to the quality of the optimisation results; the extent of the adjustment of the feasibility ranges
1043 must minimise the objective function and consider the other constraints. The CGMA algorithm
1044 is programmed such that it is able to make these adjustments to feasibility ranges automatically
1045 by following the steps described below. The actual operation of the CGMA algorithm is much
1046 more complicated, of course, but the description below covers the principal steps and it provides
1047 some intuition for the very abstract description above:

1048
1049 The following method will be used to distribute the extensions of feasibility ranges required
1050 among the affected bidding zones with respect to (especially but not only) the weighting factors:

- 1051 1. Try to calculate a solution for the optimisation problem
- 1052 In case the solver finds no solution:
 - 1053 2. Analyse utilisation of constraint variables
 - 1054 3. Detect binding constraints²⁰ (where variable value is on border of constraint)
 - 1055 4. Calculate sensitivity of binding constraints with respect to objective function
 - 1056 5. Determine changeable binding constraints with highest impact on objective function
 - 1057 6. Extend constraints so as to achieve maximum impact with respect to the objective
1058 function result
- 1059 → this leads to a new optimisation model with different constraints
- 1060 7. Recalculate the optimisation model and find a solution
- 1061 8. If necessary, the algorithm will repeat steps 2-7 above until it has found a solution.

1062
1063 To make this more concrete, consider the following illustration: Assume that 1500 MW of
1064 additional feasibility range in one direction are required. In the first step, this additional
1065 adjustment of feasibility ranges will be assigned to the different bidding zones in proportion to
1066 their weighting factors. In the example, let us say that there are five bidding zones and that their
1067 WFs are 10000 MW, 20000 MW, 30000 MW, 40000 MW, 50000 MW, respectively. The sum
1068 of the weighting factors is 150000 MW, so the relative weights of the bidding zones are 1/15
1069 (=10000MW/150000MW), 2/15, ..., 5/15. Therefore, the adjustments for the five BZs would be
1070 $(1/15) \cdot 1500 \text{ MW} = 100 \text{ MW}$, $(2/15) \cdot 1500 \text{ MW} = 200 \text{ MW}$, etc. and the adjustments in total
1071 would sum to the 1500 MW that are required.
1072

²⁰ A distinction has to be made regarding constraints that can be changed (net position feasibility ranges) and that cannot be changed (DC capacity based maximum import and maximum export flows).

1073 Unfortunately, this distribution may not be possible due to DC line restrictions - there is no
1074 point changing the net position feasibility range if a DC line is the limiting factor! In this case
1075 the DC line flow will be set equal to its capacity and the "leftovers" require a new calculation.
1076 This is where the cleverness of the algorithm outlined above comes in which aims at finding a
1077 solution quickly.

1078
1079 To summarise, if the CGMA algorithm finds a solution for given input data, all is well. If there
1080 is no solution the algorithm then automatically adjusts (i.e., extends) feasibility ranges as
1081 outlined above until it finds a solution. Since no restrictions are imposed upon the feasibility
1082 ranges, the existence of a solution is ensured.

1083
1084 However, this leads to the second question stated above: Following the adjustment of feasibility
1085 ranges by the algorithm, the resulting feasibility ranges by definition exceed those originally
1086 stated by TSOs. In other words, a solution may have been found, but it remains to be confirmed
1087 that this solution is realistic in the sense that the TSOs concerned agree with the extension. This
1088 is what the Active Quality Management Process (AQMP) described in Chapter 4 aims at.

1089
1090 In step 1, the AQMP tries to ensure that the changes to feasibility ranges are validated by the
1091 TSOs concerned. If this cannot be achieved in time (i.e., before the relevant CGM process
1092 deadline), step 2 kicks in. Since step 2 leads to a change in the optimisation model, it is
1093 described below.

1094
1095 In the light of the explanations above the algorithm will always find a solution. However, it may
1096 have to extend feasibility ranges in order to do so. If it is not possible to agree on the extension
1097 to feasibility ranges under step 1 of the AQMP, a different approach is needed. In step 2 of the
1098 AQMP, the CGMA algorithm will thus be augmented with a set of additional constraints, the
1099 absolute minimum and/or maximum net positions (ABS_NP_MIN / ABS_NP_MAX). These
1100 constraints will be respected by the algorithm by definition. However, all feasibility ranges not
1101 affected by such an additional constraint may be modified by the algorithm in a manner similar
1102 to the approach outlined above.

1103
1104 Absolute minimum and/or maximum net positions signal that a TSO would not be able to build
1105 an IGM based upon a net position above or below the absolute net position, respectively.
1106 Absolute minimum and/or maximum net positions are to be used with great caution as they
1107 make TSOs vulnerable to the accusation that the "no undue discrimination" requirement set out
1108 in Article 18(3) of Regulation 2015/1222 is not respected.

1109
1110 This concludes the discussion of how the CGMA algorithm deals with situations in which there
1111 is not, at first, a solution given the input data provided. The process aspects of such a situation
1112 are discussed in more detail in Chapter 4.

1113
1114 DC losses did not feature in the discussion above. The DC losses are to be determined (and net
1115 positions are to be adjusted accordingly) as part of the DC PSLC (pole splitting and loss

1116 calculation) sub-process which is out of scope of the CGMA process. The CGMA IT Platform
1117 will merely check the results of the PSLC sub-process for consistency as part of a quality check.

1118
1119

1120 Applying the algorithm: Outputs

1121 The purpose of the CGMA process is to provide to TSOs data that are inputs of critical
1122 importance in the preparation of IGMs (and thus CGMs), namely

- 1123 • balanced net positions
- 1124 • balanced flows on DC lines (borders)

1125 The output variables determined by the CGMA algorithm have the same granularity as the input
1126 variables. For example, if a TSO who has several bidding zones in its control area provides a
1127 single preliminary net position covering the entire control area, the CGMA algorithm will
1128 compute a single balanced net position.

1129

1130 The CGMA output data will be used by the DC PSLC sub-process in order to compute flows
1131 per individual DC line as well as losses. The results of the DC PSLC sub-process are fed back to
1132 the CGMA IT Platform.

1133 As the final step in the CGMA process, the CGMA output data computed by the CGMA
1134 algorithm as well as those computed by the DC PSLC sub-process are provided to TSOs (and
1135 other relevant parties such as RSCs).

1136
1137

1138 Applying the algorithm: summary

1139 A brief summary concludes the description of the processing phase. First the target net position
1140 is established (even though for ease of processing this is always set equal to zero and a non-zero
1141 target is taken into account indirectly). Provisionally balanced DC flows and associated
1142 minimum and maximum flows per DC line are obtained. In the subsequent step, applying the
1143 CGMA algorithm yields balanced net positions (balanced at pan-European level) and DC flows
1144 (per DC border). For situations where no solution exists, another process step modifies the
1145 optimisation model by extending the net position feasibility ranges. Following the algorithm
1146 run, the DC PSLC sub-process (which is not part of the CGMA process) determines DC flows
1147 per DC line as well as losses. The results can then be used in order to update the individual grid
1148 models.

1149

1150 The following section briefly discusses the post-processing phase.

1151
1152

1153 3.4 Post-processing phase

1154

1155 The post-processing phase entails a number of tasks most of which (specifically the publishing
1156 of individual grid models as well as subsequent steps: merging of individual grid models etc.)
1157 are not within scope of the present document. A general description of the post-processing
1158 phase is provided in the annotated CGMM. As far as the CGMA process is concerned, the
1159 question is only how the results of the processing phase are to be used. Application of the
1160 CGMA algorithm in the processing phase yields balanced net positions as well as balanced
1161 flows on DC lines (borders).

1162

1163

1164 4 Business processes

1165

1166 The present chapter describes the CGMA business processes and the various steps within these
1167 processes. This description, together with the description of the CGMA algorithm in Chapter 3,
1168 reflects the requirements with respect to the algorithm set out in Article 19(3) and 19(4) of the
1169 CGMM.

1170

1171 4.1 CGMA business processes overview

1172

1173 Regardless of the time horizon for which balanced net positions and balanced flows on DC lines
1174 are being computed, the steps in the CGMA process are essentially the same (although the
1175 deadlines by which the different steps need to have been completed differ, of course).

1176

1177 However, it should be noted that the deadlines for completing the various steps are much more
1178 constraining in the case of the (D-2) process than for the other time frames. This creates a
1179 special challenge in case the CGMA algorithm cannot find a solution immediately. The options
1180 for dealing with this problem are discussed in detail. First, however, the common CGMA
1181 process steps are outlined. Following the description of the process steps the deadlines
1182 applicable to each step are stated.

1183

1184 Most of the process steps have one or more (performance) indicators associated with them.
1185 These indicators are explained in more detail in the CGMA IT specification ("Common Grid
1186 Model Alignment Requirements and Technical Specification") described in chapter 6. However,
1187 it is useful to reference them in the description of the process steps already as this provides for a
1188 more detailed view of the process. The indicators described in the present version of the
1189 CGMAM should be thought of as a minimum; it is likely that as implementation progresses and,
1190 especially, as lessons are learnt from the parallel run ("dry run") of the CGMA process planned
1191 for 2017-Q4, additional indicators may be included.

1192

1193 4.2 Summary of the three phases

1194

1195 As was noted at the very beginning of Chapter 3, the CGMA process consists of three distinct
1196 phases. The various steps of the processing phase will be discussed in detail below. The
1197 description of the pre-processing and post-processing phases, however, will be kept brief and
1198 will serve primarily to clearly delineate the interfaces and the associated responsibilities. The
1199 reasons for this are as follows:

1200

1201

1202

1203

1204

1205

- Pre-processing phase: The CGMAM aims to leave TSOs as much freedom as possible and to be only as prescriptive as necessary. With respect to the pre-processing phase, a TSO's only firm obligation is to provide its PPD on time and in the right quality. How TSOs obtain these PPD is entirely their own choice although from the point of view of the overall process the preference is clearly for coordinated approaches. The latter ought to reduce the total adjustment required, so the CGMAM provides guidance by outlining

1206 coordinated pre-processing approaches under development (cf. Annex II). These
 1207 descriptions are meant to be helpful, but it is by no means mandatory for any TSO to
 1208 adopt either of these or any other particular approach.

1209 • Post-processing phase: The post-processing phase is referred to in the CGMAM (and, in
 1210 this sense, included in the CGMA process) for the sake of completeness. The output of
 1211 the CGMA process, the balanced net positions and balanced flows on DC lines, are a
 1212 critical input for the preparation of IGMs and their subsequent merging into CGMs. All
 1213 of the latter tasks are part of the post-processing phase. However, the CGMA process
 1214 proper ends with the provision of the balanced net positions and balanced flows on DC
 1215 lines to TSOs.

1216
 1217 It is helpful to provide an outline of each of the three phases before describing the individual
 1218 steps within each phase. The different steps are labelled with a code (reference) which makes it
 1219 easy to refer to them and the indicators associated with each of them. The first element of the
 1220 codes used is a symbol relating to the process phase:

- 1221 • A – Pre-processing phase
- 1222 • B – Processing phase
- 1223 • C – Post-processing phase

1224
 1225 An identifier for the time horizon could be added; e.g., (D-2), (W-1), etc. However, in line with
 1226 the introductory explanations it does not seem particularly helpful to make that distinction
 1227 except when defining the deadlines.
 1228

Reference	What happens in this step
A_*	TSOs prepare their PPD either by themselves (TSO-individual approach) or in coordination with other TSOs (coordinated approach). Alignment agents (RSCs) will likely play an important role in the coordinated approaches. When the PPD have been computed, TSOs provide their PPD to the CGMA IT platform via the OPDE. The pre-processing phase ends when the PPD have successfully passed the syntax check aimed at ensuring that the TSO's submission can be processed by the CGMA IT platform. (The content is assessed during the processing phase; see below.)

Reference	What happens in this step
B_*	The processing phase begins with a semantics check of the PPD provided to the CGMA IT platform. In other words, the content will be checked with respect to a number of quality criteria. In the case of the (D-2) time frame, missing or poor-quality data may be substituted by the CGMA IT platform. Once a full set of PPD is available, the CGMA algorithm described in the preceding chapter establishes balanced net positions and balanced flows on DC lines (borders). If convergence cannot be achieved immediately, a work-around procedure ensures that a solution can nevertheless be found. Balanced net positions and balanced flows on DC lines (per border) are then further adjusted by the separate DC PSLC sub-process (not part of CGMA): flows are computed for individual DC lines and DC losses are determined and the results of this sub-process are fed back to the CGMA IT platform. The processing phase ends when balanced net positions and balanced flows on DC lines have been made available to all participating TSOs.
C_*	In the post-processing phase each TSO by default adjusts its IGM by using the balanced net positions and balanced flows on DC lines as input data. The IGM adjustment may optionally be delegated to the alignment agent (RSC).

1229

1230

1231

1232

1233

1234

1235

1236

1237

1238

1239

1240

1241

1242

1243

1244

1245

1246

1247

1248

1249

1250

1251

1252

1253


1254

As part of this overview, the principal roles and parties involved should be explained. First of all, there are the TSOs with clearly defined responsibilities related to the provision of PPD. Pursuant to Article 19(8) of the CGMM, each TSO has to designate an alignment agent. It is expected that all alignment agents will be RSCs. However, the converse is not necessarily true in that some RSCs may decide not to offer the services described below. Article 19(8)(c) of the CGMM assigns to alignment agents the responsibility for ensuring that the CGMA *"results obtained are consistent with those obtained by all other alignment agents (if any)."* This task as well as the tasks related to the Active Quality Management Process described below clearly require some measure of cooperation between RSCs. It may be the case that this cooperation will be facilitated by a coordinator (i.e., an RSC with a coordinating function) and that this coordinator role will rotate among different alignment agents / RSCs. The cooperation between different alignment agents (roles, responsibilities etc.) and, in particular, the tasks and responsibilities of the coordinator are clearly topics to be addressed in the "Inter RSCI Agreement on Coordination and Minimum Standards of Regional Security Coordination Initiatives" envisaged in the "Multilateral Agreement on Participation in Regional Security Coordination Initiatives". In line with the deadline stated in Annex 3 of the Multilateral Agreement, the relevant provisions need to have been agreed and included in the Inter-RSC Agreement by the end of 2017. Future versions of the present CGMAM will be updated in the light of the Inter-RSC Agreement.

Finally, two optional elements of the pre-processing data mentioned at the very beginning of the preceding chapter, the absolute minimum net position (ABS_NP_MIN) and the absolute maximum net position (ABS_NP_MAX), should be explained in more detail here as they will be of considerable importance in this chapter.

1255
1256
1257
1258
1259
1260
1261
1262
1263
1264
1265
1266

If a TSO's balanced net position may under no circumstances be lower than a certain value, that TSO is facing a stability threat and can set an ABS_NP_MIN in line with this restriction. Conversely, if a TSO's balanced net position may under no circumstances exceed a certain value, that TSO's constraint is referred to as an adequacy threat and the TSO can set an ABS_NP_MAX. A TSO could theoretically even set both constraints; however, it still needs to respect the requirement for a minimum feasibility range of $2 \cdot \beta \cdot WF\%$. Note, however, that the ABS_NP_* are meant to be used on an exceptional basis only and they have to respect consistency requirements: ABS_NP_MIN has to be less than or, at most, equal to $(PNP + FR_{neg})$; ABS_NP_MAX has to be greater than or, at most, equal to $(PNP + FR_{pos})$. The following diagram illustrates the concept of absolute minimum and maximum net positions:



1267
1268
1269
1270
1271

Figure 4: Absolute minimum and maximum net positions

1272 **4.3 Pre-processing phase process steps**

1273

Reference	What happens in this step
A_010	Determination of PPD
A_020	PPD made available by TSOs
A_030	CGMA syntax check
A_040	End of pre-processing phase

1274

1275 These process steps and the associated (performance) indicators are described in more detail in
1276 the following table.

1277

1278 Default rule used in the tables in this chapter:

- 1279 • References to IT systems involved are meant to be comprehensive; i.e., if, for example,
1280 an indicator refers to the "CGMA IT platform" but does not refer to, say, the Quality
1281 Portal (QAS), then the data relating to that indicator will not be accessible via the QAS,
1282 they will only be available via the CGMA IT platform

1283

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
A_010	TSOs determine their PPD either on an individual or coordinated basis	(no relevant indicators at European level)		TSOs and / or RSCs may want to define their own (performance) indicators; however, as the process by which TSOs establish their PPD is out of scope of the CGMAM, no relevant indicators can be set at pan-European level
A_020	TSOs provide their PPD to the CGMA IT platform via the OPDE..			Provision of PPD by TSOs may, where agreed, be delegated to RSCs. This is especially relevant in case of a coordinated approach (RSC would then provide PPDs on behalf of all involved TSOs). It means that this RSC is the party with which the alignment agent will communicate instead of the TSO(s) in the rest of the process, especially for quality gate issues. RSC and alignment agent may be the same party, which favours this approach.

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
		A_020_010	General OPDE syntax check passed? Per TSO All time frames Each submission OPDE	This indicator has been added for the sake of completeness. It is expected that all data submitted to the OPDE will have to pass a general OPDE syntax check, so this step is included here for the PPD as well. Data that do not pass the OPDE syntax check will be rejected and TSOs will be informed about the rejection. However, this indicator is not expected to be analysed as part of the CGMA process.
		A_020_020	Time of submission of PPD Per TSO All time frames Each submission CGMA IT platform	As noted, applies to all PPD submissions whether (ultimately) successful or not
		A_020_030	Data format used for submission of PPD Per TSO All time frames Each submission CGMA IT platform	Each TSO was originally expected to choose and then continue to use one of two data formats for providing its PPD to the CGMA IT platform. However, given that at least for the foreseeable future only a single data format will be used, this indicator could be left out for the time being.
A_030	During the CGMA syntax check the CGMA IT platform verifies compliance with the format (and related) requirements of the CGMA IT platform; a submission that does not meet the requirements is rejected and the TSO concerned is informed accordingly.			
		A_030_010	CGMA syntax check successful? Per TSO All time frames Each submission CGMA IT platform	In order for the CGMA IT platform to be able to work with the PPD, the PPD submissions need to be in a format that the CGMA IT platform can understand. This is what is checked in this process step.

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
		A_030_020	PPD successfully submitted ? Per TSO All time frames Each submission CGMA IT platform	This particular indicator refers to the syntax only; "successfully" does not refer to the contents.
A_040	At this point the pre-processing phase has been completed. In the subsequent step (i.e., during the processing phase) the PPD will be checked with respect to their content.	(no relevant indicators at European level)		

1284

1285

1286 4.4 Processing phase process steps

1287

Reference	What happens in this step
B_010	Quality gate (CGMA semantics check)
B_020	Availability of a full set of PPD is ensured
B_030	First run of CGMA algorithm
B_040	Active quality management process (AQMP) – step 1: validation of adapted FRs
B_050	Active quality management process (AQMP) – step 2 [(D-2) only]: augmented CGMA algorithm
B_060	Ensure consistency of results obtained by different alignment agents (if any)
B_070	CGMA process results available
B_080	End of processing phase

1288

1289

1290 These process steps and the associated (performance) indicators are described in more detail in
1291 the following table:

1292

1293 B_010 - Quality gate (CGMA semantics check)

1294 At the beginning of the processing phase the PPD submitted are checked for "quality" in the
1295 sense of "content" as opposed to "format". That part of the process is also referred to as the
1296 "quality gate". The quality gate basically consists of a series of checks and tests that each TSO's
1297 PPD have to pass in order to be considered to be of sufficient quality. "Of sufficient quality"
1298 means that the PPD can be used by the CGMA algorithm without any adjustment, resubmission
1299 of data, or substitution. Such adjustments or substitutions are made as part of the subsequent
1300 process step. In order to ensure that the deadline for the submission of PPD is respected, the
1301 CGMA IT platform stops accepting PPD when the corresponding deadline has been reached.
1302 The submission of data after the deadline has to be especially authorised by an alignment agent
1303 and is logged.

1304

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
B_010	As PPD are submitted, the CGMA IT platform --runs a number of checks on the PPD submitted (see below), --adjusts the data as needed, and --informs the TSO concerned about the results. At the agreed cut-off time, the CGMA IT platform blocks further PPD submissions.			
		B_010_010	Are minimum requirements with respect to FRs respected? Per TSO All time frames Each submission CGMA IT platform	This concerns the agreed minimum range (which is determined by the WF). The FR is defined relative to the PNP so it is in principle always consistent with the PNP. An insufficiently wide FR does not lead to the PPD being rejected (see next line)

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
		B_010_020	<p>Adjustments to insufficiently wide FRs (including a special mention if ABS_NP_* had to be exceeded)?</p> <p>Per TSO</p> <p>All time frames</p> <p>Each submission</p> <p>CGMA IT platform</p>	<p>The CGMA IT platform automatically adjusts an insufficient FR and informs the TSO concerned about the new values used. This approach makes it possible to retain the remainder of the PPD, notably the PNP, rather than substitute the complete set of PPD.</p> <p>Default adjustment: FRneg and FRpos are each increased by half of what is still needed in order to reach the minimum required</p> <p>If the default adjustment were to lead to one of the ABS_NP_* (if any) being exceeded, the constraining FR would be set to equal the corresponding ABS_NP_* and the remainder of the adjustment needed would be made to the other FR.</p> <p>If following the above procedure were to lead to both ABS_NP_* being exceeded, then in the first instance both FRs would be set to equal the corresponding ABS_NP_*. The remaining adjustment needed would then, once again, be assigned to both FRs equally such that both ABS_NP_* would be exceeded by the same absolute amount in terms of MW. Of course, the TSO is alerted to this modification and invited to resubmit the PPD (see B_020)</p>

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
		B_010_030	Where applicable: are DC data complete (expected flows; as well as $I_{Flow_{max,k,i}}$ and $I_{Flow_{min,k,i}}$)? Per TSO All time frames Each submission CGMA IT platform	Adjustments to the DC FRs are not mentioned, because the DC FRs are, in principle, given by the maximum permissible import and export flows which are equal to the technical capacity. As noted in the description of the CGMA algorithm, TSOs can specify a narrower DC FR due to operational requirements (see below).
		B_010_035	Where applicable, adjust DC data Per TSO All time frames Each submission CGMA IT platform	This step generally refers to the preparation of preliminarily balanced DC flows as well as consistent maximum import and export flows. If data from one TSO are missing, data from the other TSO are used. If data from the TSOs are inconsistent, they are consolidated according to agreed rules. The TSOs concerned are informed who are allowed to upload new data if feasible within the deadline.
		B_010_040	Are ABS_{NP_* provided? Per TSO All time frames Each submission CGMA IT platform	All values set shall be reported per TSO. As these are entirely optional data, PPD not containing ABS_{NP_* will not be rejected. ABS_{NP_MIN} corresponds to a stability threat ABS_{NP_MAX} corresponds to an adequacy threat It is also possible to specify both; however, the minimum FR has to be respected.

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
		B_010_045	Where applicable (i.e., where $I_{Flow_{max,k,i}}$ and $I_{Flow_{min,k,i}}$ for a DC cable have been provided), are $I_{Flow_{max,k,i}}$ and $I_{Flow_{min,k,i}}$ consistent with the technical limits of the DC line? Per TSO All time frames Each submission CGMA IT platform	Values per TSO. These values could be said to be a DC equivalent of ABS_NP_*. They cannot, of course, exceed the technical limits of the cable. The CGMA IT platform will therefore adjust the data provided if necessary.
		B_010_050	Are consistency requirements with respect to ABS_NP_* respected? Per TSO All time frames Each submission CGMA IT platform	The ABS_NP_* have to be consistent with the other PPD provided (e.g., ABS_NP_MAX of + 500 MW is not consistent with a PNP of + 1000 MW). The data are consistent if the following formulae hold: $ABS_NP_MAX \geq PNP + FR_{pos}$ $ABS_NP_MIN \leq PNP + FR_{neg}$ (Note the sign convention.) If this is not the case, the PPD should be rejected and the TSO should be informed accordingly.
		B_010_055	Are consistency requirements with respect to $I_{Flow}(*,k,i)$ respected? Per TSO All time frames Each submission CGMA IT platform	The $I_{Flow}(*,k,i)$ have to be consistent with the other PPD provided. The corresponding tests are equivalent to those for the ABS_NP_*. If the data are not consistent, the PPD should be rejected and the TSO should be informed accordingly.

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
		B_010_060	Are general consistency requirements met? Per TSO All time frames Each submission CGMA IT platform	This is about plausibility checks such as reasonable limits – e.g., a "small" bidding zone should not have a PNP of 10000 MW etc. However, a reference to such plausibility checks is recorded here primarily as a reminder. It will be rather difficult to define sensible tests in the first place and even if and when such tests have been included in the checking routine in the light of operational experience it is not at all clear whether PPD could or should be rejected on the basis of such tests. A more likely function is that such plausibility checks will serve as a warning that, for example, flags PPD for manual checking.
		B_010_070	Have PPD successfully passed the Quality Gate? Per TSO All time frames Each submission CGMA IT platform	This particular indicator refers to the content only; "successfully" does not refer to the syntax (which is checked in a preceding step)

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
		B_010_080	Time of submission of all sets of PPD that have successfully passed the Quality Gate? Per TSO All time frames Each submission CGMA IT platform	The relevant criterion is the dispatch of the corresponding ACK file; the time at which that file is dispatched is recorded. The most important question, of course, is whether the associated deadline has been met? Note that if, upon request of the TSO, the CGMA IT platform is reopened for submission of revised / updated PPD, this indicator would also need to be recorded at a later stage in the process. However, for the time being an explicit reference has not been included a second time below.
		B_010_090	Logging of PPD-related ACK files Per TSO All time frames Each submission CGMA IT platform	

1305

1306 B_020 - Availability of a full set of PPD is ensured

1307 The CGMA IT platform subsequently ensures the availability of a full set of PPD; regardless of
1308 whether all TSOs have submitted their PPD in time and regardless of the quality of the PPD
1309 submitted. In other words, if data are missing the CGMA IT platform substitutes these data;
1310 limiting the substitution to those data that are missing.

1311 The substitution rules used are similar to those defined for the overall CGM process and
1312 described in the annotated CGMM. For the year-ahead time frame, no substitution rules are
1313 defined because, given the time available, substitution is to be strictly avoided. The month-
1314 ahead and the week-ahead time frame are not mandatory at pan-European level. If all relevant
1315 regions agree on a common approach, this common approach could be documented in a future
1316 version of the CGMAM. For the time being, no substitution rules are included for these time
1317 frames.

1318

1319 As for the (D-2) time frame, one analogy with the substitution rules for IGMs referred to above
1320 is that both pre-processing data for the same day of delivery (the equivalent of IGMs for the
1321 same day of delivery) and CGMA results for the complete history of prior algorithm runs (the

1322 equivalent of archived IGMs for days of delivery in the past) may be available as substitute
 1323 data.

1324
 1325 In the case of the CGMA process, substitute data would, in principle, be required for the full set
 1326 of those pre-processing data that are mandatory, i.e.,

- 1327 • preliminary net position;
- 1328 • feasibility range for the adjustment of the preliminary net position;
- 1329 • preliminary flows on DC lines;
- 1330 • maximum import and maximum export flows on DC lines

1331
 1332 However, no genuine substitution will be carried out in the case of the feasibility range for the
 1333 adjustment of the preliminary net position and in the case of the maximum import and
 1334 maximum export flows on DC lines. If these data are not available, they will always be replaced
 1335 with the minimum feasibility range, placed symmetrically around the preliminary net position,
 1336 and the technical capacity limits of the DC line, respectively.

1337
 1338 As for the preliminary net position and the preliminary flows on DC lines, the basic principle is
 1339 to use substitute data that are as representative of the given scenario as possible.

1340
 1341 Step 1: Use values for different timestamps from the same set of PPD (i.e., the same day of
 1342 delivery) by applying the order of substitution indicated in the matrix below (Figure 5).

1343
 1344

Replaced by ->	Load increase						Beginning of outages												End of outages / winter peak											
	00:30	01:30	02:30	03:30	04:30	05:30	06:30	07:30	08:30	09:30	10:30	11:30	12:30	13:30	14:30	15:30	16:30	17:30	18:30	19:30	20:30	21:30	22:30	23:30						
00:30	1	2	3	4	5	6																								
01:30	5	1	2	3	4	6																								
02:30	5	3	1	2	4	6																								
03:30	6	4	2	1	3	5																								
04:30	6	4	3	2	1	5																								
05:30			5	4	2	1	3																							
06:30							1	2	3	4	5	6	7																	
07:30								1	2	3	4	5	6																	
08:30									1	2	3	4	5																	
09:30										3	1	2	4	5																
10:30											3	2	1	4	5															
11:30												5	2	1	3	4														
12:30													5	3	2	1	4													
13:30														5	4	2	1	3												
14:30															7	6	5	4	1	2	3									
15:30																6	5	4	1	2	3									
16:30																	6	5	4	3	1	2								
17:30																		7	6	5	4	3	1	2						
18:30																			7	6	5	4	3	2	1					
19:30																						8								
20:30																						3	1	2	4	5				
21:30																							2	1	3	4	5			
22:30																								4	2	1	3	5		
23:30																									5	4	2	1	3	
23:30																										5	4	3	2	1

1345
 1346 Figure 5: Substitution matrix

1347
 1348 For example, for the 11:30 timestamp the substitution order would be:

- 1349 1 – 11:30 (no substitution)
- 1350 2 – 10:30

1351 3 – 12:30

1352 4 – 13:30

1353 5 – 9:30

1354

1355 Step 2: If step 1 does not succeed (for example, because the entire file with PPD has not been
1356 received by the CGMA IT Platform), substitute data will be obtained from the Pan-European
1357 Verification Platform (PEVF) in the form of matched schedules relating to the same timestamp
1358 for a previous day of the same type. The PEVF is an application linked to the OPDE just like
1359 the CGMA IT platform and will be briefly illustrated in chapter 6. Three types of days are
1360 distinguished: working day, Saturday, Sunday. (A calendar of bank holidays etc will not be
1361 maintained by the CGMA IT platform.) In step 2, the CGMA IT platform will go back at most
1362 five days. If no substitute data can be obtained in this manner, the system moves on to step 3.

1363

1364 Step 3: In step 3, substitute data would once again be obtained from the PEVF in the form of
1365 matched schedules related to different timestamps for a previous day of the same type by
1366 applying the above substitution matrix. As in step 2, the CGMA IT platform will go back at
1367 most five days. If no substitute data can be obtained in this manner, the system moves on to step
1368 4.

1369

1370 Step 4: In step 4, the PEVF would continue to be the source of the substitute data. The data to
1371 be used in step 4 are matched schedules relating to the same timestamp on a past day of a
1372 different type. The system would go back at most five days.

1373

1374 If steps 1 to 4 do not yield usable substitute data, default values of zero for both the preliminary
1375 net position and the preliminary flows on DC lines are used.

1376

1377 Note that if PPD are substituted, all PPD will be substituted. For example, if only the
1378 preliminary net position is missing the system will nevertheless substitute the preliminary net
1379 position and (if applicable) the DC-related pre-processing data.

1380

1381

1382

1383

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
B_020	<p><u>(D-2) time frame:</u> At the agreed cut-off time, the CGMA IT platform ensures the availability of suitable PPD for each bidding zone by</p> <ul style="list-style-type: none"> --replacing missing data with substitute data --modifying low-quality data (e.g., insufficient feasibility ranges) --informing the TSOs concerned about the substitution and by reopening, upon request, the CGMA IT platform for submission of (updated) PPD --TSOs are also informed about adjustments to FRs and invited to resubmit new PPD with updated FRs themselves; upon request the CGMA IT platform can be reopened for submission of (updated) PPD <p><u>(W-1) / (M-1):</u> Not pan-European time frames; may be added at a later time</p> <p><u>(Y-1):</u> Substitution of flawed or missing data is not acceptable for this time horizon; the alignment agents are responsible for obtaining a suitable set of PPD from their TSOs</p>			
		B_020_010	PPD substituted because of (...) Per TSO All time frames Each submission CGMA IT platform	The indicator should distinguish between substitutions due to poor quality data and substitutions necessary because no data were submitted.

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
		B_020_020	Preliminary net position across all bidding zones For the CGM area All time frames Each submission CGMA IT platform	The CGMA IT platform would, by default, aggregate across the entire CGM area. This indicator does not, in principle, allow making inferences with respect to individual synchronous areas.
		B_020_030	Aggregate FR For the CGM area All time frames Each submission CGMA IT platform	The CGMA IT platform would, by default, aggregate across the entire CGM area. This indicator does not, in principle, allow making inferences with respect to individual synchronous areas. Specifically, the aggregate FR exceeding the aggregate PNP in the opposite direction as the aggregate deviation from the target net position is a necessary (but not sufficient) condition for achieving convergence.

1384

1385

1386 **B_030 – First run of CGMA algorithm**

1387 The CGMA algorithm will take whatever input data are available from the CGMA IT platform
1388 following the cut-off time and possible substitution of missing or poor-quality data and attempt
1389 to obtain a solution; i.e., a set of balanced net positions and balanced flows on DC lines
1390 (borders).

1391 • The (optional) absolute net positions (ABS_NP_MAX and ABS_NP_MIN) are not used
1392 as constraints in the first run of the algorithm. TSOs can provide these additional
1393 constraints if the net position based upon which they build their IGM may not, under
1394 any circumstances, be lower (ABS_NP_MIN is a lower bound for permissible BNP) or
1395 higher (ABS_NP_MAX is an upper bound for permissible BNP) than a certain value.

1396 • If the algorithm finds a solution in the first run without adapting feasibility ranges, that
1397 solution is the default solution. The CGMA algorithm may be run again at a later time,
1398 but the first solution will be retained as the default solution.

1399 ○ At the (D-2) time horizon, the first run of the CGMA algorithm is to be
1400 completed just after 16:35h. (16:35h is the (D-2) deadline for all input data to
1401 be available, by substitution if necessary.)

1402 ○ PI: "Solution obtained without modification of FRs"

1403 ○ Note that since no feasibility ranges have been adapted, the absolute net
1404 positions (ABS_NP_*) cannot have been exceeded.

- 1405
- 1406
- 1407
- 1408
- 1409
- 1410
- 1411
- 1412
- 1413
- 1414
- 1415
- If the algorithm cannot find a solution without adapting feasibility ranges, it will extend the feasibility ranges by using the approach described at the very end of the chapter on the CGMA algorithm ("Applying the algorithm: Step 3 – scenarios without solutions").
 - PI: "No convergence without adaptation of FRs; FRs extended by a total of X MW / Y %"
 - Since no restrictions are imposed upon the extent to which the FRs may be extended, the existence of a solution is guaranteed from a mathematical point of view. Whether the solution obtained is meaningful / relevant in practical terms will be assessed in the subsequent step ("Validation of adapted FRs")

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
B_030	First run of CGMA algorithm as described above			
		B_030_010	Time at which first algo run was completed One value per CGMA process Applies to all time frames CGMA IT platform	Completion of algorithm run means that the previous step has to have been completed. Checking on the algorithm run thus provides a simple means of checking whether the earlier CGMM deadline was respected if the algo run is completed at or before 16:35h (D-2).
		B_030_020	Solution obtained without modification of FRs? One value per CGMA process Applies to all time frames CGMA IT platform	
		B_030_030	No convergence without adaptation of FRs; FRs extended by a total of X MW / Y % One value per CGMA process Applies to all time frames CGMA IT platform	This indicator, in principle, only becomes relevant if the value of indicator B_030_020 above is "No". If a solution is found without adapting FRs, the value of indicator B_030_030 becomes "Not applicable" (an even simpler solution would be to provide no value in that case).

1416

1417

1418 B_040 – Active quality management process (AQMP) – step 1: validation of adapted FRs

1419 (NB: This process step is not relevant if the CGMA algorithm has managed to find a solution
1420 without adapting FRs.)

1421 If, in the first run, the CGMA algorithm had to adapt the FRs in order to obtain a solution, that
1422 solution remains to be confirmed. The confirmation entails validating the adapted (extended)
1423 FRs. In other words, if it can be shown that the adjustment of the FRs was acceptable to all
1424 TSOs, then the solution obtained is a valid solution.

1425

1426 This first step of the AQMP makes use of the fact that within a synchronous area it does not
1427 matter mathematically where (in which bidding zone or zones) the FRs are extended. In
1428 particular, within a synchronous area the extension of one or two sets of FRs by a large amount
1429 is equivalent to the extension of many FRs by a small amount. The latter kind of adjustment is
1430 the adjustment made by the CGMA algorithm. However, in a synchronous area with many
1431 TSOs such as Continental Europe it would be very time-consuming to contact each and every
1432 TSO and obtain permission for extending the FRs. Also, if even one TSO refused the
1433 adjustment, other TSOs' FRs would have to be extended by an even larger amount. Therefore, it
1434 would be much easier to validate the extended FRs if the corresponding commitments could be
1435 obtained from a small number of TSOs.

1436

1437 All TSOs and their alignment agents are therefore encouraged to pre-agree on mutual assistance
1438 arrangements by which they commit to help each other by extending their feasibility ranges if
1439 necessary. Such arrangements are all the more valuable in cases where a TSO knows that it will
1440 occasionally have to specify absolute minimum or maximum net positions. Note that all TSOs
1441 will, at any rate, have to enter into contractual agreements with their alignment agents (RSCs).
1442 Such contractual agreements should be tailored to the specific needs of each region or group of
1443 TSOs and might very well include operational agreements such as provisions on mutual
1444 assistance in the CGMA process.

1445

1446 Before outlining how this approach would be implemented in practical terms, note that step 2 of
1447 the AQMP provides for a fall-back procedure that essentially works as follows: The CGMA
1448 algorithm is re-run with an additional set of constraints. These additional constraints – the
1449 ABS_NP_* - guarantee that, for example, a TSO that knows that its imports of electricity
1450 exceeding a certain value would lead to a stability threat can ensure that such constraints will be
1451 respected; i.e., that its feasibility ranges will not be involuntarily expanded beyond the
1452 constraint (in this case ABS_NP_MIN). Of course, such constraints could be used to address
1453 other types of restrictions in addition to import restrictions such as a minimum import or
1454 maximum export value in case of an adequacy threat. To the extent that such constraints are set
1455 and prevent the corresponding TSOs' feasibility range(s) from being adjusted, all other TSOs'
1456 feasibility ranges have to be adjusted by a commensurately larger amount. Note, however, that
1457 making use of such ABS_NP_* constraints in the computation of the results is to be avoided as
1458 much as possible. Therefore, the fall-back procedure is preceded by step 1; an alternative
1459 approach during which the ABS_NP_* constraints do not have to be explicitly included in the

1460 calculation of the results, but the requirement in Article 19(4)(c) of the Common Grid Model
1461 Methodology is respected nonetheless.

1462
1463 In practical terms, the CGMA algorithm will aggregate the FR adjustments it has made by
1464 alignment agent. Each alignment agent thus knows the total amount of the FR adjustments (in
1465 terms of MW) that it needs its TSOs to agree to. In particular, if a single TSO were to agree to
1466 accept the entire adjustment that would ensure that this alignment agent has made the
1467 contribution expected from it.

1468
1469 As far as the process is concerned, the alignment agents might agree for one of their number to
1470 act as coordinator. Note, however, that these details of implementation have not yet been
1471 discussed and are unlikely to be resolved before the dry run envisaged for 2017-Q4. If the
1472 CGMA algorithm has to extend the FRs, this is signalled to all alignment agents (and all TSOs)
1473 in a suitable manner; the details of this alert mechanism remain to be determined. One option
1474 might be for alignment agents to organise a conference call at a certain time during which
1475 alignment agents unable to provide their assigned contribution in terms of extended FRs can ask
1476 other alignment agents for assistance. As for whether a conference call is the most suitable
1477 means of communication, further trials and testing can be conducted during the dry run in 2017-
1478 Q4. Nothing hinges on using this or an alternative means of communication.

1479
1480 In practical terms, each alignment agent would (likely based on the above-mentioned pre-
1481 agreements) contact one or more of its TSOs with a view to obtaining agreement to extend the
1482 TSO's (TSOs') FR (typically by the maximum amount acceptable) until the total amount of
1483 adjustment of FRs required from that alignment agent has been obtained. Either the TSOs
1484 concerned would send updated PPD (in which case TSOs need to be allowed to provide these
1485 data even after the usual cut-off time) or the alignment agent makes these modifications
1486 manually via the CGMA application GUI. In the latter case, a means of ensuring that TSOs'
1487 agreement is documented in a robust manner needs to be found. For example, if the alignment
1488 agent establishes contact by telephone and their (telephone) lines are recorded anyway, the
1489 documentation required would be ensured without any additional preparations. TSOs would
1490 also need to receive an acknowledgement via a suitable mechanism (to be determined).

1491
1492 When all alignment agents have provided their assigned share of the adjustments required, the
1493 CGMA algorithm can be manually restarted using the updated PPD / FRs as input. If there were
1494 to be a coordinating RSC, for example, that coordinator could trigger this re-calculation. Under
1495 the assumptions made, a solution would be guaranteed to exist and would have the property that
1496 (i) all (updated) FRs are respected and (ii) none of the ABS_NP_* are violated.

1497
1498
1499 Step 1 of the active quality management process, if successful, ensures that a solution is found
1500 without including another set of constraints in the algorithm. No involuntary changes to FRs are
1501 required.

- 1502 • "successful completion of algo run following voluntary modification of FRs by X MW"
1503 is registered (PI)

- 1504 • FR adjustments accepted are to be reported per TSO
 1505
 1506
 1507

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
B_040	Solution requires adjustment of FRs (i.e., confirmation that these FR adjustments were acceptable)			
		B_040_010	Total adjustment requested per alignment agent Per alignment agent All time frames CGMA IT platform	
		B_040_020	Total adjustment provided per alignment agent and per TSO Per alignment agent; per TSO All time frames CGMA IT platform	Note that agreeing to an adjustment is equivalent to providing updated PPD and is recorded accordingly
		B_040_030	Manual algorithm runs Per CGMA process All time frames CGMA IT platform	Also applies to manual algorithm runs triggered in subsequent steps
		B_040_040	Computation time required for all manual algorithm runs Per CGMA process All time frames CGMA IT platform	
		B_040_050	Time of last PPD adjustment Per CGMA process All time frames CGMA IT platform	
		B_040_060	Computation time required for final run of CGMA algorithm Per CGMA process (if applicable) All time frames CGMA IT platform	

1508
 1509
 1510

1511

1512 B_050 – Active quality management process (AQMP) – step 2 [(D-2) only]: augmented CGMA
1513 algorithm

1514
1515 If step 1 of the AQMP is not successful (i.e., no solution is found) by the cut-off time (17:05h in
1516 the case of the (D-2) process), the CGMA algorithm is automatically restarted. However, under
1517 step 2 of the AQMP the CGMA algorithm is augmented with an additional set of constraints,
1518 namely the absolute net positions (ABS_NP_MIN and ABS_NP_MAX).

1519
1520 Note that the alignment agent shall have the ability to try out the procedure described in this
1521 step earlier in the process (i.e., before the 17:05h deadline) for trial and testing purposes without
1522 the results being used automatically ("dry run").

1523
1524 As the augmented CGMA algorithm is run, three outcomes are possible:

- 1525 • The algorithm finds a solution and none of the additional constraints become binding.
 - 1526 ○ PI: "No convergence without adaptation of FRs; augmented CGMA algorithm
 - 1527 run; none of the ABS_NP_* binding; solution obtained; FRs extended by a total
 - 1528 of X MW"
- 1529 • The algorithm finds a solution and one or more of the additional constraints become
1530 binding.
 - 1531 ○ PI: "No convergence without adaptation of FRs; augmented CGMA algorithm
 - 1532 run; one or more of the ABS_NP_* binding; solution obtained; FRs extended
 - 1533 by a total of X MW" is registered (PI) and published to QAS
 - 1534 ○ Those ABS_NP_* constraints that were binding are reported to all TSOs
- 1535 • There is no solution. This outcome is exceedingly unlikely in that it requires all TSOs to
1536 set additional constraints in the form of absolute net positions. For the sake of
1537 completeness, if that outcome should materialise the solution obtained during step 1
1538 (guaranteed to exist because the FRs are extended as necessary) is retained as the
1539 solution. In this case TSOs would have to be informed about the outcome via a suitable
1540 alert mechanism.
 - 1541 ○ PI: "No convergence without adaptation of FRs; augmented CGMA algorithm
 - 1542 run; all of the ABS_NP_* binding; no solution obtained; FRs extended by a
 - 1543 total of X MW / fall-back to default solution" is registered (PI) and published to
 - 1544 QAS and sent to TSOs as an alert (means of communication to be determined)

1545
1546 To repeat, if the augmented CGMA algorithm finds a solution by extending feasibility ranges
1547 involuntarily, this can be done in the following way: Feasibility ranges can be extended on both
1548 sides for those TSOs who have not set any ABS_NP_*. If a TSO has set an ABS_NP_MAX, the
1549 balanced net position for that TSO shall not exceed the value of ABS_NP_MAX. If a TSO has
1550 set an ABS_NP_MIN, the balanced net position for the TSO shall not be less than the value of
1551 ABS_NP_MIN.

1552
1553 With respect to step 2 of the AQMP, the more ABS_NP_* conditions are set and the more
1554 constraining these are, the more the FRs of TSOs without such ABS_NP_* conditions will have
1555 to be adjusted.

1556
1557

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
B_050	Augmented CGMA algorithm is run			
		B_050_010	No convergence without adaptation of FRs; augmented CGMA algorithm run; none of the ABS_NP_* binding; solution obtained; FRs extended by a total of X MW Per CGMA process All time frames CGMA IT platform	
		B_050_020	No convergence without adaptation of FRs; augmented CGMA algorithm run; one or more of the ABS_NP_* binding; solution obtained; FRs extended by a total of X MW Per CGMA process All time frames CGMA IT platform	
		B_050_030	Binding ABS_NP_* constraints Per CGMA process per TSO All time frames CGMA IT platform	
		B_050_040	No convergence without adaptation of FRs; augmented CGMA algorithm run; all of the ABS_NP_* binding; no solution obtained; FRs extended by a total of X MW / fall-back to default solution Per CGMA process All time frames CGMA IT platform	

1558
1559
1560

1561 B_060 Ensure consistency of results obtained by different alignment agents (if any)

1562

1563 This task is recorded here for the sake of completeness; it is not expected to be of practical
 1564 relevance. However, by way of background note that since all alignment agents are using the
 1565 same CGMA IT platform, they must logically be producing identical (i.e., consistent) results if
 1566 and only if their computations are based upon the same input data. The only way in which
 1567 inconsistencies might thus be introduced would be for alignment agents to use different sets of
 1568 input data. The latter scenario is avoided by imposing the simple rule that the CGMA results to
 1569 be used in the later stages of the process are to be those based upon the definitive run of the
 1570 CGMA algorithm (in the case of the (D-2) time horizon this is to be the run starting at or just
 1571 after 17:05h).

1572

1573

1574 B_070 - CGMA process results available

1575

1576 The CGMA IT platform makes the results of the CGMA process available to all TSOs and
 1577 RSCs via the OPDE in a CIM-based format and also publishes the results of the CGMA process
 1578 via the quality portal. The CGMA results (output data) are, for each scenario and each TSO:

1579

- balanced net position

1580

- where applicable, balanced flows on DC lines (borders)

1581

The granularity of the output data corresponds to the granularity of the input data. For example,
 1582 if a TSO provides a single PNP for a control area covering more than one bidding zone, that
 1583 TSO will receive a single balanced net position in return.

1584

1585

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
B_070	CGMA output available			
		B_070_010	CGMA results incl. time-stamp of delivery provided to primary users (i.e., the users who provided the PPD) Per CGMA process; per TSO All time frames CGMA IT platform	

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
		B_070_020	CGMA results incl. time-stamp of delivery provided to secondary users (i.e., other users who have a use for the results, if any) Per CGMA process; per TSO All time frames CGMA IT platform	

1586

1587

Not covered in this process description is the separate DC PSLC (pole splitting and loss calculation) sub-process, as part of which balanced flows are computed for individual DC lines, losses are calculated, and balanced net positions are adjusted accordingly.

1588

1589

1590

1591

1592

B_080 - End of processing phase

1593

The processing phase ends when balanced net positions and balanced flows on DC lines have been made available to all participating TSOs.

1594

1595

1596

1597

4.5 Post-processing phase process steps

1598

Reference	What happens in this step
C_010	Data for checking for compliance with CGMA results available
C_020	Data for checking for compliance with "best forecast" criterion available
	The following steps are mentioned for the sake of completeness, but are no longer part of the CGMA process:
	Each TSO adjusts its IGM based on its balanced net position and (if applicable) balanced flows on DC lines
	Each TSO provides the aligned IGM for merging into the CGM

1599

1600

These process steps and the associated (performance) indicators are described in more detail in the following table:

1601

1602

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
C_010	Data for checking for compliance with CGMA results available	C_010	Data for checking for compliance with CGMA results available Per CGMA process; per TSO All time frames This indicator is expected to be computed by QAS	"Compliance check" refers to checking whether the updated IGMs are indeed consistent with the CGMA output data provided. The CGMA process provides the raw data. However, the compliance check as such is no longer part of the CGMA process.
C_015		C_015	Data for checking for compliance with CGMA results available Per CGMA process; per TSO All time frames This indicator is expected to be computed by QAS	This indicator aims at obtaining a list of delta values; i.e., not just a "Yes or No?" answer to the question of whether an IGM is consistent with the CGMA output, but a list of deviations measured in MW per optimisation area and for all relevant data (net positions; flows on DC lines).
C_020	Data for checking for compliance with "best forecast" criterion available	C_020	Data for checking for compliance with "best forecast" criterion available Per CGMA process; per TSO (D-2) time horizon CGMA IT platform	This "compliance check" refers to checking whether the PNP and expected flows on DC lines can be said to constitute "best forecasts" as required by Article 18(3) of Regulation 2015/1222. The CGMA process provides the raw data to be compared to PEVF data. However, the compliance check as such is no longer part of the CGMA process.

Reference	Description (responsible party; input / starting point; output / results)	Indicator ref.	Indicator description (incl. destination)	Comments
C_025	Aligned forecast quality	C_025	Data for checking on the added value of the CGMA process Per CGMA process; per TSO (D-2) time horizon CGMA IT platform	This "compliance check" refers to checking how good a predictor of realised physical flows the CGMA results were and, in particular, whether the CGMA results managed to improve upon the PPD. The CGMA process provides the raw data to be compared to PEVF data. However, the compliance check as such is no longer part of the CGMA process.
C_030		C_030	Assessment of overall robustness of CGMA algorithm and process	Not part of the CGMA process

1603
1604

1605 4.6 Deadlines for all process steps and all time frames

1606
1607
1608
1609
1610

The deadlines in the following table²¹ refer to the time by which the corresponding step has to have been completed. Where a deadline refers to a certain date and not time, the deadline corresponds to 23:59h on the date given.

²¹ Please note that while the heading of this section refers to "all time frames", the time frames which are not mandatory at pan-European level; i.e., (W-1) and (M-1); are (for the time being) included as placeholders only. The relevant deadlines would have to be agreed on regional level. If all regions concerned can agree on common deadlines it would be possible to include these in a future update of the present document. Otherwise the reference in the present document serves as a reminder of the need for agreeing on common deadlines for each of the relevant regions.

1611

Reference	(D-2)	(W-1)	(M-1)	(Y-1)	Comments
A_010	Before 16:30h				
A_020	16:30h			15 July plus three business days	
A_030	16:30h plus ca. 5 seconds				
A_040	16:30h plus ca. 10 seconds				
B_010	~ 16:31h				
B_020	16:35h				
B_030	16:35h plus a few seconds				
B_040	Shortly before 17:05h at the very latest				
B_050	17:15h minutes two minutes or so				
B_060	17:15h minus one minute or so				
B_070	17:15h			15 July plus nine business days	
B_080	Just after 17:15h				
IGM update	Well before 19:00h				

1612

1613

1614 5 Reporting

1615

1616 Three types of reporting will be implemented under the CGMAM:

- 1617 • Operational reporting
- 1618 • TSO-individual reporting via QAS
- 1619 • Regulatory reporting

1620

1621 The operational reporting is targeted at the alignment agents (RSCs). The key conduit for the
1622 operational reporting is the GUI of the CGMA IT platform from which the time series with data
1623 on all the performance indicators described in the the CGMA IT specification will be available
1624 for analysis. The primary data themselves (PNPs, expected flows on DC lines, FRs, BNPs,
1625 balanced flows on DC lines etc.) will also be available.

1626

1627 TSO-individual reporting via QAS is meant for TSOs and will encompass the data of most
1628 relevance to a TSO's participation in the CGMA process; in particular the primary data referred
1629 to above (PNPs, expected flows on DC lines, FRs, BNPs, balanced flows on DC lines etc.).

1630

1631 Regulatory reporting is modelled on the biennial reporting under Article 31(3) of Regulation
1632 2015/1222 and will, in fact, use the report on capacity calculation and allocation as the reporting
1633 channel. In other words, CGMA performance indicators will be included in the biennial report
1634 under Article 31(3). The first of these reports was due on 14 August 2017; with additional
1635 reports to be provided upon explicit request of ACER every two years thereafter. By default all
1636 performance indicators will be included. However, in light of the volume of information already
1637 being submitted as part of the report on capacity calculation and allocation it may be sensible to
1638 restrict the CGMA-related data to a subset of the performance indicators.

1639

1640

1641 **6 IT implementation**

1642

1643 The present chapter explains the CGMA IT implementation in four distinct sections. The first
1644 section describes the work streams into which the IT-implementation-related work has been
1645 summarised. The second section explains the integration of the CGMA IT platform into the
1646 overall IT architecture built on and around the Operational Planning Data Environment (OPDE;
1647 an IT infrastructure supporting the CGM and other processes being developed by ENTSO-E).
1648 The details of the CGMA IT platform setup are described in the "Common Grid Model
1649 Alignment Requirements and Technical Specification" (or "CGMA IT specs"). Because of the
1650 importance of that material for the present CGMAM, the subsequent section provides an
1651 extensive summary of that document. Some of the technical aspects of CGMA-related data
1652 exchanges are covered in the "CGMA Data Exchanges Implementation Guide" prepared by
1653 ENTSO-E WG EDI on behalf of the CGMA project. In order to complete the present chapter,
1654 the fourth and final section gives an overview of the contents of the CGMA Data Exchanges
1655 Implementation Guide.


1656

1657 **6.1 CGMA IT platform within the overall IT architecture**

1658


1659 As illustrated by Figure 6 the CGMA application is one of the applications that are part of the
1660 Operational Planning Data Environment (OPDE) – in Article 21 of the CGMM referred to as
1661 "information platform".

1662



1663
1664 Figure 6: Operational Planning Data Environment (stylised representation)

1665
1666 The following Figure 7 provides some additional technical context for the OPDE applications:
1667



1668
1669 Figure 7: Operational Planning Data Environment (stylised architecture)

1670 The following section describes the CGMA IT specification proper.

1671

1672 **6.2 The CGMA IT specification**

1673


1674 The requirements with respect to the (central) CGMA IT platform are described in detail in the
 1675 "Common Grid Model Alignment Requirements and Technical Specification" (or "CGMA IT
 1676 specs"). While the primary addressees of that document are the developers of the CGMA IT
 1677 platform, some passages of the CGMA IT specs will also be relevant for the vendors who adapt
 1678 TSOs' IT systems as required as well as the TSOs themselves. The vendors will, in particular,
 1679 find the chapters on the external data exchange as well as the chapter on the Quality Gate to be
 1680 of interest whereas the chapter on master data will be important for TSOs. Apart from this target
 1681 audience, the CGMA IT specs should be considered background material for the present
 1682 CGMAM. Knowing and understanding the CGMA IT specs is therefore not a prerequisite for
 1683 understanding the present document. However, since many readers of the CGMAM will be very
 1684 interested in the CGMA IT specs, an extensive summary is provided below.

1685

1686 Following a description of the scope of the CGMA IT specs and the material covered therein
 1687 (chapter 01), chapter 02 explains the various components of the CGMA IT platform and how
 1688 these are linked to external applications within the OPDE (Operational Planning Data
 1689 Environment). The following Figure 8 provides an overview.

1690

1691



1692

1693 Figure 8: CGMA IT platform architecture

1694

1695

1696 The integration and process layer will provide transparent access to the OPDE and connect all
1697 CGMA application modules internally via web services. It is able to read and write all required
1698 data formats. The process engine is shown as part of the integration and process layer. This
1699 component will guard and control the optimisation service shown on the left-hand side of the
1700 diagram; it will schedule automatic and manual jobs, and gather process-related quality and
1701 performance indicators.

1702
1703 The distinct areas in the above diagram correspond to the principal modules of the CGMA IT
1704 platform. The CGMA calculation module includes GAMS (General Algebraic Modeling
1705 System) with CPLEX (commercial software integrated via an API); the optimisation core (a
1706 service running optimisation tasks); and the quality gate which – as was described in detail in
1707 Chapter 4 – validates all CGMA input data, contributes the substitution data if necessary (via
1708 the verification platform which is the ultimate source for these data), and gathers the various
1709 indicators (KPIs) also described in Chapter 4 and the CGMA IT specs. The web-based user
1710 portal makes it possible for alignment agents to actually use the CGMA application. Finally, the
1711 CGMA system needs a storage module that provides a file system and relational database.


1712
1713 Anyone interested in learning more about the different modules should refer to the detailed
1714 explanations in the CGMA IT specs.

1715
1716 Chapter 03 of the CGMA IT specs sets out the requirements with respect to hosting. These
1717 should be read in conjunction with additional and more detailed requirements described in the
1718 annex of the "Minimum Viable Solution Agreement" which, at the time at which the present
1719 document was being prepared, was the principal contract describing the cooperation of ENTSO-
1720 E and TSOs in setting up the OPDE and associated IT infrastructure. The hosting requirements
1721 include, inter alia, a description of the types and number of servers to be provided by the hosting
1722 entity. In addition to the hardware requirements, the functionalities required are outlined.

1723
1724 The description of the CGMA business processes in chapter 04 of the CGMA IT specs is largely
1725 equivalent to the description in the corresponding chapter in the present document. However,
1726 the description in the CGMA IT specs is limited to the (D-2) time frame, whereas the present
1727 document covers all time frames for which the CGMA process is used; i.e., all time frames for
1728 which market schedules are not available.

1729
1730 External data exchange - i.e., the exchange of data between the CGMA IT platform on one end
1731 and TSOs or external OPDE applications such as the PEVf on the other end - is covered in
1732 chapter 05 of the CGMA IT specs. The CGMA IT platform makes use of four different
1733 document types maintained by ENTSO-E WG EDI (plus Common Grid Model Exchange
1734 Standard (CGMES) files) in order to enable the data exchanges required. These data exchanges
1735 are represented for the (D-2) case in the sequence diagram in Figure 9:

1736



1737

1738 Figure 9: CGMA external data exchanges (D-2) excluding DC PSLC sub-process

1739

1740 For each of the data exchanges numbered 1 to 9 above, the CGMA IT specs state the associated
1741 document type and, for each type, the recommended (non-mandatory) file naming convention.

1742

1743 Three application interfaces to and / or from external systems are depicted in the above diagram.
1744 Optional data flows are represented by dotted lines. First of all, there is a bilateral connection
1745 with individual TSOs. This connection is used to send PPD from the TSO to the CGMA IT
1746 platform whereas the CGMA IT platform sends the CGMA output data (results) and error or
1747 status messages the other way. The data format used is explained in more detail in Annex IV.
1748 The same format is used for providing input data to the CGMA IT platform and for sending
1749 CGMA output data back (Reporting Information Market Document). Acknowledgement
1750 messages have a format of their own. All of these data are exchanged via the OPDE and
1751 delivered automatically.

1752

1753 The exchange of data with the Quality Portal is unilateral in the sense that the CGMA IT
1754 platform provides data to the Quality Portal but not conversely. The data being exchanged are
1755 the optimisation results. A CIM-based format, the Reporting Information Market Document
1756 (RIMD), will be used to transfer the CGMA output (i.e., the results of the optimisation) via the
1757 OPDE and automatic delivery.

1758

1759 Data exchange with the Verification Platform (PEVF) is bilateral (i.e., two-way). The CGMA
1760 system obtains substitution data (in the form of (D-1) matched schedules provided by the
1761 Verification Platform) from the OPDE using the CIM RIMD format. Data may be provided via
1762 automatic daily delivery or upon request by the CGMA platform.

1763

1764 Chapter 05 of the CGMA IT specs also references an additional document, the CGMA Data
1765 Exchanges Implementation Guide, as well as an associated set of XML schema definition files
1766 (XSDs) available from the WG EDI page on the ENTSO-E website. A summary of the CGMA
1767 Data Exchanges Implementation Guide is provided below. The XSDs and the information
1768 contained in the CGMA Data Exchanges Implementation Guide are very important for vendors
1769 working to adapt TSO systems such that these are able to communicate with the CGMA IT
1770 platform.

1771

1772 Chapter 06 of the CGMA IT specs on data storage provides details on the CGMA IT platform's
1773 database, more specifically on each of the tables in the data model (see diagram of the CGMA
1774 data model in the CGMA IT specs; the diagram is not included in the present document).
1775 Internal data storage and internal archiving arrangements as well as the possible use of OPDM
1776 data stores are also described in the chapter.

1777

1778 The (initial) master data used are listed in chapter 07. There is some overlap between these data
1779 and information included in the present document; where this duplication exists it is deliberate.
1780 For example, the list of optimisation areas is included both in the CGMA IT specs and in the
1781 present CGMAM. With two exceptions there is a one-to-one mapping between optimisation
1782 areas and TSOs - the exception being Eirgrid and SONI (two TSOs who will jointly provide one
1783 IGM and thus one set of PPD for the CGMA process) and Energinet.dk (which, as a single
1784 TSO, will be managing the two optimisation areas of DK1 / Denmark-West and DK2 /
1785 Denmark-East each of which will be providing a separate IGM and thus a separate set of PPD
1786 to the CGMA process). Noting the two exceptions, the CGMA IT specs provide the list of TSOs
1787 whereas the CGMAM provides the list of optimisation areas.

1788

1789 The CGMA IT specs, in addition, also list the Alignment Agents and the TSOs preliminarily
1790 associated with each of them. The present CGMAM only assigns Alignment Agents to a TSO
1791 where the appointment has been explicitly confirmed.

1792

1793 For those master data included both in the present document and the CGMA IT specs, there are
1794 some differences in the details provided. For example, the CGMA IT specs contain, for each
1795 optimisation area, both the EIC for the area and the EIC for the associated TSO whereas these
1796 data are not felt to be relevant for the CGMAM. Both documents contain a list of individual DC
1797 lines included in the CGMA algorithm; the CGMA IT specs also include the corresponding EIC
1798 code and the linear factor in the losses polynomial (which can be specified separately for each
1799 DC line).

1800

1801 Understanding the meaning of the detailed master data related to DC lines and the discussion
1802 thereof in the CGMA IT specs requires a good grasp of the underlying conceptual questions.
1803 The CGMAM provides these explanations in chapter 03 on the CGMA algorithm.

1804

1805 Both the CGMA IT specs and the present CGMAM include information on the DC and virtual
1806 AC links in the form of a stylized map of the European grid. These maps are equivalent.

1807

1808 Chapter 07 of the CGMA IT specs also includes a list of the business types that are supported.
1809 Since some of these terms are equivalent but not identical to terms used in the present
1810 CGMAM, a correspondence table is included in the Glossary in Annex V.

1811

1812 The way that the algorithm described in chapter 3 of the present CGMAM has been
1813 implemented in the CGMA IT platform and transposed into the modelling language used by
1814 GAMS is described in chapter 08 of the CGMA IT specs. Terminology and symbols/notation
1815 used differ somewhat from those used in the present CGMAM; however, in terms of content
1816 there are no inconsistencies.

1817

1818 Chapter 09 of the CGMA IT specs covers the internal data exchange between the different
1819 modules of the CGMA IT platform and notably also describes a dedicated XML data format
1820 used for this purpose.

1821

1822 The interfaces of the CGMA IT platform are described in chapter 10 of the CGMA IT specs.
1823 The first section addresses internal interfaces and the various web service operations provided
1824 for these internal exchanges. External interfaces (specifically those between the CGMA IT
1825 platform on one end and the PEVF or QAS - both modules hosted on the OPDE - on the other
1826 end) are addressed in the second section. That section describes the specific adjustments
1827 required in order to allow the CGMA IT platform to exchange data with these other two
1828 applications. For example, the PEVF will not be able to provide aggregate AC and DC net
1829 positions because such a time series does not exist. The CGMA IT platform will therefore have
1830 to compute the aggregate values from the separate values for the AC net position and DC flows
1831 provided by the PEVF. The third and final section of that chapter addresses message exchange
1832 via the OPDE. It describes the preparations that the hosting entity has to complete in order to
1833 allow the CGMA IT platform to communicate via the ATOM network and it outlines the
1834 "receive" and "send" operations available as well as the EDX businessTypes associated with
1835 each of the four WG-EDI-maintained document types.

1836

1837 Chapter 11 on the Quality Gate describes in detail the various checks performed by the CGMA
1838 IT platform in order to ensure that the input data used meet the requirements. These checks are
1839 referred to in the description of the various process steps in chapter 4 of the present document.
1840 Chapter 11 of the CGMA IT specs also covers the subjects of substitution and modification,
1841 respectively, of input data which includes, for example, the rules applied by the CGMA IT
1842 platform in order to ensure that inadequate feasibility ranges are increased. As chapter 4 would
1843 suggest, the checks described in the CGMA IT specs can be grouped into (A) checks on
1844 individual TSO PPD: A1 syntax check; A2 semantic check; and (B) checks on the complete set
1845 of PPD in order to check consistency of, inter alia, data related to DC lines.

1846

1847 As there was very considerable overlap between the contents of chapter 12 of the CGMA IT
1848 specs and the previous chapter 5 on "Key performance and quality indicators" in the present
1849 CGMAM, the latter chapter was essentially removed. However, these indicators are described in
1850 detail in the CGMA IT specs.

1851

1852 Chapter 13 of the CGMA IT specs describes the web portal which allows the Alignment Agents
1853 to actually use the CGMA IT platform. Aside from pure administration tasks such as the
1854 management of the master data this chapter also explains how the web portal will make it
1855 possible for Alignment Agents to perform the tasks also described in the present CGMAM such
1856 as the manual modification of input data (including as part of the AQMP), the manual triggering
1857 of optimisation runs, or the review and exporting of data on performance indicators.

1858

1859 Chapter 14 concludes by summarising all requirements into a single chapter in the form of a
1860 table.

1861

1862 This completes the summary of the CGMA IT specs.

1863

1864

1865 **6.3 Summary of CGMA Data Exchanges Implementation Guide**

1866

1867 The CGMA Data Exchanges Implementation Guide was prepared by ENTSO-E WG EDI on
1868 behalf of the CGMA project. The Implementation Guide follows a standard format / outline for
1869 such documents and provides a description of the CGMA business processes and document
1870 exchange processes as well as general rules for document exchange. While the other three
1871 formats used for CGMA-related data exchanges - the Acknowledgement Market Document, the
1872 Problem Statement Market Document, and the Status Request Market Document - are not
1873 modified for the specific CGMA use cases, this is different for the fourth format, the Reporting
1874 Information Market Document (RIMD). The Implementation Guide therefore provides detailed
1875 information on how the RIMD format is to be used in the context of the CGMA process. This
1876 information is highly technical and would be very useful for, inter alia, a vendor supporting a
1877 TSO in setting up the CGMA process and data exchanges. The EDI Library on the ENTSO-E
1878 website provides detailed information on the RIMD as well as associated XSDs (see
1879 [https://www.entsoe.eu/Documents/EDI/Library/cim_based/schema/Reporting%20information%
1880 20document%20and%20schema%20v1.pdf](https://www.entsoe.eu/Documents/EDI/Library/cim_based/schema/Reporting%20information%20document%20and%20schema%20v1.pdf)).

1881

1882

1883

Annex

1884

1885 I. ANNEX – Test Results

1886

1887 The CGMA algorithm described in Chapter 3 of the present document is not based on
1888 theoretical considerations alone. In fact, the algorithm was developed over a period of about two
1889 years and was rigorously tested against data at every step of its development. The tests
1890 themselves have evolved in parallel with the algorithm and have gone through a number of
1891 versions. The two most recent series of tests, referred to as “CGMA Testing 2017”, included
1892 both challenges deliberately designed to (stress-) test the algorithm for robustness and realistic
1893 test scenarios. More specifically, TSOs were invited to provide "real" input data (i.e., PPD) in
1894 order to make it possible to test the performance of the algorithm against the sort of challenges
1895 expected to be encountered in daily operation²².

1896

1897 Both the robustness checks and the tests against regular data were successful. No problems with
1898 the algorithm were identified. The minimum feasibility range of 2 % of instantaneous peak load
1899 was shown to be generally sufficient to ensure the existence of a solution. In those instances in
1900 which the feasibility range provided was not sufficient, the algorithm managed to find a solution
1901 based on the approach outlined at the end of Chapter 3 ("Applying the algorithm: Step 3 –
1902 scenarios without solutions"). In summary, these test results were very encouraging and suggest
1903 that the CGMA algorithm will perform very well.

1904

1905 Even though the tests thus far have not identified any shortcomings, a parallel run of the CGMA
1906 algorithm and CGMA process is scheduled to start in January 2018. This parallel run is
1907 basically a long-term test under highly realistic conditions. It will provide the definitive
1908 reassurance that the CGMA algorithm can successfully handle all the challenges that arise in
1909 daily operations.

1910

1911

²² All test results from 2015 onwards can be found at: <https://extra.entsoe.eu/SOC/IT/SitePages/WP-5%20Common%20Grid%20Model%20Alignment.aspx>

However, please note that TSO-individual results are only made available to the corresponding TSOs and that individuals not associated with an ENTSO-E member organisation will not be provided with access rights.

1912 II. ANNEX - Coordinated Pre-processing Approaches

1913

1914 The present annex serves to outline four coordinated pre-processing strategies currently under
1915 development by designated alignment agents. The first, referred to as "INPROVE"
1916 (Identification of Net Positions Representative of the OVERall Electrical evolution), is being
1917 developed by Coreso. The second contribution – which encompasses several methodological
1918 approaches – is being developed by the Nordic RSC. The third contribution outlines the
1919 approach envisaged in the Baltic RSC. The fourth contribution outlines the approach being
1920 developed by SCC.

1921

1922 Note that the development of pre-processing approaches is at a very early stage and that
1923 additional attempts are under way to develop suitable strategies in this respect. In particular, it is
1924 also too early to say what exactly these strategies will aim at. However, this should become
1925 progressively clearer based on the parallel run in 2018.

1926

1927 Before presenting this material in detail, a reminder of the rationale for such coordinated pre-
1928 processing approaches is helpful. Holding everything else constant, the difficulty of finding
1929 balanced net positions and balanced flows on DC lines increases in proportion to the
1930 "preliminary net position across all bidding zones" (illustrated, for example, in Figure 2). The
1931 "preliminary net position across all bidding zones" is simply the sum of individual preliminary
1932 net positions. As such it is a measure of the aggregate forecast error – "error" because in
1933 equilibrium, exports have to exactly equal imports and the net position across all bidding zones
1934 has to be zero.

1935

1936 In order to obtain the balanced net positions needed for the subsequent stages of the CGM
1937 process, the CGMA algorithm has to redistribute the "preliminary net position across all bidding
1938 zones" (the aggregate forecast error) across bidding zones (ideally respecting the feasibility
1939 ranges set by each TSO). In other words, the preliminary net positions have to be adjusted until,
1940 post-adjustment, they sum to zero (at which point they are referred to as balanced net positions).

1941

1942 It is intuitively plausible that the latter task is much easier when the volume of redistribution
1943 required (i.e., the aggregate forecast error) is 500 MW rather than, say, 5000 MW. The
1944 coordinated pre-processing strategies outlined in this chapter aim at precisely this reduction in
1945 the size of the adjustment required. Under a coordinated (regional) approach, several individual
1946 preliminary net positions are forecast jointly, and, if the technique works as intended, the sum of
1947 the individual preliminary net positions estimated in this way is smaller (in absolute terms) than
1948 if the preliminary net positions had been estimated by each TSO individually. Note that this
1949 does not entail reducing the absolute size of each individual preliminary net position; it is the
1950 aggregate that matters from the point of view of the overall CGMA process.

1951

1952 Finally, note that the strategies outlined below are still under active development. In that sense
1953 the material presented here provides a snapshot of the current state of development and does not
1954 purport to be definitive.

1955

1956 **II (i) Pre-processing approach of CORESO**

1957

Coordinated pre-processing approach under investigation by Central European TSOs

iNProve: Identification of Net Positions Representative of the Overall Electrical evolution

(contribution kindly provided by Coreso)

1958

1959

1960 General Principles

1961

1962 The regional statistical approach intends to build a coordinated forecast of net positions for a set
1963 of bidding zones located in the same “electrical region” of the system (like capacity calculation
1964 regions (Core, CSE, SWE, etc. ...)), or the entire Continental Europe synchronous area. This
1965 approach consists of establishing a linear relationship between net position(s) and a set of input
1966 variables representative of the situation of the electrical market and the electrical grid in the
1967 chosen market area as well as neighbouring bidding zones. Coefficients of the linear models are
1968 trained and fitted by learning on past realisations or forecasts of these variables. At the time of
1969 writing the regional statistical approach was solely focused on the former CWE CCR.

1970

1971

1972 Choice of input data

1973

1974 Data analysis

1975 The more relevant the information provided to the forecasting models, the better the quality of
1976 the forecast. In order to guide the choice of input data, an analysis was conducted in order to
1977 identify the possible links between the net position of different bidding zones and different
1978 types of input data

1979 A data analysis made on past market realisations showed that:

- 1980 - Net positions of certain bidding zones are strongly correlated with net positions of other
1981 bidding zones (when Germany exports, clear tendency of import in Switzerland,
1982 Austria, and France)
- 1983 - The net position of a particular bidding zone is highly correlated with the net position of
1984 this same bidding zone during the preceding hour.

1985 This indicates that feeding the forecasting engine with past market realisations already provides
1986 a significant and relevant amount of information for the forecast.

1987

1988 Further analysis also using data on load, renewable infeed and cumulated unavailability of
1989 generation units showed that for certain bidding zones, these types of data were particularly
1990 relevant (for small electrical countries like Belgium, the unavailability of production, the load
1991 for thermo-sensitive countries like France, or renewable infeed for Germany or Spain and
1992 Portugal).

1993

1994

1995 Input data for the forecasting models

1996

1997 Two types of data were chosen as inputs:

1998 - Past commercial data: realised net positions of the entire Continental Europe
1999 synchronous area for the week preceding the target scenario (the time stamp for which
2000 preliminary net positions are being forecast)

2001 - Forecast of exogenous data such as load, must-run production and renewables infeed.

2002 For each type of data, not only values corresponding to the target bidding zone are provided but
2003 also values corresponding to neighbouring bidding zones (if not all European bidding zones).

2004 This has two advantages:

- 2005 • data collection, storage, and management for all individual forecasts can be centralised,
2006 and
- 2007 • the interdependencies between the different connected bidding zones can be captured to
2008 the maximum extent.

2009

2010 However, this also increases the number of input variables and the volume of data.

2011

2012 Output Data (hourly resolution)

2013

2014 - (Aggregate AC/DC) Net position per bidding zone

2015

2016 - DC flows per interconnector

2017 The approach of net position forecasting is easily extensible to different timeframes, or
2018 regions. The target net position can correspond to the full aggregate AC/DC net position of
2019 a bidding zone (considering all borders) or to aggregation in a specific capacity calculation
2020 region.

2021 For example, the two following models could be built for the net position of Germany: one
2022 considering only the borders with France and Benelux (CWE), and another model taking
2023 into account the borders with France, Benelux, Denmark, Poland, the Czech Republic,
2024 Austria, and Switzerland; i.e., all of Germany's relevant electrical borders.

2025

2026 The DC flow per interconnector can be predicted using the same methodology. For this
2027 forecast, the availability and capacity of the link will be key input data.

2028

2029

2030 Learning market behaviour or market tendencies through history

2031

2032 Structure of the forecasting models

2033 The statistical approach tries to learn and reproduce the market behaviour within a region of the

2034 system. During learning, the forecasting engine identifies correlations between the net position

2035 and the set of input variables in the history, and determines appropriate weights and coefficients

2036 for each of the relevant predictors to be applied for forecasting future values of the net position.

2037

2038 The final forecasting model is a linear function with adapted weights on each of the input

2039 variables considered relevant during learning.

2040

2041 Implicit or explicit coupling of net positions

2042 The past market outcomes based on which the forecasting model learns are coupled: the sum of

2043 past hourly net positions of the bidding zones participating in the Continental Europe

2044 synchronous area equals zero.

2045 The forecasted net positions can be pre-coupled (implicit condition in the input variables of a

2046 single-component linear model) or exactly coupled (explicit condition in a multi-component

2047 linear model)

2048

2049 Workflow for daily forecasting.

2050 Once the model has been trained on historical data, forecasts can be made for future target dates.

2051 In the target workflow, every day the latest market results as well as the most recent forecasts

2052 are added to the data available to the forecasting model. The forecast can then be made by


2053 applying the linear function to the provided input data.

2054 Every day, models could be also re-trained with the last day of observations. However, as the

2055 structure of the market is not expected to change drastically from one day to the next, the

2056 coefficients of the models should be stable over a certain period of time. Thus, re-training

2057 should be performed less frequently than every day; e.g., every two or three months.



2058 Figure 10: Retraining frequency (illustration)

2059

2060

2061

2062

2063 Data Analysis

2064

2065 The correlation coefficient between two variables measures the intensity of the numerical and
2066 statistical link between these variables. It does not prove a cause-and-effect relationship,
2067 however it indicates tendencies in a dataset. This value consists of the ratio between the co-
2068 variance between the two variables divided by the product of the standard deviations:

$$Cor(X, Y) = \frac{Cov(X, Y)}{\sigma_X \sigma_Y}$$

2069

2070 The coefficient value is between -1 and 1. If close to 1, the two variables tend to be strongly
2071 linked. If the value is close to -1, the variables are also strongly linked but in opposite ways. If
2072 close to zero, the variables tend to have no relation.

2073

2074 NP autocorrelation

2075 This study has no clear-cut conclusions except that the correlations between different bidding
2076 zones' net positions are limited, such that it is difficult to forecast one net position based upon
2077 the net position of another bidding zone.

2078

2079

2080 Hourly coefficient correlation

2081 This study had the following objective: separate the different hours of the days into several
2082 groups, to have a specific model depending on the period of the day. The analysis showed a
2083 strong correlation between hours during the day and hours at night in general.

2084

2085 NP vs. load correlation

2086 Load is one of the (largely) exogenous variables the correlation of which with net positions was
2087 studied. Clearly, as suggested by intuition, load is highly correlated with net positions.

2088

2089

2090 NP vs. renewable correlation

2091

2092 Wind forecast

2093 The correlation between the forecast wind infeed in Germany and European net positions is as
2094 one would expect, and there is a very high correlation between the forecast wind infeed in Spain
2095 and Portugal with these bidding zones' own net positions.

2096

2097 Solar forecast

2098

2099 As solar power is less important in Europe than wind power, the correlation is less strong, but
2100 we observe that for some countries like Germany, Italy or Switzerland, this variable is
2101 important.

2102

2103 NP vs. unavailability of production units

2104 Clearly, unavailability of production units has a high impact in net positions. And beyond the
 2105 intuitive impact on small countries like Belgium, we have other countries like Germany for
 2106 which this variable is important.

2107

2108 Basic description of the mathematics structure of the forecasting models

2109

2110 The approach consists of a penalized linear regression after a variable selection, to model the
 2111 behaviour of net positions from input data, based on previous months or years.

2112

2113 The mathematical principles of statistical algorithms used are based on:


- 2114 - An historical period of realized net positions
- 2115 - An historical period of variables that can be used to forecast net positions: previous net
 2116 positions, forecast data such as wind infeed, solar infeed, load, generation...
- 2117 - A linear algorithm

2118

2119 ⇒ The linear algorithm will model the linear relationship between the variables and the
 2120 realized net positions, by minimizing the error between the model and the target.

2121 ⇒ Finally, the result is a linear formula $\sum(A_i \cdot X_i)$ with X_i variables and A_i coefficients,
 2122 that represents in the best way the historical relationship between the net position and
 2123 the input variables.

2124 Errors out of range $[-\epsilon, \epsilon]$ are highly penalized.



2125

2126 Figure 11: Principle of the Support Vector Machine (SVM) algorithm

2127 In the figure above, it leads to penalize the regression with the sum of distances of exterior
 2128 points to a regression range (penalized term by the C factor). The introduced penalization makes
 2129 the regression particularly robust and provides especially a strong resilience to correlation issues
 2130 between regressors and a good stability to the problem dimension. This property is in particular
 2131 interesting in a context of net positions modelization since we use numerous regressors, strongly
 2132 correlated.

2133

2134

2135 **II (ii) Pre-processing approach of Nordic RSC**

2136

Coordinated pre-processing approaches under investigation by the Nordic TSOs

(contribution kindly provided by the Nordic RSC)

2137

2138

2139 **Disclaimer**

2140 *This section presents preliminary results of common Nordic work on determination of net*
2141 *positions for the D-2 process as required by Regulation (EU) 2015/1222. The objective of this*
2142 *document is mutual information between TSOs on approach and algorithm. Work is still*
2143 *ongoing and the approach may be modified or completely changed. This document does not in*
2144 *any way constrain the Nordic TSOs in their final approach to provide input to the CGMA*
2145 *algorithm.*

2146

2147

2148 **(1) Introduction**

2149

2150 The All TSOs' Proposal for a Common Grid Model Methodology of May 2016 requires the
2151 TSOs to provide their preliminary net positions to the CGM Alignment (CGMA) procedure.
2152 The input to this procedure will be preliminary net positions and DC flows from the individual
2153 TSOs.

2154

2155 The Nordic TSOs are of the opinion that their net positions are closely related, and that they
2156 preferably should be determined in one comprehensive procedure. Initially the following
2157 approaches were discussed:

2158

- 2159 • Reference Day
- 2160 • Regression against a number of relevant variables
- 2161 • Similar Net Demand
- 2162 • Euphemia based

2163

2164 The Reference day approach is the base line against which the other approaches will be
2165 evaluated.

2166

2167 Regression based approaches were seen as quite relevant, but also requiring significant effort to
2168 develop to a satisfactory level.

2169

2170 Instead, a rather simple method, Net Demand Similarity, was developed and compared with the
2171 Reference Day approach. It turned out that the proposed approach in fact leads to a significant
2172 improvement in the estimated net positions.

2173

2174 The Euphemia based approach was tested on historical data in a master's thesis that presently is
2175 being finalized. Results so far also are promising as a "proof of concept".

2176

2177 This section describes the Similar Net Demand approach in the following sub-section. In the
2178 subsequent sub-section initial test results using historical data from 2015 are presented. The
2179 following sub-section describes various potential improvements that were tested, but did not
2180 lead to better results. It was nevertheless seen as useful to include this as documentation. The
2181 last-but-one sub-section describes the Euphemia based approach, while the final sub-section
2182 concludes and sums up further work envisaged by the Nordic TSOs.

2183

2184 (2) Net Demand Similarity: the method

2185

2186 The method is based on estimating "net demand", given by the difference between the forecasts
2187 of demand and of non-dispatchable generation²³. This difference must either be produced within
2188 the area by dispatchable generation, or imported, respectively exported if negative. The idea is
2189 then to find "similar hours" with respect to net demand in recent history. "Similar" is based on a
2190 sum of least squares of the deviations. The hypothesis is that hours with similar net demand for
2191 all areas, also would have similar net positions.

2192

2193 Historical hours should not be taken too far in the past, as the water values (and prices in
2194 general) change over time, altering the patterns of dispatchable generation. On the other hand,
2195 taking too few hours in the past gives only a limited statistical basis and reduces the likelihood
2196 of finding comparable cases.

2197

2198 **Basic approach**

2199

2200 The approach is as follows:

2201

2202 1) Calculate net demand for all areas and all hours for target day

2203

$$2204 \quad DN_{i,t}^{target} = D_{i,t}^{target} - PNC_{i,t}^{target} \quad (0)$$

2205

2206 where D^{target} is the demand forecast for the target day, PNC^{target} the sum of the non-controllable
2207 generation, and i and t indices for area (bidding zone) and hour respectively.

2208

2209 "Net demand" may be negative, indicating an area where non-controllable generation exceeds
2210 demand.

2211

2212 2) Determine reference hours

²³ One might think of intermittent renewable energy, but the scope may be wider. The important point is to include generation that will not be influenced by prices within the time horizon of the analysis. In this context, nuclear is also seen as non-dispatchable.

2213 For a historical period before the present day, find one or several combinations of net demand in
 2214 all areas that matches the combination of net demand for the target day as closely as possible. In
 2215 order to find the best matches, calculate the deviation with the net demand of the forecast target
 2216 hour for all areas and each hour of the historical period:

2217

$$\alpha_{t,s} = \sum_{i \in A} w_i \cdot (DN_{i,t}^{target} - DN_{i,s})^2 \quad (0)$$

2218

2219

2220 where s is the index of an hour in the selected historical period. w_i is a suitable weighting factor
 2221 representing the size of the area.

2222

2223 We then choose a number of hours that have the lowest $\alpha_{t,x}$ and use these as the reference hours:

2224

$$s_{t,ref} = \underset{s}{\operatorname{argmin}} \alpha_{t,s} \quad (0)$$

2225

2226

2227 3) Determine net positions

2228 The net positions are taken as the average net positions of each area in the identified reference
 2229 hours, i.e. the n hours with lowest $\alpha_{t,s}$.

2230

2231 The net positions must be checked against and possibly constrained by the possible range of net
 2232 positions, determined by the forecast physical interconnection capacities and available
 2233 generation capacity. Note that this does not interfere with the ultimate goal of the whole
 2234 process, i.e. to determine the trading capacities, as the physical capacities in any case will be the
 2235 upper limit to the trading capacities.

2236

2237 The opposite problem occurs if the reference hour is more constrained. E.g. area x has a
 2238 maximum net position +1000 MW in the reference hours, and the actual net position in that
 2239 hour is equal to this value, but the maximum physical net position in this hour is 2000 MW.
 2240 This might for example happen when the reference hours occurred during a long maintenance
 2241 period. In such cases, the net position could have been higher in that hour if the maximum value
 2242 would have been higher.

2243

2244 These issues will be further discussed below

2245

2246 Calculation of flows

2247 Flows between bidding zones are of interest for two reasons:

2248

2249

1) An estimation of the DC flows between synchronous areas is a requirement of the
 CGMA methodology

2250

2251

2) On the borders between IGMs, injections are needed for each interconnection in order
 to represent import/export to neighbouring countries.

2252

2253 Although the AC injections may be obtained by other means, the present approach could be
 2254 used if it yields good results.

2255

2256 For this purpose, the algorithm was extended in order to find the flows. Firstly, an external area
 2257 was added. The net position of each area then includes the flow to the external area. After the
 2258 estimation of the net positions as described in the previous section, the flows are estimated by
 2259 solving for each time step t the optimization problem:

2260

2261

$$\min_{\mathbf{y}_t} \sum_i (a_i y_{i,t}^2 + b_i |y_{i,t}|)^2$$

subject to

$$\mathbf{A}\mathbf{y}_t = \mathbf{PN}_t \quad \forall i$$

$$lb_{i,t} \leq y_{i,t} \leq ub_{i,t} \quad \forall i$$

2262

2263

2264 Here \mathbf{y}_t is the vector of the flows to be found at time t , \mathbf{PN}_t is the vector of the net positions
 2265 found for time t and \mathbf{A} is the matrix that defines the couplings between the bidding zones.
 2266 Moreover, lb_{it} and ub_{it} are the lower and upper flow limits on the interconnections. By
 2267 minimizing the flows, loop flows are avoided in this formulation. \mathbf{a} and \mathbf{b} are vectors of suitable
 2268 weights.

2269

2270 The optimization thus solves a minimum-cost-of-flow problem that satisfies the net positions
 2271 and avoids loop flows. A similar problem is used by Nordpool to calculate the market flows.
 2272 Main focus is on the calculation of the DC flows, as these are required by the CGMA algorithm.
 2273 In addition, it is necessary to split up the external (HVDC) flow from SE4 into flows to
 2274 Germany, Poland and the Baltics. A simple approach is to use the ratios between these flows in
 2275 the same reference hours as a basis to distribute the total flow.

2276

2277 (3) Initial results on net positions

2278

2279 **Case description and assumptions**

2280 The approach was tested on data for 2015. The following historical data are required for all
 2281 Nordic bidding zones and all hours:

2282

- 2283 • Demand forecasts
- 2284 • Forecasts of non-controllable generation
- 2285 • Historical net positions
- 2286 • Physical import and export capacities

2287

2288 As several of the required D-2 forecasts are presently not available, the tests use the real or
 2289 market data instead of forecasts, i.e. "perfect foresight". Note that the market data are used, not
 2290 metered data. Use of forecasts will reduce the quality of the results, but the market result is
 2291 based on the market participants' forecasts, and this may reduce the deteriorating effect of using
 2292 forecasts instead of market results in the algorithm. This needs to be tested once such data
 2293 become available.

2294

2295 Net positions are calculated from the difference between total export and total import for each
2296 bidding zone, taken from the Nordpool web site.

2297

2298 For "non-controllable generation", only wind production was included initially, while nuclear
2299 production was added subsequently. Solar PV was not considered significant yet. The Nordic
2300 system also includes significant volumes of non-controllable hydro generation. However, little
2301 or no data on this are available. It is a complicated issue, as the extent to which hydro generation
2302 is controllable is highly dependent on the reservoir and inflow situation. Preparing forecasts for
2303 this is an area for potential future improvement of the methodology.

2304

2305 The algorithm uses bidding zones, even though the input to the CGMA algorithm will be on a
2306 country basis. There are two reasons for this:

- 2307 • The bidding zone results may subsequently be used as a basis for use of the GSKs
2308 within each bidding zone instead of country-wide
- 2309 • The bidding zone errors are not fully correlated, and the hypothesis is thus that adding
2310 the results for the bidding zones gives a better result than estimating the country net
2311 position directly. This hypothesis needs to be tested.

2312

2313 To document the quality of the results, the main indicator used is the Mean Absolute Error,
2314 defined as:

2315

$$MAE = \frac{\sum_{i=1}^n |NP_{est} - NP_{real}|}{n}$$

2316

2317

2318 **Results net positions**

2319 The results are shown in the table below. The results are compared with an approach where the
2320 net positions are copied from a reference day²⁴.

2321

2322

²⁴ Tuesday-Friday: the day before. Monday: Friday. Saturday and Sunday: same day one week earlier.

2323

Bidding Zone	MAE (MWh/h)		Improvement (%)	MAE (% of Mean Absolute Net Position – MAN)		MAN (MWh/h)
	Net Demand Similarity	Reference Day		Net Demand Similarity	Reference Day	
SE1	282	327	14 %	20	23	1440
SE2	326	439	26 %	9	12	3585
SE3	329	587	44 %	26	46	1282
SE4	175	323	46 %	10	18	1789
NO1	174	189	8 %	10	10	1824
NO2	409	630	35 %	19	30	2100
NO3	151	204	26 %	19	26	799
NO4	158	258	39 %	29	48	542
NO5	273	429	36 %	14	22	1952
FI	272	264	-3 %	17	17	1570
DK1	309	685	55 %	41	92	747
DK2	145	226	36 %	23	35	641

2324

2325

Table 2: Test case results, bidding zones

2326

2327

2328

Bidding Zone	MAE (MW)		Improvement (%)	MAE (% of Mean Absolute Net Position – MAN)		MAN (MW)
	Net Demand Similarity	Reference Day		Net Demand Similarity	Reference Day	
Denmark	381	867	56 %	33	74	1168
Finland	272	264	-3 %	17	17	1570
Norway	714	1273	44 %	30	54	2360
Sweden	588	830	29 %	22	31	2641

2329

2330

Table 3: Test case results, countries

2331

2332 The columns MAE (MW) show the average absolute deviation in MW between the estimated
2333 net position and the net position resulting from the market clearing for the Net Demand
2334 Similarity and the Reference Day approaches respectively. The next column shows the
2335 improvement in percent. The next two columns show the same deviations in percent of the
2336 mean average net position, indicating the relative error. These numbers should be handled with
2337 some care, because if the net positions normally are small or often have opposite signs, the
2338 relative error may be large, even though this may not be large e.g. compared with the total
2339 demand and/or production of the area. The last column shows the actual net positions, i.e. the
2340 reference for the percentages in the two columns before. All these net positions are rather high,
2341 so the percentages give a reasonable indication, but this can be problematic for shorter periods.
2342

2343 Compared with the reference day approach, significant improvement is obtained for SE3 and
2344 SE4 in Southern Sweden, NO2, NO4 and NO5 (West and Northern Norway) and the Danish
2345 bidding zones. SE3 and SE4 together with the Danish areas are the major wind areas, which is
2346 probably an important part of the explanation. The Norwegian areas are the most flexible hydro
2347 areas, which would react on the changes in wind production. Only for Finland, the proposed
2348 approach results in a slight deterioration.
2349

2350 On a country basis, the improvements for especially Denmark and Norway are impressive. The
2351 relative errors for these countries are still around 30 % of the average flows. It should however
2352 be taken into account that the maximum net positions of both Denmark and Norway are well
2353 above 6000 MW, and in this perspective the deviations look more acceptable.
2354

2355 As part of the test, the optimal length of the historical period and the number of reference hours
2356 were determined empirically. A longer historical period increases the probability of finding
2357 hours with similar net positions, but at the same time they become less representative because of
2358 changes in prices and water values. Similarly, having more reference hours smooths out special
2359 situations, but makes it necessary to include less representative hours. So for both parameters
2360 there will be an optimum number. In the present tests, the following parameters were used:
2361

2362 Historical period: 4 days back in time
2363 Number of reference hours: 2
2364

2365 The weighting factors w_i were all equal to 1.
2366
2367

2368 **Results net flows**

2369

2370 It appears possible to estimate the flows, initial results indicate MAEs of the order of 10 to 25 %
2371 of the cable capacities, cf. the table below.

2372

2373

Interconnection		MAE (MWh/h)	MAE (% of capacity)
NorNed	NO2-Netherlands	107	15
Skagerrak	NO2-DK1	163	10
Storebælt	DK1-DK2	111	19
Kontiskan	SE3-DK1	128	18
Fenno-Skan	SE3-Finland	207	17
Kontek	DK2-Germany	119	20
Baltic Cable	SE4-Germany	46	??
SwePol	SE4-Poland		
NordBalt	SE4-Lithuania	n/a	n/a
Estlink	Finland-Estonia	n/a	n/a

2374

2375 **Table 4: Test case results, HVDC flows**

2376

2377 (4) Potential improvements

2378

2379 **Historical period and number of hours**

2380 In the tests referred to above, the optimal number of historical days was found to be equal to
2381 four, and the number of reference hours used equal to two. Earlier tests on a country basis
2382 yielded a much longer period (13 days) and a larger number of hours (10). More testing is
2383 needed to find the optimal numbers. They might also be state dependent, e.g. during stable
2384 periods in winter a longer period may be better than during snow melting. The optimal numbers
2385 may also depend on some of the other options below.

2386

2387

2388 **Weighting factors**

2389 In the initial test case described above, the weights w_i for all bidding zones were all set equal to
2390 1. This means that the bidding zones with the largest exchange flows dominate the sum in
2391 Equation (0), which again might mean that areas with smaller exchange flows get relatively
2392 larger deviations. On the other hand, areas with large exchange flows are also the largest areas
2393 in terms of demand and/or production, and therefore dominate the Nordic exchange pattern
2394 overall. So it might be that when the net positions of these bidding zones are close to their
2395 correct values, the smaller areas follow. On the other hand, it might be that the influence of the
2396 areas with large exchange flows becomes too large, resulting in unacceptable deviations for the
2397 smaller areas.

2398

2399 An alternative calculation was therefore done with weighting factors equal to the inverse of the
2400 bidding zones' net average demand. This may be expected to change the results somewhat in
2401 favour of the smaller areas. An initial test confirmed this assumption, but gave slightly worse
2402 results on a country basis. This also needs to be tested more.

2403


2404 **Constraints on minimum and maximum net positions**

2405 In general, bidding zones' export and/or import is often constrained by physical limitations on
2406 their export respectively import capacities. Consequently, these limitations will also constrain
2407 maximum and minimum net positions of the bidding zones. However, it turns out that the
2408 relations between the limited import and export capacities on the one hand and the limitations
2409 on the bidding zones' net positions are not straightforward.

2410

2411 The obvious relations are given by the fact that a bidding zone's net position cannot be larger
2412 than the sum of the export capacities of its interconnections with other bidding zones, and not be
2413 less than the sum of the corresponding import capacities. However, for the Nordic system in
2414 2015 it turns out that these constraints are never binding. The figure below illustrates this for
2415 bidding zone SE1:

2416




2417

2418 Figure 12: Example of estimated (brown) and market (blue) flows and the minimum and maximum net positions for
2419 SE1.

2420

2421 This is also clearly illustrated in the next figure that shows the minimum and maximum net
2422 positions during 2015 for all Nordic bidding zones, as well as the physical maximum capacity in


2423 MW. Although the latter naturally varies somewhat during the year, it is obvious that the
 2424 physical maximum is seldom a binding constraint.
 2425



2426
 2427 Figure 13: Lowest and highest maximum positions in 2015 and physical maximum.

2428
 2429 The reason for this behaviour is that most bidding zones have a transit function in addition to
 2430 being dominated by import or export. When the maximum net position of a normally exporting
 2431 bidding zone is calculated, the export capacities of the normally importing lines are included,
 2432 even though they in reality do not contribute to the zone's export capacity. The maximum net
 2433 position will then not be a binding constraint in the net position estimation, even though the
 2434 capacities of the exporting lines in reality may constrain the maximum net position. The
 2435 situation is illustrated in the figure below:
 2436

2437



2438

2439

Figure 14: Bidding zone with transfer flow

2440

2441

2442

2443

2444

2445

2446

The bidding zone has a theoretical maximum net position of $700 + 1000 = 1700$ MW. Its actual net position is $1000 - 500 = 500$ MW, and the maximum net position is far from being a binding constraint. However, the capacity of the exporting line in reality probably limits the net position in the given situation (this is not certain, depending on the conditions for the import – reduced import also results in an increased net position).

2447

2448

2449

2450

2451

2452

2453

2454

It is not straightforward to constrain the net positions based on assumptions on transit. Firstly, most bidding zones have a somewhat dynamic behaviour, e.g. even if they are normally exporting, they may sometimes have net import, cf. the figure for SE2 above. It is also hard to know how to treat the transit flows. E.g. in the figure above, should the import be assumed to be always at least 500 or could it be reduced to zero, resulting in a maximum net position of 500 or 1000 MW respectively. Secondly, making assumptions on this to some extent pre-empts the capacity calculation itself, which should be avoided.

2455

2456

2457

2458

Several tests were done with various assumptions on the transit. However, this did not lead to a significant number of hours where the maximum or minimum net positions became constrained, and moreover it did not improve the overall results.

2459

2460

2461

2462

2463

2464

2465

2466


2467

However, the physical constraints of the interconnections obviously do have an impact on the maximum and minimum net positions. In periods where these capacities change frequently due to maintenance, including the impact of such changes could potentially improve the result. In addition to this, availability of generation capacity also constrains the possible net positions, and should be taken into account. This has not been considered and needs to be analysed in further work.

2468 **Inclusion of German net demand**

2469

2470 The total flow into or out of the Nordic area will be influenced by German renewable generation
 2471 or German net demand. An illustration is given in the figure below which depicts data for 2015.
 2472



2473

2474 Figure 15: Correlations between German renewable generation and Nordic net positions

2475

2476 The figure to some extent confirms the hypothesis, but is still ambiguous:

- 2477 • The Danish net position is normally positively correlated with German RE generation.
 2478 This is assumed to be caused by the positive correlation between Danish and German
 2479 wind generation.
- 2480 • Norwegian hydro production is negatively correlated with German RE production in
 2481 winter, but hardly at all during summer. The probable explanation is that the hydro
 2482 generation is the most flexible production in the area, and will react on changes in RE
 2483 production. However, in summer when there is much water in the reservoirs, hydro
 2484 generation is less flexible and more controlled by the hydrological situation. Moreover,
 2485 2015 was a very wet year.
- 2486 • The Swedish and Finnish patterns have less obvious explanations.


2487

2488 All in all, the Nordic net position clearly has a negative correlation with the German RE
 2489 production, and including this in the model might improve the results.

2490

2491 German net demand was therefore included in the sum (0), and different weighting factors were
 2492 tested. The following figure shows the change in result as a function of the weight of the
 2493 German net demand. A weight of zero corresponds to German net demand not being included.

2494 The numbers differ somewhat from those in , because the tests were done with slightly different
 2495 assumptions.
 2496



2497
 2498 Figure 16: Effect of including German net demand in the calculation of the sum of squared net demands
 2499

2500 The expected weight should be positive, i.e. the German net demand is used in a similar way as
 2501 the Nordic net demand in order to find the best reference hours. As could be expected, using a
 2502 negative weight gives significantly worse results. However, using a positive weight initially
 2503 does not have a large effect, though somewhat negative. For larger values, the effect becomes
 2504 increasingly negative.
 2505

2506 So far, a good explanation for this unexpected behaviour has not been found, and further testing
 2507 is needed.
 2508

2509
 2510 **Including only similar hours**

2511 The search for the best reference hours purely focuses on the best α 's in Equation (0) without
 2512 considering time of day. It might be that using only hours from a similar time of day could give
 2513 better results. A test was therefore done using weighting factors measuring the distance to the
 2514 actual hour of the day.

2515 It turned out that this did not improve the results. This might be because the selected days
 2516 mostly already were "similar", which was not verified.
 2517

2518
 2519


2520 **Distribution functions**

2521 Apart from the average errors, it is also of interest to look at the distribution of the errors. In
 2522 general a narrow distribution is preferable to a wide distribution, indicating that large errors
 2523 sometime occur.

2524

2525 A preliminary picture of the distribution of errors is show below.

2526



2527

2528 Figure 17: Preliminary distribution functions of the flow errors

2529

2530 The pictures suggest that the average errors are close to zero, indicating that the estimations
 2531 have the correct expectation. For many areas, the distribution function seems to resemble
 2532 normal distributions (to be verified), but this is clearly not the case for NO1, NO3, NO4 and
 2533 DK1.

2534

2535 The distribution functions are of particular interest when comparing different approaches, as
 2536 reducing the large errors is more important than minimizing the average error.

2537

2538

2539 (5) Euphemia based approach

2540

2541 **Description**


2542 The approach based on the Price Coupling of Regions (Euphemia) is based on the idea that on
 2543 D-2 (after the clearing of the market), the best available information for the business day D is
 2544 contained in the bid curves of the PXs for D-1. Of course, the market participants can change
 2545 their bids from D-1 to D, but such changes cannot reasonably be foreseen in any approach.
 2546 However, what changes and can be forecast is:

- 2547 • Inelastic (price insensitive) demand
- 2548 • RES production
- 2549 • Outages of network elements
- 2550 • Topology

2551 With access to the PXs' clearing function and the possibility to change these parameters, it is
 2552 then in principle possible to estimate new net positions.

2553
 2554
 2555
 2556
 2557

The principal shape of the bid and offer curves in each bidding zone is as shown in the figure below:



2558
 2559 Figure 18: Supply and demand curves for one area, original (to the left) and modified (to the right)

2560
 2561 The left hand panel shows assumed supply and demand curves for D-1 (or any other appropriate
 2562 reference), resulting in a particular market solution with a price and a cleared volume.
 2563 Importantly, the **brown** part of the supply curve represents renewable (or rather: non-
 2564 controllable) production, while the **red** part of the demand curve represents inelastic (non price-
 2565 sensitive) demand). These parts of the curves would in a perfect market not be influenced by
 2566 prices. The brown part of the supply curve should in theory lie at zero, but at least parts of it
 2567 may be assumed to be slightly positive due to e.g. maintenance costs.

2568
 2569 Assume that for the same hour of the business day D, the forecast of non-controllable power is
 2570 lower than for D-1. This shifts the whole supply curve to the left. Moreover, assume that
 2571 demand is higher than for D-1. This shifts the demand curve to the right. For the area in
 2572 consideration we get a new market balance with increased price and volume. In a market with
 2573 multiple zones, the result will naturally be influenced by the imports and exports between the
 2574 areas, but the principal shifts of the supply and demand curves are the same.

2575
 2576 So on D-2 forecasts must be prepared for:

- 2577 • non-controllable production
- 2578 • inelastic demand

2579 for each bidding zone.

2580

2581 Although the principle shown in Figure 18 is straight forward, there are challenges in practice:

2582


2583 *Which parts of the bid- and offer curves are determined by non-controllable generation and*
2584 *inelastic demand?*

2585

2586 As an example, the curves for Germany/Austria for 24.06.2014 are shown below:

2587

2588



2589

2590 Figure 19: Supply and demand curves German/Austria (source: EPEX)

2591

2592 Although the principal shapes from Figure 18 can be recognized, we observe among other
2593 features negative bids. The crucial question is, however, which part of these bid curves must be
2594 substituted with the RES and demand forecasts. A possible option is to base this on the forecast
2595 from the day before, but this needs to be further explored.

2596

2597 *How to set the exchange capacities in the market clearing?*

2598 To get reasonable net positions, realistic exchange capacities must be used in the market
2599 clearing. However, setting these capacities is the purpose of the D-2 calculations.

2600 Setting infinite capacities is not a solution: this will in many cases lead to net positions that are
2601 unrealistic.

2602

2603 For the *Flow Based* approach this is probably not problematic: the inputs to the FB algorithm
2604 are mainly physical limits of the interconnections and the Critical Network Elements (CNE). So

2605 changes in the availability of assets will mostly translate directly into the capacities of
 2606 interconnections and CNEs.

2607
 2608 For the *ATC* approach this is more challenging. Setting the capacities will to some extent pre-
 2609 determine the result. Still the TSOs have significant experience in how outages will affect the
 2610 interconnections. Moreover, the result is not final, but only establishes a base case from which
 2611 to calculate the final capacities. In any case this must be studied more closely if the *FB* approach
 2612 is not the final choice for the market clearing.

2613
 2614 *Handling of reservation of physical transmission capacity*
 2615 If physical reservations for bilateral trade are made this needs to be reflected correctly in the
 2616 calculations.

2617
 2618 **Preliminary results**
 2619 The preliminary results for the Euphemia based approach for 2015 are shown in , together with
 2620 the results for the other methods discussed in this section.

2621
 2622

	Euphemia	Net Demand Similarity	Reference Day
SE1	257	282	327
SE2	285	326	439
SE3	354	329	587
SE4	171	175	323
NO1	114	174	189
NO2	319	409	630
NO3	129	151	204
NO4	138	158	258
NO5	259	273	429
FI	201	272	264
DK1	244	309	685
DK2	93	145	226

2623
 2624 Table 5: Mean Average Error per bidding zone in MW for the Euphemia based approach, compared with alternatives

2625
 2626 The last two columns in the table are identical to those in . The country results are shown below.

2627
 2628

2629

	Euphemia	Net Demand Similarity	Reference Day
Denmark	278	381	867
Finland	201	272	264
Norway	539	714	1273
Sweden	512	588	830


2630

2631 Table 6: Mean Average Error per country in MW for the Euphemia based approach, compared with alternatives

2632

2633 All results are summed up in the following figure.

2634



2635

2636 Figure 20: Comparison of MAEs for three approaches

2637

2638 Preliminary conclusions:

- 2639 • The Euphemia based approach is better than the Net Demand Similarity approach for all
- 2640 bidding zones and countries, except SE3.
- 2641 • Improvements are significant for NO1, NO2 and the Danish bidding zones.

2642

2643 At the present stage, it is not obvious what is "good enough". This must be analysed further

2644 once the processes are up and running. It should also be noted that both approaches use perfect

2645 foresight forecasts, and that using real forecasts may worsen the results.

2646

2647 For the Euphemia based approach, it should further be considered that the need for alignment is
2648 reduced and may ultimately be avoided when more (all) involved countries are included, as the
2649 result of the market clearing already will be balanced.

2650

2651 (6) Conclusions and further work

2652

2653 The work done so far indicates that an approach based on finding recent hours with similar net
2654 demand results in preliminary net positions that are significantly closer to real values than a
2655 simple reference day approach for almost all Nordic bidding zones. This result is obtained with
2656 a conceptually simple algorithm that is easy to implement. As forecast data were not sufficiently
2657 available, real market results were used instead of forecasts, and this may have influenced the
2658 result in a positive direction. However, the project group does not think the effect should be
2659 very large, as also the market results are based on forecasts.

2660

2661 An additional simple algorithm for the estimation of the flows was also tested and initial results
2662 look somewhat promising. More analysis is however needed on the flows.

2663

2664 A number of potential improvements to the base algorithm were tested, but none of these so far
2665 gave better results.

2666

2667 In addition to the main analysis using the Net Demand Similarity methodology, an approach
2668 based on the use of Euphemia data was also tested in a master's thesis at NTNU in Trondheim,
2669 using the Euphemia Simulation Facility. This approach showed additional improvements,
2670 especially for Denmark and some of the Norwegian bidding zones. These are promising results,
2671 and the work that was done is certainly a proof of concept for this approach. It may be the best
2672 option for Europe in the long run. However, a number of hurdles must be passed before the
2673 Euphemia approach can be realized in practice.

2674

2675 At this stage of the implementation of the capacity calculation process, it is not possible to know
2676 what is required for the preliminary net positions to be "good enough", meaning that they
2677 provide a sufficient basis for capacity calculations. This must be tested thoroughly when all
2678 required procedures are established, and this may confirm that e.g. the Net Demand Similarity
2679 approach is good enough, or that improved methods need to be developed. The improvements
2680 obtained with the Net Demand Similarity approach certainly seem to be worth the rather limited
2681 additional efforts compared with the Reference Day approach.

2682

2683 Further work will include:

2684

- testing with forecast data instead of market results
- establishment of reasonable minimum and maximum values
- analysis of the variability of the results
- if possible a structured comparison of alternative approaches

2685

2686

2687

2688

2689 In the longer term, preparing forecasts of non-controllable hydro may have a potential of
2690 improving the results.

2691
2692
2693

II (iii) Pre-processing approach of Baltic RSC


Coordinated pre-processing approach under investigation by Baltic TSOs

(contribution kindly provided by the Baltic RSC)

2694
2695
2696
2697
2698
2699
2700
2701
2702
2703
2704

In providing pre-processing data to the CGMA process, the three TSOs of the Baltic region – Elering AS, Augstsprieguma tīkls AS, Litgrid AB – are planning to cooperate on a regional level. The process currently envisaged is summarised in the following Figure 21 which is explained in more detail below. Note that:

- This cooperation is building on the existing coordination of the forecasting of AC-only net positions, HVDC flows, consumption and production data. The objective is to follow existing processes as closely as possible so as to not set up parallel processes.
- This is an initial draft vision developed by Elering and a later detailed version may deviate from the description below.



2705
2706

Figure 21: Overview of pre-processing approach envisaged in Baltic region

2707
2708
2709
2710
2711
2712
2713
2714
2715
2716
2717
2718
2719

First, note that the pre-processing cooperation outlined above applies to those time frames for which the CGMA process is required; i.e., those time frames for which there are no market schedules (from (D-2) up to and including (Y-1)). The relevant market time unit is one hour; i.e., all data will be provided with a resolution of one hour. One abbreviation in the above figure that deserves to be explained is "ISEI" – this is a web portal for exchange planning data used by the BRELL organisation (BRELL: Belarus, Russia, Estonia, Latvia and Lithuania).

In step 1 of the process, each TSO provides schedules for a reference day (i.e., a day with characteristics similar to those expected for the relevant energy delivery day). The data provided include preliminary AC-only net positions and associated feasibility ranges as well as preliminary DC flow data including DC feasibility ranges. The schedules provided will be adjusted if congestion is expected (which will typically be driven by the outage of important

2720 cross-border connections including both HVDC links and AC tie lines). Where the HVDC flow
2721 forecasts from the Nordic region are not consistent with the initial forecasts, the latter may also
2722 be modified.

2723

2724 In step 2 of the process, the matched schedules for the (historic) reference day will be used as
2725 the basis of the forecast. If no congestion is expected they will be used without modification; if
2726 congestion is to be expected, for each time-stamp the congested border will be identified and
2727 HVDC and conventional production will be scaled until allowed cross-border flow at forecasted
2728 congestion is achieved. If an HVDC forecast from the Nordic region is available, the target day
2729 DC schedules will be replaced with the Nordic forecast. The pre-processing data based on the
2730 matched schedules are then uploaded to both the ISEI platform as well as the CGMA system via
2731 the OPDE.

2732

2733 In step 3 of the process (no longer part of the pre-processing phase), the CGMA output data are
2734 obtained from the CGMA system and the IGMs are built (or updated) based on these balanced
2735 net positions and balanced flows on DC lines. The IGMs are then uploaded to the OPDE in turn.

2736

2737

2738

2739 **II (iv) Pre-processing approach of SCC**

2740

Coordinated pre-processing approach under investigation by SEE TSOs

(contribution kindly provided by SCC)

2741

2742

2743 **1. The pre-processing phase of CGMA methodology for SEE region**

2744

2745 In the pre-processing phase of the CGMA process, coordination of TSOs that choose SCC as
2746 Alignment Agent (AA), is planned. Pre-processing data will be prepared using the same
2747 methodology for those TSOs that delegated this task to SCC. Pre-processing cooperation
2748 procedure will be applied to those time horizons for which there are no market schedules, from
2749 D-2 up to W-1.

2750

2751 Forecast will be performed separately per TSO, since it is very hard to detect high correlation
2752 between net positions of neighboring TSOs in SEE region. Input data for prediction of TSOs
2753 PNPs are: net positions, generation and load. Each type of data will be provided on hourly time
2754 resolution. Forecast of PNPs will be determined on the basis of historical data, realized in the
2755 past (minimum) two years for the corresponding timestamps.

2756 In the networks of TSOs that currently use SCC AA services, there are no HVDC links for now.
2757 HVDC link between CGES and TERNAL is under construction, but it will not be in operation for
2758 the next two or three years. Therefore, predictions of flows on HVDC links is out of scope for
2759 the time being.

2760

2761

2762 **2. SCC method for net position forecasting**

2763

2764 In contrast to the complex models, simple statistical method is proposed by SCC. The SCC
2765 method for forecasting PNPs is based on a pattern recognition and linear regression in the
2766 neighborhood of similar data. The number of parameters here is small and they can be estimated
2767 using simple least squares approach. The key element of the proposed method is data pre-
2768 processing – defining patterns of seasonal cycles. This simplifies the short-term net position
2769 forecast problem eliminating non-stationarity in mean and variance, and filtering out the trend
2770 and seasonal cycles on periods longer than the daily one.

2771

2772 The algorithm of the proposed pattern-based linear regression is presented and summarized in
2773 the following steps:

- 2774 1. Mapping the original time series elements to patterns \mathbf{x} and \mathbf{y} ;
 - 2775 2. Selection of the k nearest neighbors of the net position query pattern \mathbf{x}^* and creation of the
2776 training set Φ ;
 - 2777 3. Construction of the linear regression model M mapping $\mathbf{X}^\Phi \rightarrow Y_t^\Phi$ based on Φ ;
 - 2778 4. Determination of the forecasted \mathbf{y}^f value for \mathbf{x}^* using M ;
 - 2779 5. Decoding \mathbf{y}^f to get the forecast values of net positions.
- 2780 Next subchapters will describe each of these steps with more details.

2781

2782 2.1 Determination of patterns from the original times series variables

2783 Data pre-processing, based on patterns, simplifies the forecasting time series with multiple
2784 seasonal cycles. In our case, patterns of the daily cycles are introduced – the input patterns \mathbf{x} and
2785 output ones \mathbf{y} .

2786 Vector of input variables $\mathbf{v}_i = [v_{i,1} \ v_{i,2} \ \dots \ v_{i,n}]^T$, where $n = 24$ for hourly data time series, and
2787 $i = 1, 2, \dots, N$ is the daily period number (N is the number of days in the time series), represents
2788 historical data of net positions ($V = NP$), generation ($V = G$) and load ($V = L$). Therefore,
2789 using label \mathbf{v}_i , three input time series will be represented in following equations (1) and (2).

2790 The input pattern is a vector $\mathbf{x}_i = [x_{i,1} \ x_{i,2} \ \dots \ x_{i,n}]^T$, representing the vector of input variables in
2791 successive time points of the daily period \mathbf{v}_i . Functions of mapping the time series elements \mathbf{V}
2792 into patterns should maximize the model quality. In this study, the input pattern $x_{i,t}^V$,
2793 representing the i -th daily period and t -th hour, calculated for input variable \mathbf{V} , is defined
2794 as follows:

$$2795 \quad x_{i,t}^V = \frac{V_{i,t} - \bar{V}_i}{\sqrt{\sum_{k=1}^n (V_{i,k} - \bar{V}_i)^2}} \quad (1)$$

2796 , where:

2797 $k = 1, 2, \dots, n = 24$ is the time series element number in the daily period i ,

2798 $V_{i,t}$ is the t -th time series element in the period i ,

2799 \bar{V}_i is the mean value of input variables in the period i .

2800 Whilst \mathbf{x} -vectors represent input patterns (i.e. normalized values of input variables for the day i
2801), \mathbf{y} -vectors represent output patterns (i.e. the forecasted values of input variables for the day
2802 $i + \tau$, where τ is a forecast horizon stated in days). Components of the n -dimensional output

2803 pattern $\mathbf{y}_i = [y_{i,1} \ y_{i,2} \ \dots \ y_{i,n}]^T$, representing the input variable vector $\mathbf{V}_{i+\tau}$, are defined as
 2804 follows:

$$2805 \quad y_{i,t}^V = \frac{V_{i+\tau,t} - \bar{V}_i}{\sqrt{\sum_{k=1}^n (V_{i,k} - \bar{V}_i)^2}} \quad (2)$$

2806 , where $i = 1, 2, \dots, N - \tau$. This is the similar equation to (1), but in this case, we do not use the

2807 mean of input variable on the day $i + \tau$ ($\bar{V}_{i+\tau}$) in the numerator and $\sqrt{\sum_{k=1}^n (V_{i+\tau,k} - \bar{V}_{i+\tau})^2}$ in the
 2808 denominator, because these values are not known in the moment of forecasting. We use known

2809 values of \bar{V}_i and $\sqrt{\sum_{k=1}^n (V_{i,k} - \bar{V}_i)^2}$ instead.

2810 Using equations (1) and (2), we can calculate input (\mathbf{X}) and output (\mathbf{Y}) pattern matrices for all
 2811 three input variables: net positions, generation and load.

2812

2813

2814 2.2 Creation of the training set Φ

2815 The relationship between \mathbf{x} and \mathbf{y} -patterns of net positions can be nonlinear. In our approach,
 2816 this function is approximated locally in the neighborhood around the current input pattern for
 2817 which we want to get the forecast of net positions (we call this pattern a net position query
 2818 pattern \mathbf{x}^*). By the neighborhood of \mathbf{x}^* , in the simplest case, we consider the set of k nearest
 2819 neighbors, defined as the k net position \mathbf{x} -patterns from the history which are closest to \mathbf{x}^* in
 2820 terms of total Euclidean distance.

2821 Total Euclidean distance quantifies the resemblance between current day and rest of the days
 2822 from the history, taking into account their combined similarity of net positions, generation and
 2823 load, using the equation:

$$2824 \quad TED_i = ED_i^{NP} + ED_i^G + ED_i^L \quad (3)$$

2825 , where ED_i^{NP} , ED_i^G , ED_i^L are Euclidean distances for net position, generation and load time
 2826 series, respectively. Euclidean distance for input variable V could be calculated using equation:

$$2827 \quad ED_i^V = \sqrt{(x_{i,1}^V - x_1^{*V})^2 + (x_{i,2}^V - x_2^{*V})^2 + \dots + (x_{i,n}^V - x_n^{*V})^2} \quad (4)$$

2828 Sorting TED_i in descending order, we could find k smallest values and then include their
 2829 appropriate \mathbf{x} and \mathbf{y} -patterns of net positions into the training set Φ :

$$2830 \quad \Phi = \begin{Bmatrix} x_1^{NP} & x_2^{NP} & \dots & x_k^{NP} \\ \Downarrow & \Downarrow & \vdots & \Downarrow \\ y_1^{NP} & y_2^{NP} & \dots & y_k^{NP} \end{Bmatrix} = \begin{Bmatrix} \mathbf{X}^\Phi \\ \Downarrow \\ \mathbf{Y}^\Phi \end{Bmatrix} \quad (5)$$

2830

2831

2832

2833

2834 **2.3 Construction of the linear regression model M using PLSR method**

2835 In the neighborhood of \mathbf{x}^* the target function mapping \mathbf{x} -patterns to \mathbf{y} -patterns is less complex
 2836 than in the entire range of \mathbf{x} variation of net positions. It is assumed that for small set of Φ this
 2837 function can be approximated locally using linear regression.

2838 To simplify the regression model the problem of approximating the vector-valued function $\mathcal{g} :$
 2839 $\mathbf{X}^\Phi \rightarrow \mathbf{Y}^\Phi$ is decomposed into a set of problems of approximating the scalar-valued functions
 2840 $g_t : \mathbf{X}^\Phi \rightarrow \mathbf{y}_t^\Phi, t = 1, 2, \dots, n = 24$. Now instead of multivariate linear regression model the
 2841 multiple linear regression models can be used, one for each component of \mathbf{y}^f .

2842 The multiple linear regression model for forecasting net positions is in the form of:

2843
$$y_t = \beta_0 + \beta_1 \cdot x_1 + \beta_2 \cdot x_2 + \dots + \beta_n \cdot x_n \quad (6)$$

2844 , where $\beta_0, \beta_1, \beta_2, \dots, \beta_n$ are coefficients. Coefficients could be estimated using least-squares
 2845 fit. However, notice that in the local approach the number of points used to build a model (k)
 2846 can be less than their dimensionality and the number of free parameters of the model ($m = n + 1$)
 2847). In such case the model is oversized – it has too many degrees of freedom in relation to the
 2848 problem complexity expressed by only a few training points. In m -dimensional space, we need
 2849 at least m points to define a hyper plane. When $m > k$, we get an infinite number of solutions

2850 of regression model (6), i.e. the least squares coefficients β_j are not uniquely defined.

2851 Also, it is worth mentioning that components of \mathbf{x} -patterns representing subsequent elements of
 2852 time series are usually strongly correlated. Correlations between predictors indicate that some of
 2853 them are linear combination of others (multicollinearity). Building model on collinear predictors
 2854 leads to imprecise estimation of coefficients and missing importance of predictors. If predictors
 2855 carry similar information about the response variable, some of them can be ignored. One way to
 2856 deal with collinearity and excessive dimensionality is the creation of new predictors combining
 2857 the original ones.

2858 Partial least-squares regression (PLSR) produces new predictors (latent variables) which are
 2859 linear combinations of the original ones and are linearly uncorrelated. The first latent variable
 2860 has the largest sample variance. Subsequent latent variables have the highest variances possible
 2861 under the constraint that they are orthogonal to the preceding components. The latent variables
 2862 are used in place of the original predictors in the regression model:

2863
$$y_t = \beta_0 + \beta_1 \cdot z_1 + \beta_2 \cdot z_2 + \dots + \beta_c \cdot z_c \quad (7)$$

2864 , where z_j is the j -th latent variable, $c < n$ is the number of components included into the
 2865 model. There is no need to use all latent variables in the model, but only the first few ones (c),
 2866 because usually they explain most of the variability in the response variable. So, components
 2867 with the lowest variance can be discarded. PLSR searches for such orthogonal directions to
 2868 project \mathbf{x} -points that have the highest variance and highest correlation with the response. The
 2869 number of predictors used in the final model is a parameter of PLSR.

2870 Based on a training set Φ , linear regression model could be described using equation:

2871
$$y_t^\Phi = B_0 + B \cdot X^\Phi \quad (8)$$

2872 , where matrices of coefficients \mathbf{B}_0 and \mathbf{B} are determined, for every \mathbf{y}_t^Φ , using PLSR.
2873

2874 **2.4 Determination of the forecasted y_t^f value**

2875 Using constructed linear regression model M (used to calculate coefficient matrices \mathbf{B}_0 and \mathbf{B}
2876 in previous step) and query pattern \mathbf{x}^* , t -th component of forecasted net position y -pattern (y_t^f) can be calculated using equation:

$$2878 \quad y_t^f = B_0 + B \cdot x^* \quad (9)$$

2879
2880

2881 **2.5 Decoding y_t^f to get the forecast values of net positions**

2882 In final step, to get the forecasted net position at hour t for τ days ahead, we decode y_t^f
2883 according to equation (2), which now can be represented as:

$$2884 \quad NP_t^f = y_t^f \cdot \sqrt{\sum_{k=1}^n (NP_k^* - \overline{NP}^*)^2 + \overline{NP}^*} \quad (10)$$

2885
2886

2887 **3. Simulation results**

2888 In our example, the proposed linear models were examined in tasks of net position forecasting
2889 of Serbian TSO (EMS) power system for two days ahead ($\tau = 2$). The hourly input variable
2890 (net positions, generation and load) time series are from the period August 2015 – June 2017.
2891 The test samples are from January 2016 up to January 2017, i.e. we forecast net positions in the
2892 successive 365 days. Total Euclidean distance is used to select the nearest net position \mathbf{x} -
2893 patterns. For each hour of the day of forecast a separate model M is built. So, for our test
2894 samples $365 \cdot 24 = 8760$ models were constructed.
2895

2896 In order to find best values of PLSR parameters k and c , that provide the smallest root mean
2897 square error of net positions for test period, sensitivity analysis of net position forecast is
2898 implemented. Result of this analysis showed that the root mean square error decrease when the
2899 number of elements in set $\Phi(k)$ increase and the number of predictors (c) decrease. Based on
2900 that conclusion, models are constructed using 80 nearest neighbors of the net position query
2901 point \mathbf{x}^* from the history (i.e. they are selected from the period from 1st August 2015 until the
2902 day before the day of the forecast) and only 1 predictor (one new latent variable compresses
2903 information extracted from all original predictors). In such case, for some query pattern \mathbf{x}^* we
2904 get the forecast as: $y_t = \beta_0 + \beta_1 \cdot z_1$. It means that y -values of the nearest neighbors of \mathbf{x}^* are
2905 similar to each other. Remember that this liner model is valid only for this query point. For
2906 another query point we determine another set of neighbors and the hyper plane changes.


2907 As relative indicator for estimating quality of prediction of net positions forecasting methods,
 2908 we calculated percent value of mean absolute error (MAE):

$$MAE = \frac{BIAS}{MAN} = \frac{\sum_{t=1}^H |NP_t^f - NP_t^r|}{\sum_{t=1}^H |NP_t^r|} = \frac{\sum_{t=1}^H |NP_t^f - NP_t^r|}{\sum_{t=1}^H |NP_t^r|} \quad (11)$$

2909
 2910 , where:

2911 NP_t^f are forecasted net positions for t -th hour during test period,
 2912 NP_t^r are realized net positions for t -th hour during test period ,
 2913 $H = 24 \cdot N$ is total number of hours in test period.


2914
 2915 Calculation has showed that percentage MAE value for EMS is 19% for testing period.
 2916 Distribution of errors is displayed on Figure 22, where each bar represents number of errors that
 2917 had a value within specific range, also known as bin. Width of every bin is 10MW. In this case,
 2918 borders of bins are 1, 10, 20,..., 1000MW in positive direction, and same negative values in
 2919 opposite direction. The majority of errors is located around zero, indicating that the forecast has
 2920 the correct expectation. Also, it is noticeable that distribution is not symmetrical around mean
 2921 value, yet that negative errors are more dominant then positive ones, which means that our
 2922 methodology usually forecast smaller net positions, than realized ones.
 2923



2924
 2925 Figure 22: Dispersion of deviation between forecasted net position and realized net positions for EMS, for test period
 2926 of one year

2927
 2928 Finally, Figure 23 displays absolute forecast errors in decending order, for all 8760 hours from
 2929 test period. Calculating feasibility range (FR) as 2% of instantaneous peak load of TSO, for

2930 EMS we get value $FR \approx 150MW$ (based on instantaneous peak load for 2014). Errors smaller
2931 than 150MW occur 89% of a time, which means that majority of errors fall within feasibility
2932 range.



2933
2934 Figure 23: Absolute forecast errors for all test hours

2935

2936 III. ANNEX – Summary of parameters used

2937

2938 The present annex provides a list of the principal parameters used for easy reference.

2939

Symbol	Parameter / Variable	Explanations
PPD	Pre-processing data	PPD for each scenario consist of --preliminary net position --feasibility range --expected flows on DC lines --maximum import and export flows per DC line The PPD may optionally include the absolute minimum and/or maximum net position.
PNP_i	Preliminary net position for bidding zone i	In accordance with Article 18(3) of Regulation 2015/1222, this has to be a TSO's "best forecast".
FR_{pos}	Positive feasibility range	$FR_{pos} \geq 0$
FR_{neg}	Negative feasibility range	$FR_{neg} \leq 0$
$[FR_{neg}; FR_{pos}]$	Feasibility range	This interval has be at least equal to $2*\beta*WF*%$ (minimum feasibility range).
$[FR_{neg,i}; FR_{pos,i}]$	Feasibility range for bidding zone i	This interval has be at least equal to $2*\beta*WF*%$ (minimum feasibility range).
$[PNP_i + FR_{neg,i}; PNP_i + FR_{pos,i}] = [NP_{min,i}; NP_{max,i}]$	Minimum and maximum net positions (= end points of the range of acceptable balanced net positions around the preliminary net position for bidding zone i)	This interval has be at least equal to $2*\beta*WF*%$ (minimum feasibility range). The preliminary net position has to be inside the feasibility range.
$IPFlow_{k,i}$	Flow expected by TSO i on (DC) connection k	In accordance with Article 18(3) of Regulation 2015/1222, this has to be a TSO's "best forecast". Connection k has a defined direction from bidding zone i to bidding zone j
$IFlow_{min,k,i}$	Maximum import flow on (DC) connection k specified by TSO i	Has to respect the technical capacity of the connection. Sign convention: $IFlow_{min,k,i} \leq 0$
$IFlow_{max,k,i}$	Maximum export flow on (DC) connection k specified by TSO i	Has to respect the technical capacity of the connection. Sign convention: $IFlow_{max,k,i} \geq 0$
$PFlow_k$	Preliminarily balanced flow on (DC) connection k	$PFlow_k = \frac{IPFlow_{k,i} + IPFlow_{k,j}}{2}$
$Flow_{min,k}$	Maximum import flow on (DC) connection k	$Flow_{min,k} = \max(IFlow_{min,k,i}; IFlow_{min,k,j})$
$Flow_{max,k}$	Maximum export flow on (DC) connection k	$Flow_{max,k} = \min(IFlow_{max,k,i}; IFlow_{max,k,j})$
ABS_NP_MIN	Absolute minimum net position	Optional element of the PPD The balanced net position for a bidding zone must not be lower than the ABS_NP_MIN (if specified). The ABS_NP_MIN must respect the requirement that $ABS_NP_MIN \leq PNP_i + FR_{neg}$
ABS_NP_MAX	Absolute maximum net position	Optional element of the PPD The balanced net position for a bidding zone must not be greater than the ABS_NP_MAX (if specified). The ABS_NP_MAX must respect the requirement that $ABS_NP_MAX \geq PNP_i + FR_{pos}$
WF	Weighting factor	Provides a proxy for the ability of a bidding zone to accommodate a change in the (preliminary) net position of a given size. Is currently defined in terms of the instantaneous peak load of a bidding zone.

Symbol	Parameter / Variable	Explanations
$NP_{weight,i}$	Weighting factor for the adjustment of the net position of bidding zone i	
$F_{weight,k}$	Weighting factor for the adjustment of the flow on (DC) connection k	
β	Minimum feasibility range modifier	The minimum feasibility range is currently set at $2*\beta*WF*\%$. The β thus varies the width of the minimum feasibility range; the larger β , the larger the feasibility range required. The initial value for β is 1.
$\sum_i PNP_i$	Preliminary net position across all bidding zones	Sum of PNPs; corresponds to the aggregate forecast error
BNP_i	Balanced net position for bidding zone i	
$BFlow_k$	Balanced flow on connection k	

2940

2941

2942 **IV. ANNEX – Data Formats**

2943

2944 As of the summer of 2017, the question of which data formats will be used by the CGMA
2945 process has been resolved in principle. Contrary to the initial expectation, only one data format
2946 will be available for sending input data (the PPD) to the CGMA IT platform: CGMES – at least
2947 in version 2.4.15 – will not be suitable for transferring the PPD to the CGMA IT platform.
2948 However, a CIM-based format, the Reporting Information Market Document, is available for
2949 transferring the PPD to the CGMA IT platform and for sending the CGMA output data
2950 (balanced net positions and balanced flows on DC lines) back to TSOs and other relevant
2951 parties.

2952

2953 RIMD is building on existing formats developed for similar transfer purposes; specifically the
2954 data exchange with the Pan-European Verification Function (PEVF). These formats are similar
2955 to scheduling formats and, simplifying somewhat, may be thought of as all-purpose vehicles for
2956 transferring time series.

2957

2958 Sample files and xsd files have also been made available to CGM SPOCs shortly upon the
2959 release of the Implementation Guide.

2960

2961 As for the data to be transferred, the table below summarises the input data (as discussed in the
2962 present document):

2963

2964

No.	Data	Source	Originator	Format
1	Bidding Zone (known to the CGMA algorithm as "Optimisation Area")	CGMA user portal	AA	internal
2	AC Link	CGMA user portal	AA	Internal
3	DC Line	CGMA user portal	AA	internal
4	DC Max Flow (in)	OPDE	TSO	RIMD
5	DC Max Flow (out)	OPDE	TSO	RIMD
6	Weighting Factor for Bidding Zone (Optimization Area)	CGMA user portal	AA	Internal
7	Weighting Factor for DC line	CGMA user portal	AA	Internal
8	Preliminary Net Position (PNPs)	OPDE	TSO	RIMD
9	Preliminary DC Flow	OPDE	TSO	RIMD
10	Positive Feasibility Range for Adjustment of PNPs	OPDE	TSO	RIMD
11	Negative Feasibility Range for Adjustment of PNPs	OPDE	TSO	RIMD
12	ABS_NP_MIN and / or ABS_NP_MAX	OPDE	TSO	RIMD
13	Substitution values from verification platform (PEVF) for missing values	PEVF	PEVF	RIMD

2965

2966

Table 7: CGMA input data

2967

2968

2969

2970

2971

2972

2973

With respect to the column "Originator", note that in many cases the information could also be provided by a party other than the party listed here. This is of particular relevance with respect to the possible delegation to RSCs of the provision of PPD by the individual TSOs (whose obligation it is to provide these data).

2974 The output data to be provided are the following:

2975

No.	Data	Source	Format
1	Quality Gate Check Results	Quality Gate	Acknowledgement Problem Statement
2	Balanced Net Position	CGMA Algorithm	RIMD
3	Balanced DC Flow	CGMA Algorithm	RIMD
4	Indicative AC Flows	CGMA Algorithm	RIMD
5	Status Information from Optimization Run	CGMA Algorithm	internal
6	KPIs (Key Performance Indicators)	CGMA Algorithm / Quality Gate	proprietary XML

2976

2977

Table 8: CGMA output data²⁵

2978

²⁵ In addition to these output data narrowly defined, the CGMA IT platform also provides information on revised / substituted input data

2979 **V. ANNEX - Glossary**

2980

Term/Abbreviation	Definition	Source/Reference
Across-synchronous area DC line	DC line connecting different synchronous areas (and therefore different CGMA optimization areas)	
DC flows	Equivalent of "flows on DC lines" The terms "flows on DC lines" and "DC flows" are used interchangeably in the various CGMA-related documents (the present CGMAM, the CGMA IT specification, the CGMA Data Exchanges Implementation Guide). All documents make use of both terms which are equivalent.	
Minimum feasibility range	Currently set at $2 \cdot \beta \% \cdot WF$; i.e., the interval [FR_neg, FR_pos] has to be wider than or equal to $2 \cdot \beta \% \cdot WF$	PT CGM WP-5
Net position	the netted sum of electricity exports and imports for each market time unit for a bidding zone A more precise way of referring to net positions in the sense in which the term is used in the CGMAM would be to refer to "aggregate AC/DC net positions". However, the simpler (and slightly less accurate) term "net position" is used in the CGMAM in order to be consistent with the terminology in Regulation 2015/1222.	Article 2(5) of Regulation 2015/1222
Netted area position	Equivalent of "net position" The CGMA DExIG uses the term "netted area position" as this is consistent with an already existing business type (B65).	
Netted area AC position	Equivalent of "AC-only net position" Also see above	
Optimisation area	In connection with the CGMA algorithm, bidding zones (control areas) are referred to as "optimisation areas".	

Term/Abbreviation	Definition	Source/Reference
Pre-processing data (PPD)	<p>The PPD consist of</p> <ul style="list-style-type: none"> • the preliminary net position (PNP) • the feasibility range (FR) for the adjustment of the preliminary net position (FR_neg; FR_pos) • expected flows on DC lines • maximum import and maximum export flows on DC lines <p>The following additional data can be optionally submitted along with the PPD:</p> <ul style="list-style-type: none"> • absolute minimum and maximum net position (ABS_NP_MIN, ABS_NP_MAX) 	PT CGM WP-5
Weighting factor	CGMA-related parameter currently defined as a bidding zone's instantaneous peak load (IPL)	PT CGM WP-5
Within-synchronous area DC line	DC line fully within a synchronous area that connects different CGMA optimization areas	

2981
2982
2983

2984 **VI. ANNEX - CGM area in terms of coverage of bidding zones (as of**
2985 **2017-07) as well as DC lines**

2986

2987 The following table comprehensively describes the geographical coverage of the CGM on the
2988 level of bidding zones. It should be read in conjunction with the annotations related to Article 1
2989 of the CGMM. Unless noted otherwise, the bidding zones listed below are part of the CGM
2990 area.

2991

2992 In the case of TSOs managing more than one bidding zone, the TSO may provide a single IGM
2993 for the whole control area (although the information on the DC lines need not be included in the
2994 IGM and can be provided via an alternative route) and the TSO's website provides additional
2995 information about the composition of the bidding zones. A TSO managing several control areas,
2996 may, of course, provide several IGMs in line with the provision in Article 19 of Regulation
2997 2015/1222.

2998

2999 Additional information of interest may also be found in the "All TSOs' proposal for Capacity
3000 Calculation Regions (CCRs) in accordance with Article 15(1) of the Commission Regulation
3001 (EU) 2015/1222 of 24 July 2015 establishing a Guideline on Capacity Allocation and
3002 Congestion Management" published on the ENTSO-E website.

3003

3004 In multiple-TSO jurisdictions, Member States may have assigned responsibilities among the
3005 TSOs in a particular manner. The present overview table does not aim to provide details on this.
3006 It also does not provide information on EICs which may, however, be found in the CGMA IT
3007 specs.

3008

3009 Where TSOs have appointed Alignment Agents (RSCs), the name of the AA/RSC is added in
3010 square brackets as, for example, [Baltic RSC].

SUB-LINE	Synch. Area	Bidding zone	TSO(s)	EU member?	ENTSO-E member?	Comments
01	CE	AL	Operatori i Sistemitë Transmetimit (OST)	No, but Energy Community member	Yes	Albania provides its IGM and is part of the CGM area. [SCC]
02	CE	AT / DE / LU	Austrian Power Grid AG Vorarlberger Übertragungsnetz GmbH Eneco Valcanale S.r.l. 50Hertz Transmission GmbH Amprion GmbH TenneT TSO GmbH TransnetBW GmbH Creos Luxembourg S.A.	Yes	Yes (except Eneco Valcanale S.r.l.)	This bidding zone composition reflects the bidding zone configuration as of 2017-07. [TSCNET]
03	CE	BA	Nezavisni operator sustava u Bosni i Hercegovini (NOS BiH)	No, but Energy Community member	Yes	[SCC]
04	CE	BE	Elia System Operator SA	Yes	Yes	[CORESO]
05	CE	BG	Electroenergien Sistemen Operator EAD (ESO)	Yes	Yes	[SCC]
06	Baltic	BY	Belenergo Holding / Belarus TSO	No	No	Belarus <u>not</u> part of CGM area; interconnections to Belarus to be incorporated as injections by the TSOs of Lithuania and Poland

SUB-LINE	Synch. Area	Bidding zone	TSO(s)	EU member?	ENTSO-E member?	Comments
07	CE	CH	Swissgrid AG	No	Yes	Switzerland is part of the CGM area; legal questions related to Article 1 (4) and (5) of Regulation 2015/1222 are out of scope of the present document [TSCNET]
08	CE	CZ	ČEPS a.s.	Yes	Yes	[TSCNET]
09	CE	DK1	Energinet.dk	Yes	Yes	[Nordic RSC]
10	Nordic	DK2	Energinet.dk	Yes	Yes	[Nordic RSC]
11	Baltic	EE	Elering AS	Yes	Yes	[Baltic RSC]
12	CE	ES	Red Eléctrica de España S.A.	Yes	Yes	[CORESO]
13	Nordic	FI	Fingrid Oyj	Yes	Yes	[Nordic RSC]
14	CE	FR	Réseau de Transport d'Electricité	Yes	Yes	[CORESO]
15	GB	GB	National Grid Electricity Transmission plc Scottish Hydro Electric Transmission plc Scottish Power Transmission plc BritNed National Grid Interconnectors Ltd. Moyle Interconnector Ltd. Offshore Transmission Owners (OFTOs – not individually listed)	Yes	Yes Yes No No No No	[CORESO]
16	CE	GR	Independent Power Transmission Operator S.A.	Yes	Yes	

SUB-LINE	Synch. Area	Bidding zone	TSO(s)	EU member?	ENTSO-E member?	Comments
17	CE	HR	HOPS d.o.o.	Yes	Yes	[TSCNET]
18	CE	HU	MAVIR Magyar Villamosenergia-ipari Átviteli Rendszerirányító Zártkörűen Működő Részvénytársaság	Yes	Yes	[TSCNET]
19	IE / NI	IE/NI	EirGrid plc System Operator for Northern Ireland Ltd Moyle Interconnector Ltd.	Yes	Yes Yes No	[CORESO]
20	CE	IT1 (NORD)	Terna - Rete Elettrica Nazionale SpA	Yes	Yes	[CORESO]
21	CE	IT2 (CNOR)	Terna - Rete Elettrica Nazionale SpA	Yes	Yes	[CORESO]
22	CE	IT3 (CSUD)	Terna - Rete Elettrica Nazionale SpA	Yes	Yes	[CORESO]
23	CE	IT4 (SUD)	Terna - Rete Elettrica Nazionale SpA	Yes	Yes	[CORESO]
24	CE	IT5 (FOGN)	Terna - Rete Elettrica Nazionale SpA	Yes	Yes	[CORESO]
25	CE	IT6 (BRNN)	Terna - Rete Elettrica Nazionale SpA	Yes	Yes	[CORESO]
26	CE	IT7 (ROSN)	Terna - Rete Elettrica Nazionale SpA	Yes	Yes	[CORESO]
27	CE	IT8 (SICI)	Terna - Rete Elettrica Nazionale SpA	Yes	Yes	[CORESO]
28	CE	IT9 (PRGP)	Terna - Rete Elettrica Nazionale SpA	Yes	Yes	[CORESO]

SUB-LINE	Synch. Area	Bidding zone	TSO(s)	EU member?	ENTSO-E member?	Comments
29	CE	IT10 (SARD)	Terna - Rete Elettrica Nazionale SpA	Yes	Yes	Not included in CGM according to Terna (not relevant from a technical point of view)
30	Baltic	LT	Litgrid AB	Yes	Yes	[Baltic RSC]
31	Baltic	LV	AS Augstsprieguma tīkls	Yes	Yes	[Baltic RSC]
32	CE	MA	ONEE	No	No	Morocco <u>not</u> part of CGM area; interconnection to Morocco to be incorporated as injection by the TSO of Spain
33	CE	MD	Moldelectrica	No, but Energy Community member	No	Moldova <u>not</u> part of CGM area
34	CE	ME	Crnogorski elektroprenosni sistem AD	No, but Energy Community member	Yes	[SCC]
35	CE	MK	Macedonian Transmission System Operator AD	No, but Energy Community member	Yes	
36	CE	MT	Enemalta	Yes	No	Malta is <u>not</u> part of the CGM area as it only has a distribution network, not a transmission network. Following the commissioning of the interconnection linking Malta with Sicily, Malta is incorporated in the IGM of Terna, the Italian TSO, as an injection.
37	CE	NL	TenneT TSO B.V. BritNed	Yes	Yes No	[TSCNET]
38	Nordic	NO1	Statnett SF	No	Yes	Norway <u>is</u> part of the CGM area. One IGM is submitted for the combined Norwegian
39	Nordic	NO2	Statnett SF	No	Yes	
40	Nordic	NO3	Statnett SF	No	Yes	
41	Nordic	NO4	Statnett SF	No	Yes	

SUB-LINE	Synch. Area	Bidding zone	TSO(s)	EU member?	ENTSO-E member?	Comments
42	Nordic	NO5	Statnett SF	No	Yes	bidding zones. [Nordic RSC]
43	CE	PL	Polskie Sieci Elektroenergetyczne S.A.	Yes	Yes	[TSCNET]
44	CE	PT	Rede Eléctrica Nacional, S.A.	Yes	Yes	[CORESO]
45	CE	RO	C.N. Transelectrica S.A.	Yes	Yes	[TSCNET]
46	CE	RS	JP Elektromreža Srbije	No, but Energy Community member	Yes	[SCC]
47	Baltic	RU	FGC	No	No	Russia <u>not</u> part of CGM area; interconnections to Russia to be incorporated as injections by the TSOs of Finland, Estonia, Latvia, Lithuania, and Norway.
48	Nordic	SE1	Svenska Kraftnät	Yes	Yes	[Nordic RSC]
49	Nordic	SE2	Svenska Kraftnät	Yes	Yes	[Nordic RSC]
50	Nordic	SE3	Svenska Kraftnät	Yes	Yes	[Nordic RSC]
51	Nordic	SE4	Svenska Kraftnät	Yes	Yes	[Nordic RSC]
52	CE	SI	ELES, d.o.o.	Yes	Yes	[TSCNET]
53	CE	SK	Slovenská elektrizačná prenosová sústava, a.s.	Yes	Yes	
54	CE	TR	TEIAS	No	No	Turkey provides its IGM and <u>is</u> part of the CGM area.
55	CE	UA_W	WPS	No, but Energy Community member	No	Western Ukraine provides its IGM (six timestamps) and <u>is</u> part of the CGM area
56	CE	XK	KOSTT	No, but Energy Community member	No	Kosovo provides its IGM and <u>is</u> part of the CGM area

3011

3012

3013

3014

3015

3016

301 VII. ANNEX - CGM area in terms of coverage of CGMA algorithm
3018 optimisation areas (as of 2017-07) as well as DC lines

3019

3020 The present annex describes the composition of the CGM area in terms of CGMA optimisation
 3021 areas; i.e., those areas for which PPD are provided and for which balanced net positions etc. are
 3022 computed. Since the optimisation areas correspond to those areas for which IGMs are
 3023 contributed to the CGM process - i.e., do not correspond one-to-one to the bidding zones listed
 3024 in the preceding Annex VI - it seemed advisable to include a separate list of optimisation areas
 3025 in the present document.

3026

3027 Note that, as far as the CGMA algorithm and the CGMA IT platform are concerned, it will
 3028 always be possible (even at a later stage) to adjust the configuration of optimisation areas; i.e.,
 3029 their number and how they are linked. It will also be possible to set "valid from" dates
 3030 (differentiated by time horizon) in the CGMA IT platform such that for non-EU TSOs there is
 3031 some flexibility with respect to when they join the CGMA process.

3032

3033

Sub-line	Synch. Area	"Area" (ISO code)	IGM / PPD on the level of CA vs BZ	Comments (incl. on IPL availability)
01	CE	AL	IGM = CA = BZ = PPD	IPL figure not yet included in ENTSO-E document but obtained directly from OST
02	CE	AT	IGM = CA = PPD At present the AT control area is part of the wider AT-DE-LU bidding zone. The splitting up of the AT-DE-LU bidding zone into an AT BZ on the one hand and a DE-LU BZ on the other hand is under way. As far as the CGMA process is concerned that question is irrelevant in the sense that it is certain that --AT will provide an IGM on the level of its control area --AT will provide PPD on the level of its control area	IPL figure available
03	CE	BA	IGM = CA = BZ = PPD	IPL figure available
04	CE	BE	IGM = CA = BZ = PPD	IPL figure available
05	CE	BG	IGM = CA = BZ = PPD	IPL figure available
06	Baltic	BY	Belarus is not part of the CGM Area and does not constitute a CGMA optimisation area	(N.A.: not applicable)

Sub-line	Synch. Area	"Area" (ISO code)	IGM / PPD on the level of CA vs BZ	Comments (incl. on IPL availability)
07	CE	CH	IGM = CA = BZ = PPD	IPL figure available
08	CE	CZ	IGM = CA = BZ = PPD	IPL figure available
09	CE	DE_50Hz	IGM = CA = PPD At present all four German control areas are part of the wider AT-DE-LU bidding zone the breaking up of which is currently under way. As far as the CGMA process is concerned that question is irrelevant in the sense that it is certain that each of the DE TSOs will provide an IGM and PPD on the level of its control area. The IPL figure for Germany in the ENTSO-E Yearly Statistics & Adequacy Retrospect needs to be pro-rated in proportion to "vertikale Netzlast" (which DE TSOs are required to publish by law); see below for additional explanations.	IPL figure for all of DE available; this has been pro-rated in proportion to maximum "vertikale Netzlast" (see below for explanations)
10	CE	DE_Am-prion	IGM = CA = PPD (see explanations above)	(see above)
11	CE	DE_TenneT	IGM = CA = PPD (see explanations above)	(see above)
12	CE	DE_Trans-netBW	IGM = CA = PPD (see explanations above)	(see above)
13	CE	DK1	IGM = CA = BZ = PPD Denmark does not pose any particular conceptual challenges as far as the CGMA process is concerned. Denmark is modelled as two control areas which each correspond to a bidding zone. Denmark will thus provide two IGMs and two sets of PPD. The only remaining task is to split the DK weighting factor (available from the ENTSO-E document only on the level of the entire country) across the two CAs/BZs. The notes below explain how this pro-rating was done in proportion to yearly consumption.	IPL figure available; see below for additional explanations
14	Nordic	DK2	IGM = CA = BZ = PPD (see comment / explanation above)	(see above)
15	Baltic	EE	IGM = CA = BZ = PPD	IPL figure available
16	CE	ES	IGM = CA = BZ = PPD	IPL figure available
17	Nordic	FI	IGM = CA = BZ = PPD	IPL figure available
18	CE	FR	IGM = CA = BZ = PPD	IPL figure available

Sub-line	Synch. Area	"Area" (ISO code)	IGM / PPD on the level of CA vs BZ	Comments (incl. on IPL availability)
19	GB	GB	IGM = CA = BZ = PPD As far as the CGMA process is concerned, the United Kingdom consists of GB (England, Wales, Scotland) and NI (Northern Ireland). This subdivision is well established and, as far as GB is concerned, does not raise any particular questions.	IPL figure available
20	CE	GR	IGM = CA = BZ = PPD	IPL figure available
21	CE	HR	IGM = CA = BZ = PPD	IPL figure available
22	CE	HU	IGM = CA = BZ = PPD	IPL figure available
23	IE/NI	IE AND NI	The key to understanding how Ireland (Eirgrid) and Northern Ireland (SONI) are taken into account in the CGMA process is the observation that IE and NI will jointly provide an IGM which corresponds to their joint bidding zone and that they will also provide a single set of PPD for the CGMA process. They also jointly constitute a single LFC area/block. However, the Eirgrid and SONI grids do not constitute a single control area, but rather two separate control areas.	IPL figures available for both TSOs; the figures will be summed up in order to obtain the (single) weighting factor for the combined PPD
24	CE	IT	IGM = CA = PPD (CA does not correspond to BZ) Italy consists of a total of ten bidding zones. However, Terna submits a single IGM on the level of the control area which is also the relevant area with respect to the CGMA process.	IPL figure available
25	Baltic	LT	IGM = CA = BZ = PPD	IPL figure available

Sub-line	Synch. Area	"Area" (ISO code)	IGM / PPD on the level of CA vs BZ	Comments (incl. on IPL availability)
26	CE	LU	<p>IGM = CA = PPD</p> <p>At present LU and all four German control areas are part of the wider AT-DE-LU bidding zone (the breaking up of which is currently under way).</p> <p>At the time of writing (July 2017) the LU IGM is contained in the IGM provided by DE TSO Amprion. Creos is expecting to provide an IGM fully of its own in future although a timetable for this has not yet been set. This means that Creos will also have to join the CGMA process and provide PPD and LU will become one of the optimisation areas for the CGMA algorithm. As for the control area / bidding zone status of LU, LU constitutes a control area. LU and DE will continue to constitute a joint / common bidding zone.</p>	IPL figure available
27	Baltic	LV	IGM = CA = BZ = PPD	IPL figure available
28	CE	MA	Morocco is not part of the CGM Area and does not constitute a CGMA optimisation area	(N.A.: not applicable)
29	CE	MD	Moldova is not part of the CGM Area and does not constitute a CGMA optimisation area	(N.A.: not applicable)
30	CE	ME	IGM = CA = BZ = PPD	IPL figure available
31	CE	MK	IGM = CA = BZ = PPD	IPL figure available
32	CE	MT	<p>In terms of the practical handling envisaged for the time being, Malta will not provide an IGM to the CGM and will instead be incorporated into Terna's IGM as an injection.</p> <p>It would appear that Malta does not have a TSO nor a transmission system and that the requirements set out in Regulation 2015/1222 are not applicable. Article 1(2) of that Regulation stipulates that "This Regulation shall apply to all transmission systems and interconnections in the Union except the transmission systems on islands which are not connected with other transmission systems via interconnections."</p>	(N.A.: not applicable)
33	CE	NL	IGM = CA = BZ = PPD	IPL figure available
34	Nordic	NO	<p>IGM = CA = PPD (CA does not correspond to BZ)</p> <p>Norway consists of a total of five bidding zones. However, Statnett submits a single IGM on the level of the control area which is also the relevant area with respect to the CGMA process.</p>	IPL figure available

Sub-line	Synch. Area	"Area" (ISO code)	IGM / PPD on the level of CA vs BZ	Comments (incl. on IPL availability)
35	CE	PL	IGM = CA = BZ = PPD	IPL figure available
36	CE	PT	IGM = CA = BZ = PPD	IPL figure available
37	CE	RO	IGM = CA = BZ = PPD	IPL figure available
38	CE	RS	IGM = CA = BZ = PPD	IPL figure available
39	Baltic	RU	Russia is not part of the CGM Area and does not constitute a CGMA optimisation area	(N.A.: not applicable)
40	Nordic	SE	IGM = CA = PPD (CA does not correspond to BZ) Sweden consists of a total of four bidding zones. However, SvK submits a single IGM on the level of the control area which is also the relevant area with respect to the CGMA process.	IPL figure available
41	CE	SI	IGM = CA = BZ = PPD	IPL figure available
42	CE	SK	IGM = CA = BZ = PPD	IPL figure available
43	CE	TR	IGM = CA = BZ = PPD	IPL figure available
44	CE	UA_W	IGM = CA = BZ = PPD	IPL figure no longer included in ENTSO-E document
45	CE	XK	IGM = CA = BZ = PPD	IPL figure not yet included in ENTSO-E document but obtained directly from KOSTT

3034
3035

3036 Notes:

3037 Link to list of EIC approved Y (area) codes:

3038 https://www.entsoe.eu/fileadmin/user_upload/edi/library/eic/ars/area.htm

3039

3040 As a general rule whenever the IPL values (or other data required) cannot be obtained from the
3041 ENTSO-E Yearly Statistics and Adequacy Retrospect the relevant RSC shall be responsible for
3042 ensuring that the data are available.

3043

3044

3045 Notes on Denmark:

3046 Figures (approximately) corresponding to instantaneous peak load are not easily available
3047 separately for the two Danish control areas. The 2016 IPL figure for all of Denmark [6115 MW]
3048 was therefore pro-rated in proportion to yearly total consumption of electricity (in 2015). The
3049 resulting weighting factors for each of the Danish control areas are shown in the table below:

3050

Consumption in MWh				
(Source: NPS website)	DK1	DK2	DK	
2015	19768527	13039599	32808126	
Share in 2015 [%]	60.3%	39.7%		
Pro-rated IPL 2016 [MW]	3687	2428	6115	

3051 (For future – internal – reference: data sources and computations have been documented in file
3052 DK-pro-rating-IPL-in-proportion-to-consumption-2015.doc. Note that the consumption figures
3053 were not updated with figures for 2016 as the consumption shares of the two control areas were
3054 likely to have remained approximately constant.)

3055

3056

3057 Notes on Germany:

3058 The table below shows weighting factors for each of the four DE control areas obtained by pro-
 3059 rating the 2016 IPL figure for all of Germany [81945 MW] in proportion to the maximum value
 3060 of "vertikale Netzlast" in 2015. (For future – internal – reference: data sources and computations
 3061 have been documented in file DE-weighting-factors-as-of-2016-09-26-1700h.xls. Note that the
 3062 "vertikale Netzlast" figures were not updated with figures for 2016 although the figure for
 3063 maximum instantaneous peak load for Germany as a whole was.)

3064

Maximum "Vertikale Netzlast" [MW]	Share [%]	Year	DE IPL share [MW]	TSO
9268	17.6%	2015	14422	50Hertz
19312	36.6%	2015	29992	Amprion
16233	30.8%	2015	25239	TenneT
7907	15.0%	2015	12292	TransnetBW
52720			81945	

3065

3066

3067 Notes on Ireland:

3068

IPL 2015 IE [MW]	IPL 2015 NI [MW]	IPL 2015 IE/NI [MW]
4704	1758	6462

3069

3070 The source for the above data on IE and NI is the 2016 edition of ENTSO-E's Yearly Statistics
 3071 and Adequacy Retrospect (for internal reference: entsoe-2017-05-29-yearly-statistics-and-
 3072 adequacy-retrospect-2015.pdf) featuring data for calendar year 2015. The ENTSO-E Statistical
 3073 Factsheet with data for 2016 (cover-dated 04 May 2017) does not contain a breakdown for the
 3074 UK figure into separate GB and NI figures.

3075

3076 The following table summarises the DC lines that need to be included in the CGMA process. The figures in highlighted cells have not yet been
3077 reconfirmed by at least one of the TSOs:
3078

No. in map	Name	Synchronous Area 1	Synchronous Area 2	TSO 1	TSO 2	Bidding Zone 1	Bidding Zone 2	Country 1	Country 2	Max. export when TSO 1 is exporting [MW]	Max. export when TSO 2 is exporting [MW]	DC weighting factor [MW]
1	Moyle Interconnector	IE/NI	GB	SONI	National Grid	IE/NI	GB	UK	UK	300 (due to voltage stability issues)	500	300
2	East West Interconnector	IE/NI	GB	EirGrid	National Grid	IE/NI	GB	IE	UK	525	525	525
3	Britned	GB	Continental Europe	National Grid	TenneT NL	GB	NL	UK	NL	1000	1000	1000
4	IFA (Cross-Channel Interconnector linking GB and FR)	GB	Continental Europe	National Grid	RTE	GB	FR	UK	FR	2000	2000	2000
5	Norned	Nordic	Continental Europe	Statnett	TenneT NL	NO2	NL	NO	NL	723	723	723
6	Skagerrak (1-4; total of four cables)	Nordic	Continental Europe	Statnett	ENDK	NO2	DK1	NO	DK	1700	1700	1700
6-1	Skagerrak 1	Nordic	Continental Europe	Statnett	ENDK	NO2	DK1	NO	DK	250	250	250
6-2	Skagerrak 2	Nordic	Continental Europe	Statnett	ENDK	NO2	DK1	NO	DK	250	250	250
6-3	Skagerrak 3	Nordic	Continental Europe	Statnett	ENDK	NO2	DK1	NO	DK	500	500	500

No. in map	Name	Synchronous Area 1	Synchronous Area 2	TSO 1	TSO 2	Bidding Zone 1	Bidding Zone 2	Country 1	Country 2	Max. export when TSO 1 is exporting [MW]	Max. export when TSO 2 is exporting [MW]	DC weighting factor [MW]
6-4	Skagerrak 4	Nordic	Continental Europe	Statnett	ENDK	NO2	DK1	NO	DK	700	700	700
7	KontiSkand (1-2; total of two cables)	Nordic	Continental Europe	SvK	ENDK	SE3	DK1	SE	DK	720	720	720
7-1	KontiSkand 1	Nordic	Continental Europe	SvK	ENDK	SE3	DK1	SE	DK	360	360	360
7-2	KontiSkand 2	Nordic	Continental Europe	SvK	ENDK	SE3	DK1	SE	DK	360	360	360
8	StoreBælt	Nordic	Continental Europe	ENDK	ENDK	DK2	DK1	DK	DK	600	600	600
9	NordBalt	Nordic	Baltic	SvK	Litgrid	SE4	LT	SE	LT	738	738	738
10	SwePol	Nordic	Continental Europe	SVK	PSE	SE4	PL	SE	PL	600	600	600
11	Baltic Cable	Nordic	Continental Europe	SVK	TenneT DE	SE4	AT / DE / LU	SE	DE	600	600	600
12	Kontek	Nordic	Continental Europe	ENDK	50Hertz	DK2	AT / DE / LU	DK	DE	600	600	600
13-1	Estlink 1	Nordic	Baltic	Fingrid	Elering	FI	EE	FI	EE	366	366	366
13-2	Estlink 2	Nordic	Baltic	Fingrid	Elering	FI	EE	FI	EE	666	666	666
14	LitPol (back-to-back converter)	Baltic	Continental Europe	Litgrid	PSE	LT	PL	LT	PL	500	500	500

No. in map	Name	Synchronous Area 1	Synchronous Area 2	TSO 1	TSO 2	Bidding Zone 1	Bidding Zone 2	Country 1	Country 2	Max. export when TSO 1 is exporting [MW]	Max. export when TSO 2 is exporting [MW]	DC weighting factor [MW]
15*	Fenno-Skan (1-2; total of two cables)	Nordic	Nordic	SvK	Fingrid	SE3	FI	SE	FI	1229	1229	1229
15-1	Fenno-Skan 1	Nordic	Nordic	SvK	Fingrid	SE3	FI	SE	FI	410	410	410
15-2	Fenno-Skan 2	Nordic	Nordic	SvK	Fingrid	SE3	FI	SE	FI	819	819	819
16*	GRITA	Continental Europe	Continental Europe	Terna	ADMIE	IT6	GR	IT	GR	500	500	500

*: DC lines fully within synchronous areas; the preliminary DC flows on these lines are made consistent by the Quality Gate; however, for the time being these preliminary DC flows are not being modified as part of the operation of the CGMA algorithm. As of July 2017, these are the only operational DC lines within synchronous areas also operated as such.


3079

3080

Table 9: DC lines to be included in CGMA process (as of 2017-07)

3081
3082
3083

The following map provides a stylized topology of the CGMA optimisation areas:



3084
3085

Figure 24: Stylised topology of CGMA optimisation areas