



Brussels, **XXX**
[...](2016) **XXX** draft

ANNEX 1

ANNEX

to the

Commission Regulation (EU)../..

establishing a network code on electricity emergency and restoration

ANNEX

to the

Commission Regulation (EU)..../..

establishing a network code on electricity emergency and restoration

Automatic low frequency demand disconnection scheme characteristics:

Parameter	Values SA Continental Europe	Values SA Nordic	Values SA Great Britain	Values SA Ireland	Measuring Unit
Demand disconnection starting mandatory level : Frequency	49	48.7 – 48.8	48.8	48.85	Hz
Demand disconnection starting mandatory level: Demand to be disconnected	5	5	5	6	% of the Total Load at national level
Demand disconnection final mandatory level: Frequency	48	48	48	48.5	Hz
Demand disconnection final mandatory level: Cumulative Demand to be disconnected	45	30	50	60	% of the Total Load at national level
Implementation range	±7	±10	±10	±7	% of the Total Load at national level, for a given Frequency
Minimum number of steps to reach the final mandatory level	6	2	4	6	Number of steps
Maximum Demand disconnection for each step	10	15	10	12	% of the Total Load at national level, for a given step