


# WG03 Report

---

COMPILED BY THOMAS SCHAUPP (KACO)

# prEN50549-1; -2



- Status:
  - all comments discussed
  - Implementation of decisions ongoing
- Schedule:
  - 1 Draft before end of the year
  - WG03 consultations regarding implementation in January
  - Dealing with comments and implementation: duration expected 5 Month instead of 3 Months planned
  - Schedule delay of ca. 2 Month resulting in an estimated publication in July

# Updated Planning EN50549-1; -2

	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18
combined Adapt to NC RfG																		
WG comments on WG Draft -1-1 and -2																		
Dealing with WG comments on Draft -1-1 and -2 combined																		
<b>Deliver splitted draft for Enquiry to CCMC</b>																		
CCMC editing (3 months) - optional																		
Enquiry (3 months)		3m																
Dealing with comments from NC's				5m														
<b>Deliver draft for voting to CCMC</b>																		
CCMC editing (2,5 months)										2,5m								
Voting by NC's (2 months)												2m						
Final editorial review by CCMC																		

# Needed clarification

---

CENELEC TC8X WG03 asks for further clarification

5 Questions from CENELEC to ESC

- Four questions have been answered

One question still open

- May a European Standard impose more stringent requirements than imposed by NC RfG and may member states use such a standard?

As no indication to these matters have been given by GC ESC, CENELEC WG03 concluded in all conscience.

EN50549 is drafted

- Assuming the conclusions of the CENELEC presentation to the 7th Meeting correct,
- Including FRT for type A as a recommendation, but not a requirement.

# Conclusion

---

- **WG03 considers EN50549-1 and EN50549-2 to be in line with RfG**

If a member state chooses to do so,

- **EN50549-1 and -2 can be used as part of the national implementation of RfG**
- **Once published, EN50549-1 and -2 should be seen as technical standard in the sense of RfG recital 27**